#1 - DHFS WALL CLOSURE INSPECTION

Facility:		
Date:	Project:	DHFS Inspector:
"X" ID# if NA	Portion of Proj:	DHFS Proj #:

TOPIC	ID	ITEM	INSPECTION SPOT CHECK METHOD	Room # where Correction is Needed
Fire Proofing	1	Wall butt	Top Track tight to steel [220 §3]	
	2	Wall butt	Hat Channel tight to steel [220 §3]	
	3	Fireproofing-Missing	Missing/thin insulation [220 §3]	
	4	Attachment-small	Beam clamps & small attachments [220 §3]	
	5	Attachment-large	Large attachments [220 §3]	
	6	Utility butt	Adjacent piping/duct [220 §3]	
Penetrations	7	Penetrations-Floor	In-wall cavities for UL design quality [101 §8.2.3.2.4.2]	
Other	8			