



You ARE the Inspector



WHEA
Lunch & Learn

PART 2

Bill Lauzon
Heather Lauzon Werner

Thurs Mar 10, 2016
11:30-1:00

Lauzon Life Safety Consulting, LLC

You ARE the Inspector



PART 1

WHEA Annual Conference

**Friday Sept 25, 2015
8:30-10:30 am**




INSPECTIONS




There are **5**
methods of
getting
inspections
done

1. Let the AHJ Do it




(Unfocused)

2. Hire an Expert



3. Do it Yourself



(Unfocused)

FOCUSED INSPECTIONS

are the **BEST**
method for
**NON-
PROFESSIONALS**



FOCUSED INSPECTIONS

What is the
Focused
Inspection
Method?




FOCUSED INSPECTIONS

**Conduct
Separate
Inspections
that are each
FOCUSED
on a single topic**



4. Do it All Yourself



(Focused)

5. Develop Staff Experts

Ceilings



Exit
Signs



Doors



Walls



Stairs &
Discharges



Ventilation



Constr
Type



Above
Ceiling



Gorridors



Sprinklers



Fire
Alarm



Electrical




(Focused)

You ARE the ^{most important} Inspector

Focused Inspections

WHY?



WHY Focused Inspections ?


You catch more
issues !



WHY Focused Inspections ?

1. Easy to get side tracked


- Disruptions
- Concentrate on one thing & overlook others



WHY Focused Inspections ?

2. Too familiar with building


- “Always been there”
- Issues don't stand out



WHY Focused Inspections ?

3. Too Many Codes to Know


- There are dozens of codes
- There are thousands of requirements



WHY Focused Inspections ?

4. Not Enough Time in Day

- Have dozens of things to do
- Important/Severity Matrix



WHY Focused Inspections ?

- 1. Easy to get side tracked**
- 2. Too familiar with building**
- 3. Too Many Codes to Know**
- 4. Not Enough Time in Day**

THE RESULT?



WHY Focused Inspections ?

**MISSED ISSUE
IDENTIFICATION!**



HOW LONG must I do Focused Inspections ?

**You FOCUS until issues
automatically pop-out at you when
you walk into a room**

MOST COMMON CITES

% of CMS Surveys

- | | |
|------------------------|-----|
| 1. Sprinkler Reports | 58% |
| 2. Fire Drills | 42% |
| 3. Electrical Issues | 35% |
| 4. Hazardous Rooms | 33% |
| 5. Sprinkler Install | 29% |
| 6. Fire Alarm Reports | 39% |
| 7. Path of Egress | 22% |
| 8. Corridor Doors | 20% |
| 9. Smoke Barriers | 13% |
| 10. Generator Reports | 13% |
| 11. Fire Alarm Install | 13% |

% of TJC EC/LS Cites

- | | |
|---------------------------------|-----|
| 1. Fire Alarm/Sprinkler Reports | 76% |
| 2. Ventilation | 50% |
| 3. Sprinkler Install | 40% |
| 4. Fire Stopping | 24% |
| 5. Obstructions | 22% |
| 6. Hazardous Rooms | 21% |
| 7. Shutdown Labels | 21% |
| 8. Corridor Doors | 19% |
| 9. Path of Egress Locks | 17% |
| 10. Smoke Barriers | 14% |

Remove Documentation

% of CMS Surveys

1. Sprinkler Reports	58%
2. Fire Drills	42%
3. Electrical Issues	35%
4. Hazardous Rooms	33%
5. Sprinkler Install	29%
6. Fire Alarm Reports	39%
7. Path of Egress	22%
8. Corridor Doors	20%
9. Smoke Barriers	13%
10. Generator Reports	13%
11. Fire Alarm Install	13%

% of TJC EC/LS Cites

1. Fire Alarm/Sprinkler Reports	76%
2. Ventilation	50%
3. Sprinkler Install	40%
4. Fire Stopping	24%
5. Obstructions	22%
6. Hazardous Rooms	21%
7. Shutdown Labels	21%
8. Corridor Doors	19%
9. Path of Egress Locks	17%
10. Smoke Barriers	14%

12 Steps of Focused Inspections

% of CMS Surveys

1. Sprinkler Reports	58%
2. Fire Drills	42%
3. Electrical Issues	35%
4. Hazardous Rooms	33%
5. Sprinkler Install	29%
6. Fire Alarm Reports	39%
7. Path of Egress	22%
8. Corridor Doors	20%
9. Smoke Barriers	13%
10. Generator Reports	13%
11. Fire Alarm Install	13%

% of TJC EC/LS Cites

1. Fire Alarm/Sprinkler Reports	76%
2. Ventilation	50%
3. Sprinkler Install	40%
4. Fire Stopping	24%
5. Obstructions	22%
6. Hazardous Rooms	21%
7. Shutdown Labels	21%
8. Corridor Doors	19%
9. Path of Egress Locks	17%
10. Smoke Barriers	14%

COVERS ALL BUT 1

12 STEP FOCUSED INSPECTIONS


6 STEP 'FOCUSED' INSPECTION CHECKLIST			*Code Tool Box Page #	**Code CMS Page #
STEP	AREA	THINGS TO CHECK		
1	CEILINGS & FLOORS	1.0 <input type="checkbox"/> Sprinkler Locations (max 7.5' to wall, 6'-15' apart, 12"/22" down)	96:99	12:35
		1.1 <input type="checkbox"/> Sprinkler Unit (none)	7	25:15
		1.2 <input type="checkbox"/> Hanging Objects (nothing on sprinklers or pipes or obstruct flow)	25	25:16
		1.3 <input type="checkbox"/> Smoke Detector Locations (max 15' to wall, 30' apart, 12" down)	44	72:32
		1.4 <input type="checkbox"/> Holes/Gaps in Ceiling Grid & Penetrations (max 1/16" gaps) (Egg Co)	7	19:30
		1.5 <input type="checkbox"/> Washable Ceiling Tiles in Patient Care Areas	7	124:132
		1.6 <input type="checkbox"/> Ceiling Height (Min 7'11" new; 6'8" existing)	18	101:43
		1.7 <input type="checkbox"/> Egress Obstructions (nothing within 4'/8" corridor path)	19	101:150
2	EXIT SIGNS	1.8 <input type="checkbox"/> Fireproofing on Beams & Columns	102	102:148
		2.1 <input type="checkbox"/> Sign Needed if Egress Path isn't Readily Apparent		
		2.2 <input type="checkbox"/> Check Within Suites (multiple doors may need sign)		
		2.3 <input type="checkbox"/> Sign Must be Readable from Any Direction of Egress		
		2.4 <input type="checkbox"/> Signs at Cross-Corridor Doors (both sides)		
		2.5 <input type="checkbox"/> Signs at Changes of Direction (with arrow)		
		2.6 <input type="checkbox"/> Obstructions of Signs (pipes, signs, lights, etc)		
		2.7 <input type="checkbox"/> NO exit signs if Looks Like an Exit (correct wording, size)		
3	DOORS	3.0 <input type="checkbox"/> Know Purpose(s) of Door (corridor, smoke, hazard, exit, etc)		
		3.1 <input type="checkbox"/> Astragal Needed at New Exit Doors; Existing if Gap > 3/8"		
		3.2 <input type="checkbox"/> Force to Open (<15# latch, 30# max, 15# full open; 50 # existing)		
		3.3 <input type="checkbox"/> Rating of Door & Frame (20/45/60/90 min) (esp Aluminum)		
		3.4 <input type="checkbox"/> Closer on All Rated Doors; Test Coordinator Function		
		3.5 <input type="checkbox"/> Mag Hold-Open on Rated Doors w/Smoke Detector max 5' Away		
		3.6 <input type="checkbox"/> Positive Self-Latch (corridor & rated doors except smoke bar; push-pull)		
		3.7 <input type="checkbox"/> Must Unlatch with Single Motion of a Hand (DEAD-BOLT)		
4	RATED WALLS	3.8 <input type="checkbox"/> Cannot Lock from Egress Side (except for Clinical Pt Need)		
		3.9 <input type="checkbox"/> No Grills or Louvers		
		4.1 <input type="checkbox"/> Purpose of Wall (corridor, smoke, hazard, exit, separation etc)		
		4.2 <input type="checkbox"/> Top of Wall (rated has fire seal)		
		4.3 <input type="checkbox"/> Seams & Screws (double coats on both)		
		4.4 <input type="checkbox"/> Rooms used for Storage of Any Amount		
		4.5 <input type="checkbox"/> Wall Patch Seams & Screws (Joint Compound; no Fire Sealant)		
		4.6 <input type="checkbox"/> Meltable Penetrations Must Be Intumescent Sealed (Cable, PVC, Insul)		
5	STAIRS & EXIT DISCHARGE	4.7 <input type="checkbox"/> Metal Penetrations & Holes Fire-Stopped (Conduits, Copper, pipes)		
		5.1 <input type="checkbox"/> Lights Constantly On (motion sensor okay; no switches)	75	101:45
		5.2 <input type="checkbox"/> Redundant Lighting (Two Lamps Along Entire Path)	75	101:50
		5.3 <input type="checkbox"/> Emergency Power Source (Generator or Battery)	75	101:45
		5.4 <input type="checkbox"/> Interruption at Discharge (gate or door)	102	101:65
		5.5 <input type="checkbox"/> Level Landing on Both Sides of Door	102	101:40
		5.6 <input type="checkbox"/> Level Walk Surface (Beveled > 1/4")	102	101:44
		5.7 <input type="checkbox"/> Direct Discharge or Exit Passageway (direct outside)	108	101:64
6	VENTILATION	6.1 <input type="checkbox"/> Mechanical Room Risers (Look for Shafts)	88	101:71
		6.2 <input type="checkbox"/> Direct Make-Up Air for Combustion Devices	108	101:154
		6.3 <input type="checkbox"/> Dampers at Floors	48	104:10
		6.4 <input type="checkbox"/> Dampers at Shaft & 2 Hr Walls	48	104:10
		6.5 <input type="checkbox"/> Corridor Neutral Air Flow - No Air Flow In/Out (Except for Infect Control)	107	104:9
		6.6 <input type="checkbox"/> Room Has Both Supply & Return/Exhaust Grills (if door is to corridor)	108	104:9
		6.7 <input type="checkbox"/> Dust on Frame Stops (esp: mech, elect, hsig, etc)	108	104:9



FOCUSED' INSPECTION CHECKLIST-B (#7-12)			*Code Tool Box Page #	**Code CMS Page #
SYS	AREA	THINGS TO CHECK		
7	CONSTR TYPE	7.0 <input type="checkbox"/> Confirm Occupancy, # Floors, Constr Date; Confirm Code Requirements		
		7.1 <input type="checkbox"/> Above Ceiling Inspection (Confirm Constr Type)		
		7.2 <input type="checkbox"/> Stacked Constr Types		
		7.3 <input type="checkbox"/> Beam & Column Fire proofing (Structural only)		
		7.4 <input type="checkbox"/> Beam & Column Encapsulation (Structural only)		
		7.5 <input type="checkbox"/> Floor Penetrations		
		7.6 <input type="checkbox"/> Building Separation Walls		
		7.7 <input type="checkbox"/> Non-Combustible Wall Materials		
8	ABOVE CEILING	8.0 <input type="checkbox"/> Top of Wall Sealing		
		8.1 <input type="checkbox"/> Fire Stopping & Joint Sealing		
		8.2 <input type="checkbox"/> Rated Wall Construction		
		8.3 <input type="checkbox"/> Sprinkler Support		
		8.4 <input type="checkbox"/> Open Electrical Boxes; Abandoned Wiring		
		8.5 <input type="checkbox"/> Damper Access		
		8.6 <input type="checkbox"/> Perforated Tiles Intact		
		9.0 <input type="checkbox"/> Confirm Corridor Location Properly Shown on LSP		
9	CORRIDOR	1.1 <input type="checkbox"/> Dead End Corridors		
		1.2 <input type="checkbox"/> Exit in Both Directions		
		1.3 <input type="checkbox"/> Spaces Open to Corridors - Smoke Detectors		
		1.4 <input type="checkbox"/> Doors (see Focused Inspection #3) & Windows		
		1.5 <input type="checkbox"/> Above Ceiling Walls vs Ceiling		
		1.6 <input type="checkbox"/> Walls Smoke Resistant		
		1.7 <input type="checkbox"/> Width & Obstructions		
		1.8 <input type="checkbox"/> Decorations & Storage		
10	SPRINKLER	1.9 <input type="checkbox"/> Suite Size & Travel Distance		
		10.0 <input type="checkbox"/> Sprinkler Locations (max 7.5' to wall, 6'-15' apart, 12"/22" down)		
		10.1 <input type="checkbox"/> Sprinkled When Required		
		10.2 <input type="checkbox"/> Coverage, Shadows, Obstructions		
		10.3 <input type="checkbox"/> Fire Pump		
		10.4 <input type="checkbox"/> Roof Eave; Canopies		
		10.5 <input type="checkbox"/> Mesh Curtains		
		10.6 <input type="checkbox"/> Fire Extinguisher Obstruction		
11	FIRE ALARM	11.0 <input type="checkbox"/> Panel Security, Power Source ID, Breaker Label & Red		
		11.1 <input type="checkbox"/> Panel Smoke Detector		
		11.2 <input type="checkbox"/> Pull Station Obstruction		
		11.3 <input type="checkbox"/> Notification Devices (audible & visual)		
		11.4 <input type="checkbox"/> Tamper Switches		
		11.5 <input type="checkbox"/> Smoke Detector Location		
12	ELECTRICAL	12.0 <input type="checkbox"/> Plug Strips & Extension Cords		
		12.1 <input type="checkbox"/> Breaker Labeling		
		12.2 <input type="checkbox"/> Panel Clearance		
		12.3 <input type="checkbox"/> Hospital Grade Outlets (Green Dot)		
		12.4 <input type="checkbox"/> GFI Outlets		
		12.5 <input type="checkbox"/> Emergency Lighting		
		12.6 <input type="checkbox"/> Generators-Remote Stop, Annunciator		

* Page in LLSC Code Tool Box, 2013 edition ** Page in CMS adopted code shown © London Life Safety Consulting, LLC; Mar 2016


6 STEP FOCUSED INSPECTIONS




See FULL size form
on slide #41

STEP		AREA	THINGS TO CHECK	*Code Tool # Page #	**Code Page #
1	CEILINGS & FLOORS	1.0	<input type="checkbox"/> Sprinkler Locations (max 7.5' to wall, 6'-15' apart, 12"/22" down)	96,99	13:35
		1.1	<input type="checkbox"/> Sprinkler Lint (none)	7	25:15
		1.2	<input type="checkbox"/> Hanging Objects (nothing on sprinklers or pipes or obstruct flow)	25	25:16
		1.3	<input type="checkbox"/> Smoke Detector Locations (max 15' to wall; 30' apart, 12" down)	44	72:32
		1.4	<input type="checkbox"/> Holes/Gaps in Ceiling Grid & Penetrations (max 1/16" gaps) (Egg Crates)	7	13:30
		1.5	<input type="checkbox"/> Washable Ceiling Tiles in Patient Care Areas	7	124:132
		1.6	<input type="checkbox"/> Ceiling Height (Min 7'0" new; 6'8" existing)	88	101:43
		1.7	<input type="checkbox"/> Egress Obstructions (nothing within 4'/8' corridor path)	59	101:150
		1.8	<input type="checkbox"/> Fireproofing on Beams & Columns	57	101:148
2	EXIT SIGNS	2.1	<input type="checkbox"/> Sign Needed If Egress Path isn't Readily Apparent	41	101:66
		2.2	<input type="checkbox"/> Check Within Suites (multiple doors may need sign)	41	101:66
		2.3	<input type="checkbox"/> Sign Must be Readable from Any Direction of Egress	41	101:66
		2.4	<input type="checkbox"/> Signs at Cross-Corridor Doors (both sides)	41	101:66
		2.5	<input type="checkbox"/> Signs at Changes of Direction (with arrow)	41	101:67
		2.6	<input type="checkbox"/> Obstructions of Signs (pipes, signs, lights, etc)	41	101:66
		2.7	<input type="checkbox"/> NO exit signs if Looks Like an Exit (correct wording, size)	41	101:67
		3.0	<input type="checkbox"/> Know Purpose(s) of Door (corridor, smoke, hazard, exit, etc)	30	101:149
3	DOORS	3.1	<input type="checkbox"/> Astragal Needed at New Dbl Doors; Existing if Gap > 1/8"	30	101:150
		3.2	<input type="checkbox"/> Force to Open (<15# latch, 30# start, 15# full open; 50 # existing)	30	101:45
		3.3	<input type="checkbox"/> Rating of Door & Frame (20/45/60/90 min) (esp Aluminum)	30	101:69
		3.4	<input type="checkbox"/> Closer on All Rated Doors; Test Coordinator Function	30	101:69
		3.5	<input type="checkbox"/> Mag Hold-Open on Rated Doors w/Smoke Detector max 5' Away	29	101:47
		3.6	<input type="checkbox"/> Positive Self-Latch (corridor & rated doors except smoke bar; push-pull)	30	101:69
		3.7	<input type="checkbox"/> Must Unlatch with Single Motion of a Hand (DEAD-BOLT)	39	101:46
		3.8	<input type="checkbox"/> Cannot Lock from Egress Side (except for Clinical Pt Need)	32	101:46
		3.9	<input type="checkbox"/> No Grills or Louvers	30	101:69
		4.1	<input type="checkbox"/> Purpose of Wall (corridor, smoke, hazard, exit, separation etc)	112	101:149
4	RATED WALLS	4.2	<input type="checkbox"/> Top of Wall (rated has fire seal)	112	101:69
		4.3	<input type="checkbox"/> Seams & Screws (double coats on both)	112	101:69
		4.4	<input type="checkbox"/> Rooms used for Storage of Any Amount	62	101:66
		4.5	<input type="checkbox"/> Wall Patch Seams & Screws (Joint Compound; no Fire Sealant)	112	101:69
		4.6	<input type="checkbox"/> Meltable Penetrations Must Be Intumescent Sealed(Cable, PVC, Insul)	53,55	101:69
		4.7	<input type="checkbox"/> Metal Penetrations & Holes Fire-Stopped (Conduits, Copper, pipes)	52,54	101:69
		5.1	<input type="checkbox"/> Lights Constantly On (motion sensor okay; no switches)	75	101:65
		5.2	<input type="checkbox"/> Redundant Lighting (Two Lamps Along Entire Path)	75	101:65
5	STAIRS & EXIT DISCHARGE	5.3	<input type="checkbox"/> Emergency Power Source (Generator or Battery)	75	101:65
		5.4	<input type="checkbox"/> Interruption at Discharge (gate or door)	102	101:65
		5.5	<input type="checkbox"/> Level Landing on Both Sides of Door	102	101:45
		5.6	<input type="checkbox"/> Level Walk Surface (Beveled > 1/4")	102	101:44
		5.7	<input type="checkbox"/> Direct Discharge or Exit Passageway (direct outside)	103	101:64
		6.1	<input type="checkbox"/> Mechanical Room Risers (Look for Shafts)	88	101:71
		6.2	<input type="checkbox"/> Direct Make-Up Air for Combustion Devices	108	101:154
6	VENTILATION	6.3	<input type="checkbox"/> Dampers at Floors	48	90A:10
		6.4	<input type="checkbox"/> Dampers at Shaft & 2 Hr Walls	48	90A:10
		6.5	<input type="checkbox"/> Corridor Neutral Air Flow - No Air Flow In/Out (Except for Infect Control)	107	90A:9
		6.6	<input type="checkbox"/> Room Has Both Supply & Return/Exhaust Grills (if door is to corridor)	108	90A:9
		6.7	<input type="checkbox"/> Dust on Frame Stops (esp: mech, elect, hskg, etc)	108	90A:9

2nd-6 STEP FOCUSED INSPECTIONS



See FULL size form
on slide #42


SYS		AREA	THINGS TO CHECK	
7	CONSTR TYPE	 262-943-4567 Lauton Life Safety Consulting	7.0	<input type="checkbox"/> Confirm Occupancy, # Floors, Constr Date; Confirm Code Requirements
			7.1	<input type="checkbox"/> Above Ceiling Inspection (Confirm Constr Type)
			7.2	<input type="checkbox"/> Stacked Constr Types
			7.3	<input type="checkbox"/> Beam & Column Fire proofing (Structural only)
			7.4	<input type="checkbox"/> Beam & Column Encapsulation (Structural only)
			7.5	<input type="checkbox"/> Floor Penetrations
			7.6	<input type="checkbox"/> Building Separation Walls
			7.7	<input type="checkbox"/> Non-Combustible Wall Materials
8	ABOVE CEILING	8.0	<input type="checkbox"/> Top of Wall Sealing	
		8.1	<input type="checkbox"/> Fire Stopping & Joint Sealing	
		8.2	<input type="checkbox"/> Rated Wall Construction	
		8.3	<input type="checkbox"/> Sprinkler Support	
		8.4	<input type="checkbox"/> Open Electrical Boxes; Abandoned Wiring	
		8.5	<input type="checkbox"/> Damper Access	
		8.6	<input type="checkbox"/> Perforated Tiles Intact	
9	CORRIDORS	9.0	<input type="checkbox"/> Confirm Corridor Location Properly Shown on LSP	
		9.1	<input type="checkbox"/> Dead End Corridors	
		9.2	<input type="checkbox"/> Exit in Both Directions	
		9.3	<input type="checkbox"/> Spaces Open to Corridors - Smoke Detectors	
		9.4	<input type="checkbox"/> Doors (see Focused Inspection #3) & Windows	
		9.5	<input type="checkbox"/> Above Ceiling Walls vs Ceiling	
		9.6	<input type="checkbox"/> Walls Smoke Resistant	
		9.7	<input type="checkbox"/> Width & Obstructions	
		9.8	<input type="checkbox"/> Decorations & Storage	
		9.9	<input type="checkbox"/> Suite Size & Travel Distance	
10	SPRINKLER	10.0	<input type="checkbox"/> Sprinkler Locations (max 7.5' to wall, 6'-15' apart, 12"/22" down)	
		10.1	<input type="checkbox"/> Sprinkled When Required	
		10.2	<input type="checkbox"/> Coverage, Shadows, Obstructions	
		10.3	<input type="checkbox"/> Fire Pump	
		10.4	<input type="checkbox"/> Roof Eave; Canopies	
		10.5	<input type="checkbox"/> Mesh Curtains	
		10.6	<input type="checkbox"/> Fire Extinguisher Obstruction	
11	FIRE ALARM	11.0	<input type="checkbox"/> Panel Security, Power Source ID, Breaker Label & Red	
		11.1	<input type="checkbox"/> Panel Smoke Detector	
		11.2	<input type="checkbox"/> Pull Station Obstruction	
		11.3	<input type="checkbox"/> Notification Devices (audible & visual)	
		11.4	<input type="checkbox"/> Tamper Switches	
		11.5	<input type="checkbox"/> Smoke Detector Location	
12	ELECTRICAL	12.0	<input type="checkbox"/> Plug Strips & Extension Cords	
		12.1	<input type="checkbox"/> Breaker Labeling	
		12.2	<input type="checkbox"/> Panel Clearance	
		12.3	<input type="checkbox"/> Hospital Grade Outlets (Green Dot)	
		12.4	<input type="checkbox"/> GFI Outlets	
		12.5	<input type="checkbox"/> Emergency Lighting	
		12.6	<input type="checkbox"/> Generators-Remote Stop, Annunciator	

* Page in LLSC Code Tool Box, 2013 edition **Page in CMS adopted code shown © Lauton Life Safety Consulting, LLC; Mar 2016

2nd-6 STEP FOCUSED INSPECTIONS



ABOVE



BELOW




BELOW THE CEILING




7

Construction Type



8

**Above
Ceiling**



9

Corridors




10

Sprinklers



11

Fire Alarm



12

Electrical





1st

Short training
on what to look
for during the
inspections



2nd

**Some actual
pictures to see
if you can spot
the issues**

INSPECTION TIPS

**Print the next 72 slides
for your own walk-
around inspection
tip-list**



TIPS

STEPS 7-12

FOCUSED INSPECTIONS




SYS		AREA		THINGS TO CHECK		**Code
						Page 4
7	CONSTR TYPE		262-943-4367 LONDON Life Safety Consulting	7.0	<input type="checkbox"/> Confirm Occupancy, # Floors, Constr Date; Confirm Code Requirements	
				7.1	<input type="checkbox"/> Above Ceiling Inspection (Confirm Constr Type)	
				7.2	<input type="checkbox"/> Stacked Constr Types	
				7.3	<input type="checkbox"/> Beam & Column Fire proofing (Structural only)	
				7.4	<input type="checkbox"/> Beam & Column Encapsulation (Structural only)	
				7.5	<input type="checkbox"/> Floor Penetrations	
				7.6	<input type="checkbox"/> Building Separation Walls	
				7.7	<input type="checkbox"/> Non-Combustible Wall Materials	
8	ABOVE CEILING			8.0	<input type="checkbox"/> Top of Wall Sealing	
				8.1	<input type="checkbox"/> Fire Stopping & Joint Sealing	
				8.2	<input type="checkbox"/> Rated Wall Construction	
				8.3	<input type="checkbox"/> Sprinkler Support	
				8.4	<input type="checkbox"/> Open Electrical Boxes; Abandoned Wiring	
				8.5	<input type="checkbox"/> Damper Access	
				8.6	<input type="checkbox"/> Perforated Tiles Intact	
9	CORRIDORS			9.0	<input type="checkbox"/> Confirm Corridor Location Properly Shown on LSP	
				9.1	<input type="checkbox"/> Dead End Corridors	
				9.2	<input type="checkbox"/> Exit in Both Directions	
				9.3	<input type="checkbox"/> Spaces Open to Corridors - Smoke Detectors	
				9.4	<input type="checkbox"/> Doors (see Focused Inspection #3) & Windows	
				9.5	<input type="checkbox"/> Above Ceiling Walls vs Ceiling	
				9.6	<input type="checkbox"/> Walls Smoke Resistant	
				9.7	<input type="checkbox"/> Width & Obstructions	
				9.8	<input type="checkbox"/> Decorations & Storage	
				9.9	<input type="checkbox"/> Suite Size & Travel Distance	
10	SPRINKLER			10.0	<input type="checkbox"/> Sprinkler Locations (max 7.5' to wall, 6'-15' apart, 12"/22" down)	
				10.1	<input type="checkbox"/> Sprinkled When Required	
				10.2	<input type="checkbox"/> Coverage, Shadows, Obstructions	
				10.3	<input type="checkbox"/> Fire Pump	
				10.4	<input type="checkbox"/> Roof Eave; Canopies	
				10.5	<input type="checkbox"/> Mesh Curtains	
				10.6	<input type="checkbox"/> Fire Extinguisher Obstruction	
11	FIRE ALARM			11.0	<input type="checkbox"/> Panel Security, Power Source ID, Breaker Label & Red	
				11.1	<input type="checkbox"/> Panel Smoke Detector	
				11.2	<input type="checkbox"/> Pull Station Obstruction	
				11.3	<input type="checkbox"/> Notification Devices (audible & visual)	
				11.4	<input type="checkbox"/> Tamper Switches	
				11.5	<input type="checkbox"/> Smoke Detector Location	
12	ELECTRICAL			12.0	<input type="checkbox"/> Plug Strips & Extension Cords	
				12.1	<input type="checkbox"/> Breaker Labeling	
				12.2	<input type="checkbox"/> Panel Clearance	
				12.3	<input type="checkbox"/> Hospital Grade Outlets (Green Dot)	
				12.4	<input type="checkbox"/> GFI Outlets	
				12.5	<input type="checkbox"/> Emergency Lighting	
				12.6	<input type="checkbox"/> Generators-Remote Stop, Annunciator	

FOCUSED' INSPECTION CHECKLIST-B (#7-12)

**Code
Page #


SYS AREA

THINGS TO CHECK

7	CONSTR TYPE	 Lauzon Life Safety Consulting 262-945-4567	7.0	<input type="checkbox"/>	Confirm Occupancy, # Floors, Constr Date; Confirm Code Requirements
			7.1	<input type="checkbox"/>	Above Ceiling Inspection (Confirm Constr Type)
			7.2	<input type="checkbox"/>	Stacked Constr Types
			7.3	<input type="checkbox"/>	Beam & Column Fire proofing (Structural only)
			7.4	<input type="checkbox"/>	Beam & Column Encapsulation (Structural only)
			7.5	<input type="checkbox"/>	Floor Penetrations
			7.6	<input type="checkbox"/>	Building Separation Walls
8	ABOVE CEILING		7.7	<input type="checkbox"/>	Non-Combustible Wall Materials
			8.0	<input type="checkbox"/>	Top of Wall Sealing
			8.1	<input type="checkbox"/>	Fire Stopping & Joint Sealing
			8.2	<input type="checkbox"/>	Rated Wall Construction
			8.3	<input type="checkbox"/>	Sprinkler Support
			8.4	<input type="checkbox"/>	Open Electrical Boxes; Abandoned Wiring
			8.5	<input type="checkbox"/>	Damper Access
9	CORRIDORS		8.6	<input type="checkbox"/>	Perforated Tiles Intact
			9.0	<input type="checkbox"/>	Confirm Corridor Location Properly Shown on LSP
			9.1	<input type="checkbox"/>	Dead End Corridors
			9.2	<input type="checkbox"/>	Exit in Both Directions
			9.3	<input type="checkbox"/>	Spaces Open to Corridors - Smoke Detectors
			9.4	<input type="checkbox"/>	Doors (see Focused Inspection #3) & Windows
			9.5	<input type="checkbox"/>	Above Ceiling Walls vs Ceiling
10	SPRINKLER		9.6	<input type="checkbox"/>	Walls Smoke Resistant
			9.7	<input type="checkbox"/>	Width & Obstructions
			9.8	<input type="checkbox"/>	Decorations & Storage
			9.9	<input type="checkbox"/>	Suite Size & Travel Distance
			10.0	<input type="checkbox"/>	Sprinkler Locations (max 7.5' to wall, 6'-15' apart, 12"/22" down)
			10.1	<input type="checkbox"/>	Sprinkled When Required
			10.2	<input type="checkbox"/>	Coverage, Shadows, Obstructions
11	FIRE ALARM		10.3	<input type="checkbox"/>	Fire Pump
			10.4	<input type="checkbox"/>	Roof Eave; Canopies
			10.5	<input type="checkbox"/>	Mesh Curtains
			10.6	<input type="checkbox"/>	Fire Extinguisher Obstruction
			11.0	<input type="checkbox"/>	Panel Security, Power Source ID, Breaker Label & Red
			11.1	<input type="checkbox"/>	Panel Smoke Detector
			11.2	<input type="checkbox"/>	Pull Station Obstruction
12	ELECTRICAL		11.3	<input type="checkbox"/>	Notification Devices (audible & visual)
			11.4	<input type="checkbox"/>	Tamper Switches
			11.5	<input type="checkbox"/>	Smoke Detector Location
			12.0	<input type="checkbox"/>	Plug Strips & Extension Cords
			12.1	<input type="checkbox"/>	Breaker Labeling
			12.2	<input type="checkbox"/>	Panel Clearance
			12.3	<input type="checkbox"/>	Hospital Grade Outlets (Green Dot)
			12.4	<input type="checkbox"/>	GFI Outlets
			12.5	<input type="checkbox"/>	Emergency Lighting
			12.6	<input type="checkbox"/>	Generators-Remote Stop, Annunciator

7

Construction Type



7

Construction Type

Need to Know:

- 1. Occupancy**
- 2. Date of Construction**
- 3. Number of Floors**



7


Construction Type

Is the building structurally able to withstand a fire for the time needed to occupy during a fire?



NFPA 220 Construction Types - LSC - Annex (p.300)

	Type I		Type II			Type III		Type IV	Type V	
	443	332	222	111	000	211	200	2HH	111	000
Exterior Bearing Walls										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0 ¹	2	2	2	1	0 ¹
Supporting one floor only	4	3	2	1	0 ¹	2	2	2	1	0 ¹
Supporting a roof only	4	3	1	1	0 ¹	2	2	2	1	0 ¹
Interior Bearing Walls										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0	1	0	2	1	0
Supporting one floor only	3	2	1	1	0	1	0	1	1	0
Supporting roofs only	3	2	1	1	0	1	0	1	1	0
Columns										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0	1	0	H ²	1	0
Supporting one floor only	3	2	1	1	0		0	H ²	1	0
Supporting roofs only	3	2	1	1	0		0	H ²	1	0
Beams, Girders, Trusses, and Arches										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0	1	0	H ²	1	0
Supporting one floor only	3	2	2	1	0	1	0	H ²	1	0
Supporting roofs only	3	2	1	1	0	1	0	H ²	1	0
Floor Construction	3	2	2 [†]	1	0	1	0	H ²	1	0
Roof Construction	2	1 ^{1/2}	1	1	0	1	0	H ²	1	0
Exterior Nonbearing Walls³	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹



**Defined in
NFPA 220**



Those members that shall be permitted to be of approved combustible material.

HEALTH CARE CONSTRUCTION TYPE

Table 18.1.6.2 Construction Type Limitations

NEW

Construction Type	Stories			
	1	2	3	4 or More
I(443)	X	X	X	X
I(332)	X	X	X	X
II(222)	X	X	X	X
II(111)	X	X	X	NP
II(000)	X	NP	NP	NP
III(211)	X	NP	NP	NP
III(200)	NP	NP	NP	NP
IV(2HH)	X	NP	NP	NP
V(111)	X	NP	NP	NP
V(000)	NP	NP	NP	NP

X: Permitted type of construction.

NP: Not permitted.

Table 19.1.6.2 Construction Type Limitations

EXISTING

Construction Type	Stories			
	1	2	3	4 or More
I(443)	X	X	X	X
I(332)	X	X	X	X
II(222)	X	X	X	X
II(111)	X	X*	X*	NP
II(000)*	X*	X*	NP	NP
III(211)	X*	X*	NP	NP
III(200)	X*	NP	NP	NP
IV(2HH)	X*	X*	NP	NP
V(111)	X*	X*	NP	NP
V(000)	X*	NP	NP	NP

X: Permitted type of construction.

NP: Not permitted.

* Building requires automatic sprinkler protection. (See 19.3.5.1.) 71

7

Construction Type

STACKED
CONSTRUCTION TYPES



**Lowest construction
type governs**

7


STACKED CONSTRUCTION TYPES

2
Story

II (000)
Un-Protected Steel

II (222)
Protected Steel

4
Story



HEALTH CARE CONSTRUCTION TYPE

Table 18.1.6.2 Construction Type Limitations

NEW

Construction Type	Stories			
	1	2	3	4 or More
I(443)	X	X	X	X
I(332)	X	X	X	X
II(222)	X	X	X	X
II(111)	X	X	X	NP
II(000)	X	NP	NP	NP
III(211)	X	NP	NP	NP
III(200)	NP	NP	NP	NP
IV(2HH)	X			
V(111)	X			
V(000)	NP			

X: Permitted type of construction
NP: Not permitted.

**Lowest type governs
WHOLE Bldg is II(000)**

7

Construction Type

FIRE PROOFING

STRUCTURAL MEMBERS



FIREPROOFING

[LSC 18.1.6.2]

All beams & columns must be covered by fire proofing thick enough for the specified rating, typically $\geq 1\text{-}1/2"$

Fire proofing @ end of flange can be $\frac{1}{4}"$ thick


Thick/heavy attachments must be insulated for 6" away from the framing

All items that are directly attached to the steel framing must be insulated the same thickness as the steel

Light attachments, such as top track or hat channel, must be fully covered for 2" away from the framing

All parts of beam clamps must be covered on all sides with $1\text{-}1/2"$ fire proofing

Never remove fire insulation to make room for any plastic pipe or insulation...NO amount of fire proofing will make up for it !



7

Construction Type

FLOOR PENETRATIONS

If not properly fire
stopped, they void
FLOOR RATING



8

Above Ceiling




8

Above Ceiling

This is a “catch-all” inspection to watch for a wide variety of issues that are typically found above the ceiling





8

Above Ceiling

**Top 10
CMS/TJC Cite**

At Rated Walls, look for:

- **Proper Fire Stopping**
- **Top of Wall Joints**
- **Taped Seams & Screws**
- **Fire Dampers at Shafts & 2-hr walls**



8

Above Ceiling

Look for:

- **Sprinkler Pipes**
- **Electrical Boxes**
- **Unused Utilities**



8

NFPA 13-1999,

6-1.1.5

“ Sprinkler
piping or
hangers shall
not be used to
support
nonsystem
components”

SPRINKLER PIPES



8

DQA

SPRINKLER PIPES

Inspectors will
cite if
ANYTHING is
even touching
a pipe or
hanger.



8

ELECTRICAL BOXES

NFPA 70 (1999 ed.)

370-28

**“ Each box
shall have a
cover”**



8

KNOCK-OUTS

**NFPA 70 (1999 ed.)
370-18
“unused
openings shall
be effectively
closed”**



8

UNUSED UTILITIES



8

Above Ceiling



Look for:

- **Perforated Ceilings**
- **Damper Door Access**

8




Perforated Ceilings

(not used much in new construction, but still around in existing)

8

Perforated Ceilings

**Normally, there
is a sound
attenuation
blanket on top of
each tile**





8

Perforated Ceilings


Often the insulation pad is out of place.

Issue: The holes allow smoke & heat to pass through

(Cite: Sprinkled above ceiling or incorrect sprinkler design)

8

Damper Access Door



Make sure the MAIN RUNNER of grid doesn't prevent

- 1. the access door from opening**
- 2. reaching the damper link**

9

Corridors



9

Corridors

**Corridors are an important,
but misunderstood, part of
the Life Safety Code**



9

Corridors



**REFER TO YOUR LIFE
SAFETY PLANS**

RULES FOR CORRIDORS:



1. CORRIDORS CONNECT EXITS & STAIRS

2. EVERY ROOM MUST OPEN INTO A CORRIDOR

3. OPEN SPACES WITH A DOOR ARE A CORRIDOR

9

Corridors

- 1. Must Exit in 2 Directions**
- 2. Dead Ends are Limited**
- 3. Spaces open to corridor must have a smoke detector**



9

Corridors



4. Doors must Resist Smoke, Self Latch & Close with a Nudge

**Top 10
CMS/TJC Cite**

5. Walls must Resist Smoke

6. Smoke-tight ceiling can substitute for walls above it



9

Corridor

WIDTH

New: 8'



Existing: 4'*

9

Corridor

WIDTH

Existing: 4' ?



***Anything Built since 10/1971:**

= 8'

9

Corridor

WIDTH

“ADJUNCT” CORRIDOR 44”



LCS 18/19.2.3.3, Exception 1


**“Not used for housing,
treatment or inpatients”**



9

**Top 10
CMS/TJC Cite**

Corridor Obstructions



Temporary Parking

- 1. 30 Minute without being moved**
- 2. Person must be in attendance at all times**
- 3. On fire alarm, they remove it**

9



Corridor

Obstructions

Temporary Parking

Exceptions:

- Crash Carts
- Isolation Carts

On fire alarm, must be removed

9

Corridor STORAGE

ONE SIMPLE RULE !

NONE* !

LSC 18/19.3.6.1, Exception 1(a)

* or in limited quantities that AHJ
deems non-hazardous



9

Corridor

DECORATIONS

TWO SIMPLE RULES !

1. Must be Non-Combustible* !

LSC 18/19.7.5.4

2. Don't Block Exits or Signs

* or flame-retardant; or in limited quantities so
no fire hazard



9

Corridor

SUITES

**The cool exception to
the corridor door
rule!**




RULES FOR CORRIDORS:



1. CORRIDORS CONNECT EXITS & STAIRS

2. EVERY ROOM MUST OPEN INTO A CORRIDOR

3. OPEN SPACES WITH A DOOR ARE A CORRIDOR



ANY ROOM DOOR THAT DOESN'T OPEN INTO A CORRIDOR is automatically in a suite !

SUITE: "Room within a Room"

9

Corridor

SUITES



- 1. Max Size** (5,000/10,000)
- 2. Max Travel Distance** (50/100)
- 3. Number of Corridor Exits** (1,000/2,500)
- 4. Don't create a Dead-End** (<20')

10

Sprinklers



**Top 10
CMS/TJC Cite**



10

Sprinkler Locations



Upright



Too Far Apart >15'

Too Near Together <6'

Upright



Too Far From Ceiling
>12"/22"

Too Far From Wall
>7.5'


Too Near to Wall
<4"



10

Sprinkler Shadows

Water spray
blocked
by
construction




10

Sprinkler Obstructions

Follow the Charts

HANGING DOWN FROM CEILING




A

B

<u>Distance to Obstruction</u>	<u>Max Distance Below Deflector</u>
<12"	0"
12-18"	2.5"
18-24"	3.5"
24-30"	5.5"
30-36"	7.5"
36-42"	9.5"
42-48"	12"
48-54"	14"
54-60"	16.5"
>60"	18"


FLOOR MOUNTED ITEMS



A

B

<u>Horiz Dist to Obstruction</u>	<u>Min Distance Below Deflector</u>
<6"	3"
6-9"	4"
9-12"	6"
12-15"	8"
15-18"	9.5"
18-24"	12.5"
24-30"	15.5"
>30"	18"



10

Mesh Curtains

(NFPA 13, 5-6.5.2.3) – See Appendix



**Applies only if
sprinkler is one side**

Broad Mesh ($\frac{1}{2}$ " Diagonal)

10

FIRE PUMPS



In 1-hr/2-hr Room

Floor Drain

Floor Pitched

**Protected from
Interruptions**



10

Eaves & Canopies

Same Rules Apply to Both

(NFPA 13, 5-13.8)

1. Sprinkle if combustibles stored or handled

2. Sprinkle if over 4' wide*

*** Unless made of noncombustible or limited combustible construction**



10

Fire Extinguisher

Obstruction

(NFPA 10, 1-6.3)



**Anything that
obstructs view or
access will be cited**

Use ZERO Tolerance

Relocating the Extinguisher
is better than relocating the obstruction



11

Fire Alarm



**Top 10
CMS/TJC Cite**



11

Fire Alarm Panels

MUST Be Located in a continuously occupied area OR have a smoke detector (NFPA 72, 1-5.6)



OR



11

FA Power

Must have 2 independent power supplies

- Primary (ac power)
- Secondary (normally battery)



- Must automatically supply within 30 sec of power loss &
- Must last for 24 hrs & then sound all alarms for 5 min
- (§1-5.2.6)



11

FA Power

Power Source (1-5.2.5.2)

Must be:

- Dedicated circuit
- Mechanically protected
- Marked in red
- Accessible only to authorized personnel
- Marked as “Fire Alarm Circuit Control”



11

Pull Station

Obstruction



**Anything that
obstructs view or
access will be cited**

Use ZERO Tolerance



11

Notification

Per NFPA 72, 4-4

- 1- 2 flashes per second
- Entire lens 80-96" above floor
- Room spacing per Tables in code
 - Corridor spacing:
 - Min 15' from end
 - Max 100' on center
 - Min 55' apart



Per IBC 907.5.2.3

- Install in public and common areas
(any room with 2 or more persons)




11

Tamper Switches

Supervisory - Control Valve (2-9.1)

- Chains are NOT an acceptable substitute
- Trouble signal when handle is moved max 2 revolutions or 1/5 of total travel distance
- Separate & distinct signal when valve position fully restored to normal





11

Smoke Detectors

Spacing

Smooth Ceilings: (2-3.4.5)

- Spaced per Mfgr or 30' on center
- Max .7 x spacing from any wall




11

Smoke Detectors

Spacing

Beam Ceilings: (2-3.4.6)





12

Electrical

**Top 10
CMS/TJC Cite**



12

Power Strips

(Relocatable Power Taps)

**MANY TYPES &
STYLES ON THE
MARKET**



12

Power Strips

(Relocatable Power Taps)

At the current time, the only RPT requirement that is seriously being enforced is that only computers may be plugged into power strips.



12

Power Strips

(Relocatable Power Taps)

Categorical Waiver requirements will be mandatory if/when LSC 2012 is adopted

Recommendations:

- MINIMIZE the use of power strips ... you will be required to monitor their use (including those for computers)
- BUY ONLY UL Listed Power Strips 1363, 1363A or 60601-1 (or other equiv listed)
- Standardize on a single brand & model for each type power strip (so they are readily identifiable)



12

Breaker Labels

Accurate – Complete - Clear



LOOK FOR:

1. Spares that are on
2. Blank Lines with Breaker in space
3. Handwritten notes; Multiple Directories

Panel Clearance

Min 36 inches



12

Hospital Grade

Look for the “Green” Dots
on plugs

(especially on patient-use
devices)



**Must ONLY BE PLUGGED
into H-G Outlets**



12

Ground Fault



**Within 4' of
any Water
Device**



Also:

- **Garages**
- **Outdoors**
- **Construction**

12

Generator

REMOTE STOP BUTTON

- Located outside generator space
- “Tamper-resistant”



BATTERY

- Maintenance Free
Prohibited if Level 1
generator

12

Generator

ANNUNCIATOR PANEL [110:3-4.1]

- Battery powered
- At 24-hour manned location
- Signals if it's operating, low fuel, pressure or temp abnormal & other conditions





2nd PART

Some actual
pictures to see if
you can spot the
issues

Multiple choice

- There may be more than one correct answer
- You only have 10 seconds per photo



Use Team Work



If there are multiple people in the room:

- Have one person look at #1
- Another look at #2
- Third look at #3

Each give



or




Be Observant



Can you spot the man in this picture?


7

Construction Type



What is the violation?

⑩






1. Cables passing through beam
2. Hanger not fire proofed
3. Beam camps not fire proofed



What is the violation?


⑩



1. No fire damper at floor
2. Supports not fire proofed
3. Unknown, room could be shaft ✓

What is the violation?

⑩



1. Wall is made of wood
2. Cannot have extension cords
3. Ladder not properly stored



What is the violation?

⑩

1

2

3

1. Steel beam is not fire proofed
2. Tress beam is not fire proofed
3. Unknown, what is constr type?

What is the violation?

⑩

3


1

2

1. Box cover only has 2 screws
2. Fire proofing missing on beam ✓
3. Fire proofing is on conduit

What is the violation?

⑩



1. Fire proofing is discolored
2. Fire proofing appears thin
3. Concrete is not fire proofing



What is the violation?

⑩

3

2

1

1. Using extension cords
2. Sleeve is grouted, not fire stopped
3. Fiberduct is not fire stopped ✓

What is the violation?

⑩

1

2

3

1. Fire proofing missing on beam ✓
2. Top of wall is not fire stopped
3. Fire stopping does not go around pipe ✓



8

Above Ceiling



What is the violation at this rated wall?

⑩




1. Facility can't confirm the blue mtl is a fire stop
2. Top of wall is not fire stopped
3. Drywall joint compound is not a fire stop




What is the violation at this rated wall?

⑩



What is the violation at this rated wall?

⑩



1. Bottom of cable is not fire stopped ✓
2. Beam is damaged
3. Cable is not bundled & supported ✓

What is the violation at this rated wall?

⑩

2


1. Wirenuts are not in a box
2. **Top of wall is not fire stopped ✓**
3. Screw is not covered with mud

1

3

What is the violation at this rated wall?

⑩



1. Fire proofing is missing on beam ✓

2. Fire stop is missing a cables

3. Cables are not bundled & supported ✓

What is the violation at this rated wall?

⑩



1. Screws are not mudded throughout ✓
2. Fire stop around patch is not UL design
3. Top of wall is not fire stopped

What is the violation?

⑩

1

2

3

?

1. Beam is not fire proofed
2. Insulation is not tight to perforated tile
3. Unknown, not enough info ✓

9

Corridors



⑩

1

What is the violation?

3

2

1. Alcove is not smoke detected ✓
2. A hazardous amount of combustibles is stored
3. A paper sign is used

What is the violation?

⑩

1


2

1. No smoke detector in space ✓
2. No smoke detectors in corridor
3. Copy mch obstructs adjunct corridor to rm ✓

3

What is the violation?

⑩



1. Door has a grill
2. Cart obstructs door from closing ✓
3. Soiled hamper stored in non-haz room

⑩

1

What is the violation?

1. **No smoke detector in space** ✓
2. Chair not pushed in when not in use
3. Chair obstructs adjunct corridor to rm

2

3

What is the violation?

⑩

1

2

3

1. No smoke detectors in corridor
2. Overbed tray stand parked in corridor
3. BP cuff parked in corridor



What is the violation?


⑩

1. Kick plate is screwed to door
2. Stool prevents door from closing ✓
3. Outlet is not GFI protected

1

2

3



What is the violation?

⑩


1

3

2

1. Clearance for electrical panel is blocked
2. Recycle container is too large ✓
3. Copy machine obstructs corridor

⑩



What is the violation?

1. Door is not kept closed
2. Paper decorations on door ✓
3. Handrails not graspable

What is the violation?

⑩

1


2

3

1. Roll-down door has manual latch ✓
2. Tray on counter prevents door from closing
3. Trash can stored in corridor

What is the violation?

⑩



1. Door encroaches on egress width
2. Combustibles stored in corridor
3. Man is holding door open

10


Sprinklers



What is the violation?

⑩


1. Flex is laying on the sprinkler pipe ✓
2. Flex is laying on the ceiling
3. The conduit is not anchored



⑩

What is the violation?

1. Wrong type extinguisher
2. Cart blocks access to extinguisher ✓
3. Sign is not directly over the unit



What is the violation?



⑩

1. Light fixture not fire stopped
2. No sprinkler (has wood framing) ✓
3. Wood column not fire proofed



What is the violation?

⑩



1. Cap is not tight to ceiling ✓
2. Sprinkler not cover shower area
3. Sliding door

What is the violation?

⑩



1. Head recessed too far into escutcheon
2. Sprinkler has debris on deflector
3. Sprinkler has dust on deflector

**What is
the
violation?**

⑩


1. Mesh curtain is too low
2. Sprinkler are too far apart
3. Paper sign blocks sprinkler flow ✓



**What is
the
violation?**

⑩

1. Sidewall sprinkler must be at top
2. Missing sprinkler in bay
3. Supply grill too close to beam



What is the violation?

⑩

1

2




3

1. Cable hung on sprinkler hanger
2. Cable supported by sprinkler
3. Duct insulation touching sprinkler



**What is
the
violation?**

⑩



1. Sprinkler too close to wall
2. Sprinkler blocked by soffit
3. Ceiling tile not seated in grid



11

Fire Alarm



What is the violation?

⑩

2

3




1

1. Sprinklers too close together ✓
2. Gap at ceiling tile; not in grid
3. Detector is 3' from fan; $< 5'$ ✓

**What is
the
violation?**

⑩


1. Should be return air grill
2. **Detector too close to grill ✓**
3. Sprinkler too close to wall



**What is
the
violation?**


1. Plastic report holder not rigid
2. Gauge in wrong position
3. Valve is locked, but no tamper switch

⑩



What is the violation?


⑩



1. No smoke detector near FA panel ✓
2. FA wires not in conduit
3. Key left in panel door ✓

What is the violation?

⑩



⑩

What is
the
violation?

1


2

3

1. No smoke detector in open space ✓
2. Sprinkler too close to light fixture
3. Chairs too close to wall heater

What is the violation?

⑩



1. Smoke detector not in every beam pocket
2. Smoke detector not located within 3' of peak ✓
3. Chandelier is too low

What is the violation?




⑩



1. Exit sign not centered over door
2. Fire pull blocked by table
3. Egress blocked by table & TV

What is the violation?

⑩



1. Should be a supply grill
2. **Detector is too close to grill** ✓
3. Light is too close to wall

12

Electrical



What is the violation?

⑩

1

2

3

1. Trash throughout room
2. Open electrical box
3. Evidence of water leakage



What is the violation?

1. Generator too close to building
2. Remote shut-off inside gen cabinet
3. Electrical box not lockable

⑩

1

2


3



What is the violation?

1. Power strip used for non-computer ✓
2. Hospital Grade plug, not outlet
3. Covers on containers




⑩



What is
the
violation?

⑩


1. ? Denotes inaccurate directory ✓
2. Spare & name of load inconsistent
3. Changes written, not typed



PANELBOARD / PANNEAU / TABLERO
SOURCE
2 1302, 1308, 1311, 1306, 1309 Rec(5)
3 1324, 1329, 1326 Rec(4)
4 1306, 1312, 1309, 1302 Rec(4)
5 1323 Bath GFI (1) ?
6 1304, 1313, 1307 Bath GFI (4)
7 1329 GFI (1)
8 1316, 1318 Reg Rec(#)
9 1329 GFI (1)
10 1316 GFI (1)
11 1331, 1339, 1332, 1338 Rec(4)
12 1321, 1322 Hall/Vest Rec(4)
13 1331, 1338, 1332, 1339 Rec(4)
14 1321 Vest Rec(3)
15 1336, 1333, 1337 GFI Rec(3)
16 1322 Corridor nurse sta. Rec(4)
17 1337, 1334, 1336 GFI & Rec(3)
18 1232 CuH-1&2
19 1341, 1334 Hall Rec(2)
20 Revised art glass Rec(4)
21 Outside GFI (2)
22 Spare 1291 Treadmill
23 1303 Unit Cab Heater (CUH-5)
24 Spare 1291 Treadmill
25 spare Double Duplex Rm 1208
26 Spare 1339 Recept
27 Spare Double Duplex Rm 1208
SQUARE 2-200

What is the violation?

⑩



1. Items stored in clearance space ✓
2. Combustible items not in Flam Liq Cab
3. Egress width less than 4'

**What is
the
violation?**




⑩

1. Open elec panel ✓
2. Pipe blocks panel clearance
3. Extension cord used

09/11/2010

What is the violation?

⑩




1. Power strip used for equip ✓
2. Hospital-grade plug not in HG outlet
3. Cords tangled & not secured

What is the violation?

⑩


1. Step stool in panel clearance space ✓
2. Chemical drum not in flam liq cab
3. PVC pipe not supported



**What is
the
violation?**


1. Computer sitting in corridor
2. Chair stored in a clean hold
3. Cord run through a door opening ✓

⑩



What is the violation?

⑩



1. Unsure which breakers are F Alarm
2. Load of 2 breakers not labeled
3. Unsure what "exit" means



**What is
the
violation?**


1. Switch too close to panel
2. Items place in clearance space ✓
3. Chemicals stored in electrical room

⑩

1

2

3





**Some actual
pictures to see
if you can spot
the issues**



You ARE the Inspector



WHEA
Lunch & Learn

PART 2

Bill Lauzon
Heather Lauzon Werner

Thurs Mar 10, 2016
11:30-1:00

Lauzon Life Safety Consulting, LLC