



# **IMPORTANT !**

**Prior** to the webinar, go to

**[www.Lauzon-lsc.com](http://www.Lauzon-lsc.com)**

**& download**

**& print**

**A free copy of the**

**“Inspection Report Tool Box”**

**These forms will be used during this webinar.**

**If you don't have the printed checklist, you'll**

**have to view the fine print on the screen**



**TOOLS for REVIEW of**

# Inspection Documentation


Lauzon  
Life Safety  
Consulting



Heather Lauzon  
Werner



Bill Lauzon





**TOOLS for REVIEW of**

# Inspection Documentation

1. REALITIES of Document Review
2. Creating a Checklist
3. The Report Tool Box
4. Evaluate The Big 5 Doc Forms



# Inspection Realities

**#1** Surveyors Review Very **Few**  
Inspection Reports

# There are Many Codes

NFPA 10, *Standard for Portable Fire Extinguishers*, 2010 edition.  
 NFPA 11, *Standard for Low-, Medium-, and High-Expansion Foam*, 2010 edition.  
 NFPA 12, *Standard on Carbon Dioxide Extinguishing Systems*, 2011 edition.  
 NFPA 12A, *Standard on Halon 1301 Fire Extinguishing Systems*, 2009 edition.  
 NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2010 edition.  
 NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, 2010 edition.  
 NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, 2010 edition.  
 NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*, 2010 edition.  
 NFPA 15, *Standard for Water Spray Fixed Systems for Aircraft Hangars*, 2012 edition.  
 NFPA 16, *Standard for the Installation of Foam-Water Sprinkler and Foam-Water Spray Systems*, 2011 edition.  
 NFPA 17, *Standard for Dry Chemical Extinguishing Systems*, 2009 edition.  
 NFPA 17A, *Standard for Wet Chemical Extinguishing Systems*, 2009 edition.  
 NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2011 edition.  
 NFPA 30, *Flammable and Combustible Liquids Code*, 2012 edition.  
 NFPA 30B, *Code for the Manufacture and Storage of Aerosol Products*, 2011 edition.  
 NFPA 31, *Standard for the Installation of Oil-Burning Equipment*, 2011 edition.  
 NFPA 40, *Standard for the Storage and Handling of Cellulose*

## LSC, Chapter 2

NFPA 111, *Standard on Stored Electrical Energy Emergency and Standby Power Systems*, 2010 edition.  
 NFPA 160, *Standard for the Use of Flame Effects Before an Audience*, 2011 edition.  
 NFPA 170, *Standard for Fire Safety and Emergency Symbols*, 2009 edition.  
 NFPA 204, *Standard for Smoke and Heat Venting*, 2012 edition.  
 NFPA 211, *Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances*, 2010 edition.  
 NFPA 220, *Standard on Types of Building Construction*, 2012 edition.  
 NFPA 221, *Standard for High Challenge Fire Walls, Fire Walls, and Fire Barrier Walls*, 2012 edition.  
 NFPA 241, *Standard for Safe Guarding Construction, Alteration, and Renovation*, 2012 edition.  
 NFPA 253, *Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source*, 2011 edition.  
 NFPA 257, *Standard on Fire Test for Window and Glass Block Assemblies*, 2007 edition.  
 NFPA 259, *Standard Test Method for Potential Heat of Building Materials*, 2008 edition.  
 NFPA 260, *Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture*, 2009 edition.  
 NFPA 261, *Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes*, 2009 edition.  
 NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile or Expanded Vinyl Wall Coverings*

(MOST have Inspection Requirements)

# There are Many Codes



(MOST have Inspection Requirements)

# Here's How Many Inspections Are Required!

# Required Reports

9

(They are ALL required by NFPA Codes)

## EMERGENCY

C-Fire Safety Plan  
Q-Fire Drills  
A-Surgical Fire Drill  
A-Hyperbaric Fire Drills  
C=Report of Fires

5

## POLICIES

C-Sprinkler Outage  
C-Fire Alarm Outage  
C-Fire Watch  
C-Space Heater  
C-Smoking  
A-Surgical Procedures

6

## JOINT COMMISSION

C-Interim Life Safety Measures  
C-Construction Program  
C-Fire Mnagement Plan  
C-Life Safety Management Plan  
C-Statement of Conditions  
C-Utility Management Plan  
C-Haz Materials Management Plan  
C-Information Collection  
C-Safety & Security Management Plan

9

(They are ALL required by NFPA Codes)

## BUILDING

A-Fire Doors  
S-Fire Dept Inspection  
D-Flame Spread Doc  
M-Elevator Recall  
A-Constr Means of Egress  
3-Elevator Use Certificate  
3-Pressure Vessel Certificate

7

## MECHANICAL

4-Dampers  
6-Dampers  
S-Smoke Control  
A-Smoke Control  
Q-Lab Hoods  
A-Lab Hoods  
W-Eye Wash  
A-Bulk Tank

8

## FIRE ALARM

W-Alarm Transmission  
M-Fire Alarm  
Q-Fire Alarm  
S-Fire Alarm  
A-Fire Alarm  
2-Smoke Detector  
10-Carbon Monoxide

7



(They are ALL required by NFPA Codes)

## ELECTRICAL

W-Generator  
M-Generator  
A-Generator  
A-Load Bank  
3-Load Bank  
A-Diesel Fuel  
A-Natural Gas  
A-Transfer Switch  
S-Emergency Breakers  
A-Emergency Breakers  
2-Emergency Breakers

## ELECTRICAL

M-Exit Signs  
M-Battery Lights  
A-Battery Lights  
M-Battery Bank Sys  
Q-Battery Bank Sys  
A-Battery Bank Sys  
M-Isolated Power  
A-Isolated Power  
S-Wet Locations  
A-Outlets  
A-Plug Strips  
A-Lab Cords

# 23

(They are ALL required by NFPA Codes)

## SUPPRESSION

M-Sprinkler  
Q-Sprinkler  
S-Sprinkler  
A-Sprinkler  
3-Sprinkler  
5-Sprinkler  
W-Standpipe  
Q-Standpipe  
A-Standpipe  
3-Standpipe  
5-Standpipe

## SUPPRESSION

W-Fire Pump  
M-Fire Pump  
A-Fire Pump  
A-Hydrants  
5-Hydrants  
D-Water Storage Tank  
W-Water Storage Tank  
M-Water Storage Tank  
Q-Water Storage Tank  
S-Water Storage Tank  
A-Water Storage Tank  
3-Water Storage Tank  
5-Water Storage Tank

## SUPPRESSION

M-Fire Extinguisher  
A-Fire Extinguisher  
H-Fire Extinguisher  
S-Hood Cleaning  
S-Hood Extinguisher  
A-Kitchen Equipment  
S-Clean Agent  
A-Clean Agent  
5-Clean Agent  
M-Dry Chemical Agent  
S-Dry Chemical Agent  
A-Dry Chemical Agent  
H-Dry Chemical Agent

37

# How Many? (All Total)

Surveyors COULD ask to see  
**over 100!**

# How Many Inspection Reports do Inspectors Usually Ask to See?

About **10!**

That's less than!

**10%**

**of What they COULD Ask For!**

# Inspection Realities

**#2**

Surveyors Review 1% of  
Inspection Requirements



# How do You Figure That ?

**#2**

Surveyors Review 1% of  
Inspection Requirements

# Inspection Realities

## FACTORS:

A. There is a  
**LIMITED TIME**  
Available for a  
Surveyor to Review  
Documents

B. Surveyors Do  
**NOT** use a Checklist  
of Required  
Inspection Points

C. Document  
Review is **BORING**

### FIRE ALARM AND EMERGENCY COMMUNICATION SYSTEM INSPECTION AND TESTING FORM

To be completed by the system inspector or tester at the time of the inspection or test.  
It shall be permitted to modify this form as needed to provide a more complete and/or clear record.  
Insert N/A in all unused lines.  
Attach additional sheets, data, or calculations as necessary to provide a complete record.

Date of this inspection or test: 12/22/2010 Time of inspection or test: 8:00 AM

#### 1. PROPERTY INFORMATION

Name of property: Main Street Towers  
Address: 12345 Main Street, Pleasantville, NY 01111  
Description of property: 40-story high-rise building with an adjacent 1-story parking structure  
Occupancy type: B1  
Name of property representative: Mary Morris, Property Manager, Mary's Management Company  
Address: 12345 Main Street, Pleasantville, NY 01111  
Phone: 222/222-2222 Fax: 333/333-3333 E-mail: mm@mmc.com  
Authority having jurisdiction over this property: Inspector Jack Jones, Pleasantville Fire Department  
Phone: 444/444-4444 Fax: 555/555-5555 E-mail: jackjones@pfd.org

#### 2. INSTALLATION, SERVICE, AND TESTING CONTRACTOR INFORMATION

Service and/or testing organization for this equipment: Fred's Fine Fire Alarm Systems  
Address: 789 Broad Street, Pleasantville, NY 01113  
Phone: 888/888-8888 Fax: 999/999-9999 E-mail: fredfriendly@fffas.com  
Service technician or tester: Fred Friendly  
Qualifications of technician or tester: NICE1 IV No 888888  
A contract for test and inspection in accordance with NFPA standards is in effect as of: 6/11/2010  
The contract expires: 6/11/2011 Contract number: 45678 Frequency of tests and inspections: Quarterly  
Monitoring organization for this equipment: Manny's Monitoring  
Address: 899 First Street, Pleasantville, NY 01114  
Phone: 777/777-7777 Fax: 777/777-7777 E-mail: manny@mannys.com  
Entity to which alarms are retransmitted: Pleasantville Fire Department Phone: 444/444-4444

#### 3. TYPE OF SYSTEM OR SERVICE

- ☐ Fire alarm system (nonvoice)  
☐ Fire alarm with in-building fire emergency voice alarm communication system (EVACS)  
☐ Mass notification system (MNS)  
☒ Combination system, with the following components:  
☒ Fire alarm ☒ EVACS ☒ MNS ☒ Two-way, in-building, emergency communication system  
☐ Other (specify): N/A

## THIS MEANS:

1. Surveyors Only  
Visually SCAN the  
Document

2. Surveyors Look for  
the 1-4 Things they  
are Familiar With

3. Typically they  
Scan Less Than  
10% of the  
Document Items

#### 4. SYSTEM POWER (continued)

##### 4.3.4 Batteries

Location: Inside each panel Type: Gel cell Nominal voltage: 24 VDC Amp/hour rating: 14

Calculated capacity of batteries to drive the system:

In standby mode (hours): \_\_\_\_\_ In alarm mode (minutes): See attached calculations

☒ Batteries are marked with date of manufacture.

#### 5. ANNUNCIATORS

☐ This system does not have annunciators.

##### 5.1 Location and Description of Annunciators

Annunciator 1: Fire control room

Annunciator 2: Front lobby at east entrance doors

Annunciator 3: Engineering office on P1 level

#### 6. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring organization	Contact: <u>Manny Monitor</u>	Time: <u>8:10 AM</u>
Building management	Contact: <u>Mary Morris</u>	Time: <u>8:00 AM</u>
Building occupants	Contact: <u>By PA Announcement</u>	Time: <u>8:15 AM</u>
Authority having jurisdiction	Contact: <u>Pleasantville Fire Dept.</u>	Time: <u>8:15 AM</u>
Other, if required	Contact: <u>N/A</u>	Time: <u>N/A</u>

#### 7. TESTING RESULTS

##### 7.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Comments
Control unit	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Lamps/LEDs/LCDs	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Fuses	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Trouble signals	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Disconnect switches	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Did not test
Ground-fault monitoring	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Supervision	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Local annunciator	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Remote annunciators	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Power extender panels	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Isolation modules	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

## RESULTS:

### 7. TESTING RESULTS *(continued)*

#### 7.11 Auxiliary Functions

Description	Visual Inspection	Functional Test	Comments
Door-releasing devices	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Fan shutdown	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Smoke management/ Smoke control	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Smoke damper operation	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Smoke shutter release	<input type="checkbox"/>	<input type="checkbox"/>	N/A
Door unlocking	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Elevator recall	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Elevator shunt trip	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
MNS override of FA signals	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

#### 7.12 Alarm Initiating Device

☒ Device test results sheet attached listing all devices tested and the results of the testing

#### 7.13 Supervisory Alarm Initiating Device

☒ Device test results sheet attached listing all devices tested and the results of the testing

#### 7.14 Alarm Notification Appliances

☒ Appliance test results sheet attached listing all appliances tested and the results of the testing

#### 7.15 Supervisory Station Monitoring

Description	Yes	No	Time	Comments
Alarm signal	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4:30 PM	
Alarm restoration	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4:40 PM	
Trouble signal	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4:30 PM	
Trouble restoration	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4:40 PM	
Supervisory signal	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4:30 PM	
Supervisory restoration	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4:40 PM	

4. Do the Math:

$$\begin{array}{l} 10\% \text{ of Docs } \times \\ 10\% \text{ of Doc Items} \\ = 1\% \end{array}$$

# Inspection Realities

**#3**

A “Clean” Inspection Does  
NOT Mean Compliance

### This Time: No Inspection Deficiencies 😊

- Maybe You Are Perfect
- Maybe Surveyor is Not Perfect

### Remember:

- Only 1% of Things are Checked
- Different Surveyors Key on Different Things



This Time: No Inspection Deficiencies! 😊

- Maybe You Are Perfect
- Maybe Surveyor is Not Perfect

Remember:

- Only 1% of Things are Checked
- Different Surveyors Key on Different Things

Next Time: Inspection Deficiencies? ☹️

**It all  
boils down to . .  
.**

## Do You Feel Lucky?



# Inspection Realities

**#4**

**Vendors Don't  
Always do it Right**

### 4. Vendors Don't Always do it Right

- Most of their Clients are NOT Health Care
- Most of their Clients are NOT Surveyed, so NO ONE is reviewing their work
- Most do not Know What Edition of the Code you Need to Follow

### 4. Vendors Don't Always do it Right

- Most Vendor's Forms do NOT Follow Detailed Code Requirements
- Vendors Know the Technicalities of the System, but not all the Details of Code Inspections
- Many Surveyors Blindly Accept Vendor Forms



### 4. Vendors Don't Always do it Right

- The Bigger the Vendor the More Resistance to Change
- The Customer is Always Right
- You Pay the Vendor to Protect You; Hire Another if They Don't Produce

# Inspection Realities

**#5**

**Beware of Advice**

## 5. Beware of Advice

- CMS is the BOSS on federal compliance



1. State surveyors can't speak for CMS

(they only give personal opinions)

2. State surveyors don't get CMS interpretations

2. CMS is usually poor/late at clarifications

Refer to S&C Letters, Fed Register

- Must follow the MOST Restrictive Rules

### 5. Beware of Advice



TJC processes are sometimes:

1. Incomplete (Don't always apply the Code)
2. Sometimes Contrary to CMS or the Code

## COMPLIANCE+OPERATIONS

### Tracking and documenting physical environment compliance

How to prepare for accreditation surveys well ahead of time

November 7, 2018 | Joshua Brackett, PE



Image by Shutterstock

A facility professional new to a hospital has just been told by the CEO that the facility has been in its “Joint Commission window” of 18 months from the previous survey for the past year.

Although familiar with The Joint Commission survey process, the facility manager has no

## ASHE HFM Magazine

Nov-Dec 2018

Be especially  
cautious of  
Following  
**Joint Commission**  
Rules

## 5. Beware of Advice

- Example: Inspection

These date time frames can be found at the  
Commission's Comprehensive Accreditation

- Every six years = 72 months from the last event, +/- 45 days
- Every five years = 60 months from the last event, +/- 45 days
- Every 36 months/three years = 36 months from the last event
- Annually/every 12 months/once per year/every year = one year  
+/- 30 days.
- Every six months/semiannually = six months from the last event, +/- 15 days
- Quarterly = three months from last event, +/- 10 days.
- Monthly = 12 times per year, once per calendar month.
- Every week = once per calendar week.

**These Accreditation Time Frames are not**  
**on any codes** (Fire Alarm tolerances come the closest)  
**DO NOT Follow for ANY inspection.** (Follow the code!)



TOOLS for REVIEW of

# Inspection Documentation

1. REALITIES of Document Review
2. **Creating an Inspection Checklist**
3. The Report Tool Box
4. Evaluate The Big 5 Doc Forms



## Checklist Method

Evaluate your FORMS against  
what the codes require








## How do I Extract the Details of Required Inspections & Tests?

### **4 STEPS:**

1. Determine WHAT CODE is applicable
2. Get a COPY of the code
  - Printed – Easier to view, More time consuming
  - Electronic – May be on-line; Not always handy
3. SEARCH for key “frequency” words
  - Printed – May Miss some inspections
  - Electronic – Usually faster & more precise
4. Make Up a Inspection Doc Checklist

## Step 1: Determine WHAT CODE is applicable

- Must Have Access to Many Codes
- Must Know Where Inspection Requirements are Located








Also see CMS S&C Letters (web browse: CMS)


Let's use an example

## Checklist Creation


### Step 1: Determine WHAT CODE is applicable



**EXAMPLE: Door Inspections**

**EXAMPLE: Door Inspections****Checklist Creation****Step 2: Get a COPY of the code**

- Most facilities have the 2012 LSC
- Recommend getting pdf version from NFPA (handbook is better)



- NFPA 80 (small std)
- Recommend getting pdf version from NFPA (handbook is better)

Look in Table of Contents or Index for  
“Inspection” & “Test”

# Checklist Creation


<b>Chapter 7</b>	<b>Means of Egress</b>	<b>101– 45</b>
7.1	General	101– 45
7.2	Means of Egress Components	101– 49
7.3	Capacity of Means of Egress	101– 73
7.4	Number of Means of Egress	101– 76
7.5	Arrangement of Means of Egress	101– 76
7.6	Measurement of Travel Distance to Exits	101– 78
7.7	Discharge from Exits	101– 78
7.8	Illumination of Means of Egress	101– 79
7.9	Emergency Lighting	101– 80
7.10	Marking of Means of Egress	101– 81
7.11	Special Provisions for Occupancies with High Hazard Contents	101– 83
7.12	Mechanical Equipment Rooms, Boiler Rooms, and Furnace Rooms	101– 83
7.13	Normally Unoccupied Building Service Equipment Support Areas	101– 83
7.14	Elevators for Occupant-Controlled Evacuation Prior to Phase I Emergency Recall Operations	101– 84
<b>Chapter 8</b>	<b>Features of Fire Protection</b>	<b>101– 86</b>
8.1	General	101– 86
8.2	Construction and Compartmentation	101– 86
8.3	Fire Barriers	101– 87
8.4	Smoke Partitions	101– 92
8.5	Smoke Barriers	101– 93
8.6	Vertical Openings	101– 95
8.7	Special Hazard Protection	101– 97

## Door Inspections in LSC

Start at Chapter 7

## Research Fire Door Inspections

Continue in Chapter 8






## EXAMPLE: Door Inspections

## Checklist Creation

<b>Chapter 18</b>	<b>New Health Care Occupancies .....</b>	<b>101–183</b>
18.1	General Requirements .....	101–183
18.2	Means of Egress Requirements .....	101–186
18.3	Protection .....	101–191
18.4	Special Provisions .....	101–196
18.5	Building Services .....	101–198
18.6	Reserved .....	101–199
18.7	Operating Features .....	101–199
<b>Chapter 19</b>	<b>Existing Health Care Occupancies ...</b>	<b>101–201</b>
19.1	General Requirements .....	101–201
19.2	Means of Egress Requirements .....	101–201
19.3	Protection .....	101–201
19.4	Special Provisions .....	101–214
19.5	Building Services .....	101–214
19.6	Reserved .....	101–215
19.7	Operating Features .....	101–215


## Research Fire Door Inspections

*Finally in Chapter 18/19*




## Step 3: SEARCH for key words

Do a methodical search of each NFPA referenced code looking for keywords of :




- Day or Daily
- Week
- Month
- Quarter
- Annual
- Year




## Step 3: SEARCH for key words

Do a methodical search of each NFPA referenced code looking for keywords of inspection FREQUENCY :



- Day or Daily
- Week
- Month
- Quarter
- Annual
- Year





**Can scan visually ... BUT  
It's easy to miss inspections**



**EXAMPLE: Door Inspections****Checklist Creation****Step 3: SEARCH for key words**

I prefer to use seachable pdf versions of the codes

**Use 'Control F' ("Find")**

Search for: "inspect" & "test"

Search for frequency: "day", "daily",  
"week", "month", "quarter", "semi",  
"annual", "year"

## EXAMPLE: Door Inspections

## Checklist Creation

### Chapter 7 Results

“Where Required”

#### 7.2.1.15 Inspection of Door Openings.

7.2.1.15.1\* Where required by Chapters 11 through 43, the following ~~door assemblies~~ shall be inspected and tested not less than **annually** in accordance with 7.2.1.15.2 through 7.2.1.15.8.

- (1) Door leaves equipped with panic hardware or fire exit hardware in accordance with 7.2.1.7
- (2) Door assemblies in exit enclosures
- (3) Electrically controlled egress doors
- (4) Door assemblies with special locking arrangements subject to 7.2.1.6

7.2.1.15.2 Fire-rated door assemblies shall be inspected and tested in accordance with NFPA 80, *Standard for Fire Doors and Other Opening Protectives*. Smoke door assemblies shall be inspected and tested in accordance with NFPA 105, *Standard for Smoke Door Assemblies and Other Opening Protectives*.

7.2.1.15.3 The inspection and testing interval for fire-rated and nonrated door assemblies shall be permitted to exceed 12 months under a written performance-based program in accordance with 5.2.2 of NFPA 80, *Standard for Fire Doors and Other Opening Protectives*.

7.2.1.15.4 A written record of the inspections and testing shall be signed and kept for inspection by the authority having jurisdiction.

7.2.1.15.5 Functional testing of door assemblies shall be performed by individuals who can demonstrate knowledge and understanding of the operating components of the type of door being subjected to testing.


7.2.1.15.6 Door assemblies shall be visually inspected from both sides of the opening to assess the overall condition of the assembly.

#### Applies Only in:

- Chapters 12/13-Assembly
- Chapters 15/15-Education
- Chapters 16/17-Day Care
- Chapters 32/33-Res B&C

#### CMS S&C Letter 17-38

- Confirms Applies ONLY in these Occupancies  
IF 2-hr separated from Healthcare



## EXAMPLE: Door Inspections

## Checklist Creation

### Chapter 8 Results

#### 8.2.2 General.

8.2.2.1 Where required by other chapters of this *Code*, every building shall be divided into compartments to limit the spread of fire and restrict the movement of smoke.

8.2.2.2 Fire compartments shall be formed with fire barriers that comply with Section 8.3.

8.2.2.3 Fire compartments shall be formed by fire barriers complying with 8.3.1.2.

8.2.2.4 Where door assemblies are required elsewhere in this *Code* to be smoke leakage-rated in accordance with 8.2.2.4, door assemblies shall comply with all of the following:

- (1) They shall be tested in accordance with ANSI/UL 1784, *Standard for Air Leakage Tests for Door Assemblies*.
- (2) The maximum air leakage rate of the door assembly shall be  $3.0 \text{ ft}^3/\text{min}/\text{ft}^2$  ( $0.9 \text{ m}^3/\text{min}/\text{m}^2$ ) of door opening at 0.10 in. water column ( $25 \text{ N}/\text{m}^2$ ) for both the ambient and elevated temperature tests.
- (3) Door assemblies shall be installed in accordance with NFPA 105, *Standard for Smoke Door Assemblies and Other Opening Protectives*.
- (4) Door assemblies shall be inspected in accordance with 7.2.1.15.

“Smoke Leakage”


“Where Required”

Applies Only if Smoke Leakage-Rating is required:

Smoke Leakage Rating is Required Only in:

- Areas of Refuge in Accessible Means of Egress
- Accessible Occupant Evacuation Shafts
- Not Smoke Barrier & Corridor Doors

A.8.4.3.4 Gasketing of doors should not be necessary, as the clearances in NFPA 80, *Standard for Fire Doors and Other Opening Protectives*, effectively achieve resistance to the passage of smoke if the door is relatively tight-fitting.






**EXAMPLE: Door Inspections****Checklist Creation****Chapter 18/19 Results**

<b>Chapter 18</b>	<b>New Health Care Occupancies</b>	<b>.....</b>	<b>101-183</b>
18.1	General Requirements	.....	101-183
18.2	Means of Egress Requirements	.....	101-186
18.3	Protection	.....	101-191
18.4	Special Provisions	.....	101-196
18.5	Building Services	.....	101-198
18.6	Reserved	.....	101-199
18.7	Operating Features	.....	101-199
<b>Chapter 19</b>	<b>Existing Health Care Occupancies</b>	<b>...</b>	<b>101-201</b>
19.1	General Requirements	.....	101-201
19.2	Means of Egress Requirements	.....	101-204
19.3	Protection	.....	101-208
19.4	Special Provisions	.....	101-214
19.5	Building Services	.....	101-214
19.6	Reserved	.....	101-215
19.7	Operating Features	.....	101-215

**NO Door Inspections**

**NO added Door  
Inspections in  
Healthcare**



**EXAMPLE: Door Inspections****Checklist Creation**


## CMS S&C Letter 17-38

### CMS Expectations on Door Inspections

In health care occupancies, annual inspection and testing in accordance with the 2010 NFPA 80 is required for all fire door assemblies. Non-rated doors, including corridor doors to patient care rooms and smoke barrier doors, are not subject to the annual inspection and testing requirements of either NFPA 80 or NFPA 105. But, non-rated doors should be routinely inspected as part of the facility maintenance program as all required life safety features and systems must be maintained in proper working order. LSC deficiencies associated with the annual inspection and testing of fire doors should be cited under K211 – *Means of Egress - General*.

### **KEY POINTS:**

- Annual Fire Door inspection per NFPA 80-2010
- Non-Rated Doors do NOT need to be annually inspected; but must be maintained
- Cite under K211 (later revised to K761)




## EXAMPLE: Door Inspections

<b>Chapter 1 Administration</b> .....	80- 5	<b>Chapter 9 Special-Purpose Horizontally Sliding</b>	
1.1 Scope .....	80- 5	<b>Accordion or Folding Doors</b> .....	80-22
1.2 Purpose .....	80- 5	9.1 Doors .....	80-22
1.3 Retroactivity .....	80- 5	9.2 Supporting Construction .....	80-22
1.4 Equivalency .....	80- 5	9.3 Clearances Around Openings .....	80-22
<b>Chapter 2 Referenced Publications</b> .....	80- 5	9.4 Assembly Components .....	80-22
2.1 General .....	80- 5	<b>Chapter 10 Vertically Sliding Fire Doors</b> .....	80-22
2.2 NFPA Publications .....	80- 5	10.1 Doors .....	80-22
2.3 Other Publications .....	80- 6	10.2 Supporting Construction .....	80-22
2.4 References for Extracts in Mandatory		10.3 Clearances .....	80-23
Sections .....	80- 6	10.4 Assembly Components .....	80-23
<b>Chapter 3 Definitions</b> .....	80- 6	<b>Chapter 11 Rolling Steel Doors</b> .....	80-24
3.1 General .....	80- 6	11.1 Doors .....	80-24
3.2 NFPA Official Definitions .....	80- 6	11.2 Supporting Construction .....	80-24
3.3 General Definitions .....	80- 7	11.3 Openings .....	80-24
<b>Chapter 4 General Requirements</b> .....	80-11	11.4 Assembly Components .....	80-24
4.1 General Limitations .....	80-11	11.5 Weather Protection .....	80-25
4.2 Listed and Labeled Products .....	80-11	<b>Chapter 12 Fire Shutters</b> .....	80-25
4.3 Classifications and Types of Doors .....	80-11	12.1 Types .....	80-25
4.4 Glazing Material in Fire Doors .....	80-12	12.2 Requirements .....	80-25
4.5 Fire Resistance-Rated Glazing in Doors		12.3 Weather Protection .....	80-25
and Windows .....	80-12	<b>Chapter 13 Service Counter Fire Doors</b> .....	80-25
4.6 Classification of Hardware for Fire		13.1 Doors .....	80-25
Doors .....	80-12	13.2 Supporting Construction .....	80-25
4.7 Placement of Detectors .....	80-12	13.3 Counters .....	80-25
4.8 Supporting Construction .....	80-13	<b>Chapter 14 Automatic Closing Devices</b> .....	80-26
4.9 Testing .....	80-14	14.1 Hoistway Door Vision Panels .....	80-27
<b>Chapter 5 Care and Maintenance</b> .....	80-14	14.2 Door Operation .....	80-27
5.1 General .....	80-14	<b>Chapter 15 Chute Doors</b> .....	80-27
5.2 Inspections .....	80-14	15.1 Doors .....	80-27
5.3 Maintenance .....	80-16	<b>Chapter 16 Access Doors</b> .....	80-27
<b>Chapter 6 Swinging Doors with Builders</b>		16.1 Doors .....	80-27
<b>Hardware</b> .....	80-16	16.2 Types of Doors .....	80-27
6.1 Doors .....	80-16	<b>Chapter 17 Fire Windows</b> .....	80-28
6.2 Supporting Construction .....	80-16	17.1 Windows .....	80-28
6.3 Openings .....	80-16	17.2 Glazing Material .....	80-28
6.4 Assembly Components .....	80-17	17.3 Types of Windows .....	80-28
6.5 Application, Installation, and		17.4 Installation .....	80-29
Adjustment .....	80-19	17.5 Closing Devices .....	80-29
<b>Chapter 7 Swinging Doors with Fire Door</b>		<b>Chapter 18 Glass Block Assemblies</b> .....	80-29
<b>Hardware</b> .....	80-19	18.1 General .....	80-29
7.1 Doors .....	80-19	18.2 Installation .....	80-29
7.2 Supporting Construction .....	80-19		
7.3 Openings .....	80-20		
7.4 Assembly Components .....	80-20		
<b>Chapter 8 Horizontally Sliding Doors</b> .....	80-20		
8.1 Doors .....	80-20		
8.2 Supporting Construction .....	80-21		
8.3 Openings (Reserved) .....	80-21		
8.4 Assembly Components .....	80-21		

Look in Section 5.2

## Checklist Creation

### Research Fire Door Inspections






**EXAMPLE: Door Inspections****Checklist Creation****5.2\* Inspections**

- ▲ 5.2.1\* Fire door assemblies shall be inspected and tested not less than annually, and a written record of the inspection shall be signed and kept for inspection by the AHJ.

▲ 5.2.3 Functional **Testing**.

5.2.3.1 Functional testing of fire door and window assemblies shall be performed by individuals with knowledge and understanding of the operating components of the type of door being subject to testing.

5.2.3.2 Before testing, a visual inspection shall be performed to identify any damaged or missing parts that can create a hazard during testing or affect operation or resetting.



## EXAMPLE: Door Inspections

### 5.2.4 Swinging Doors with Builders Hardware or Fire Door Hardware.

5.2.4.1 Fire door assemblies shall be visually **inspected** from both sides to assess the overall condition of door assembly.


▲ 5.2.4.2 As a minimum, the following items shall be verified:

- ▲ (1) No open holes or breaks exist in surfaces of either the door or frame.
- ▲ (2) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
- ▲ (3) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.
- ▲ (4) No parts are missing or broken.
- ▲ (5) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.
- (6) The self-closing device is operational; that is, the active door completely closes when operated from the full open position.
- (7) If a coordinator is installed, the inactive leaf closes before the active leaf.
- (8) Latching hardware operates and secures the door when it is in the closed position.
- ▲ (9) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.
- (10) No field modifications to the door assembly have been performed that void the label.
- ▲ (11) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.

## Checklist Creation

### KEY CHECKPOINTS


1. Is the door in working order & good condition  
(1)-(4); (6)-(9); (11)
2. Clearances per code (5)
3. No field modifications (10)







**EXAMPLE: Door Inspections****Checklist Creation****Step 4: Make Up a Document CHECKLIST**

I prefer to cut & place discoveries in a spreadsheet



<b><u>1. FIRE DOOR, SWINGING ANNUAL</u></b>	<b>NFPA CODE NFPA 80-2010</b>
<b><u>(2). Fire doors inspected &amp; tested</u></b> at least annually;	§5.2.1
(A) with written & signed record of inspection	
(B) Testing performed by Individuals with knowledge & understanding of the operating components of the door being inspected	§5.2.3.1
<b><u>(3) Test Automatic Closing</u></b> doors to verify the assembly will close under fire conditions.	§5.2.6
<b><u>(4) Visual inspection</u></b>	§5.2.3.1
(A) performed (prior to testing) from both sides to assess overall condition of door assembly	5.2.4.1
(B) No holes or breaks exist in surfaces of either door or frame	§5.2.4.2(1)
(C) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.	§5.2.4.2(3)
(D) No parts are missing or broken.	§5.2.4.2(4)
(E) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.	§5.2.4.2(5)
(F) The self-closing device is operational (active door completely closes when from the full open position)	§5.2.4.2(6)
(G) Latching hardware operates and secures the door when it is in the closed position.	§5.2.4.2(8)
(H) No field modifications to the door assembly have been performed that void the label.	§5.2.4.2(10)
(I) Hardware shall be examined, and inoperative hardware, parts, or other defects shall be replaced without delay.	§5.2.9


# You'll Quickly Learn there are 2 Inspection Situations




**You'll Quickly Learn there are**

**2**

**Inspection  
Situations**



**1. “Basic”  
Inspections**



**2. “IF”  
Inspections**

## **Research the Applicable Codes**

### **1. “Basic” Inspections**

**Do these  
Inspections  
for ALL  
items**

## Research the Applicable Codes

### 2. “IF” Inspections

**Inspections you do  
ONLY “IF”  
you have  
a certain component**

You’ll see these later when we review specific checklists

The process of creating checklists can be very complicated & time consuming

**LLSC has gone through these steps for almost all the NFPA codes**

(available to Code Central Members as the “Document Tool Box”)

**Let's look at the LLSC  
Door Inspection Checklist**

# TWO PARTS OF THE CHECKLIST

## Fire Door Checklist

LLSC INSPECTION REPORT EVALUATION TOOL 5 Most Cited Inspections Page 1 of 9

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)					
NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010	TJC STD	
Report Title:		Date of Report:			
		(1) Report contains (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) Specific CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency			
		(2) Fire doors inspected & tested at least annually;	\$5.2.1	LS.02.01.20 EP 32	
		(A) with written & signed record of inspection	\$5.2.3.1	LS.02.01.20 EP 32	
		(B) Testing performed by Individuals with knowledge & understanding of the operating components of the door being inspected	\$5.2.6	EC.02.03.05 EP 20	
		(3) Test Automatic Closing doors to verify the assembly will close under fire conditions.	\$5.2.3.1	LS.02.01.20 EP 32	
		(4) Visual inspection	5.2.4.1		
		(A) performed (prior to testing) from both sides to assess overall condition of door assembly	\$5.2.4.2(1)	LS.02.01.20 EP 32	
		(B) No holes or breaks exist in surfaces of either door or frame	\$5.2.4.2(3)	LS.02.01.20 EP 32	
		(C) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.	\$5.2.4.2(4)	LS.02.01.20 EP 32	
		(D) No parts are missing or broken.	\$5.2.4.2(5)	LS.02.01.20 EP 32	
		(E) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.	\$5.2.4.2(6)	LS.02.01.20 EP 32	
		(F) The self-closing device is operational (active door completely closes when from the full open position)	\$5.2.4.2(8)	LS.02.01.20 EP 32	
		(G) Latching hardware operates and secures the door when it is in the closed position.	\$5.2.4.2(10)	LS.02.01.20 EP 32	
		(H) No field modifications to the door assembly have been performed that void the label.	\$5.2.9	LS.02.01.20 EP 32	
		(I) Hardware shall be examined, and inoperative hardware, parts, or other defects shall be replaced without delay.			

### Part 1 - Basics

Inspect ALL rated doors for these items

4 BASIC CHECKPOINTS

These items are only inspected if present, but form should have space to indicate that item is not present, i.e. not applicable					
NOT APPLIC	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010	TJC STD
			(4) Visual inspection (continued)	\$5.2.4.2(11)	LS.02.01.20 EP 32
			(J) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.	\$5.2.4.2(2)	LS.02.01.20 EP 32
			(K) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.	\$5.2.4.2(7)	LS.02.01.20 EP 32
			(L) If a coordinator is installed, the inactive leaf closes before the active leaf	\$5.2.4.2(9)	LS.02.01.20 EP 32
			(M) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.	\$5.2.12.1	EC.02.03.05 EP 20
			(5) Maintenance: Guides and bearings shall be kept well lubricated to facilitate operation	\$5.2.2.1	
			(6) A written Performance Based program for inspection, testing and maintenance is an acceptable alternative to the above if acceptable to the AHJ		

### Part 2 - "IFs"

Inspect these items IF you have these components

3 SUPPLEMENTAL CHECKPOINTS

We'll show you how to use this form later when reviewing the top 5 inspection documents



TOOLS for REVIEW of

# Inspection Documentation

1. REALITIES of Document Review
2. Document Review Concepts
3. **The Report Tool Box**
4. Evaluate The Big 5 Doc Forms



# What is the Report Tool Box?

NOTHING MORE THAN  
**A COPY OF THE CODE**

In a Checklist Format

It's a Tool to:

1. Show That You Know the Code
2. Document That You are Following the Code

# Code Workshop

## Report Tool Box Suite

1. Report Tool Box
2. Document Tool Box

AVAILABLE TO CODE CENTRAL MEMBERS  
(FREE DOWN-LOAD)

# 1. Report Tool Box

"REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS			Logo							Developed by Lanes Life Safety Consulting Lanes-LLSC.com For Support, Contact: 262-554-3874; Llanes@lsc.com	
Facility:	ABC Health Care, Nauvoo, WI		v14.1 12/22/2016		(Format \$1 - Date Fill-In)						
Freq	Report Name (Ref - NFPA Code Reg)	Code	NFPA/DHS Code	TJC Stand ard	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Dnc File Loc	Typic al Image	
Freq	1 - GENERAL & BUILDING	Code	NFPA/DHS Code	TJC Stand ard	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Dnc File Loc	Typic al Image	
A	1DA-FIRE DOOR, SLIDING-ROLLING-ANNUAL	X	NFPA 88-2018, SS	EC 82.03.1 5, EP 28							
A	1DB-FIRE DOOR, SWINGING-ANNUAL	X	NFPA 88-2018, SS	LS 82.04.28 , EP 32							
A	1DC-DOORS, ASSEMBLY-ANNUAL	X	LSC-2812, 57	LS 82.04.28 , EP 32							
SA	1C-LOCAL FIRE DEPT INSPECTION (LTC)	X	DHS 132.02(5)(a)	LS 81.01.01 , EP 14							
Always	1D-FLAME SPREAD DOCUMENTS	X	LSC-2812, 518/15	LS 82.04.38 , EP 14	Last Review/Update:						
M	1E-ELEV RECALL-MONTHLY	X	LSC-2812, 53	LS 82.04.58 , EP 12	Jan 1 Feb 1 Mar 1	Apr 1 May 1 Jun 1	Jul 1 Aug 1 Sep 1	Oct 1 Nov 1 Dec 1			
D	1F-CONSTRUCTION MEANS OF EGRESS	X	LSC-2812, 518/15	LS 81.01.01 , EP 14	Refer to Log of Daily Inspections						
Always	1G-LIFE SAFETY PLAN	X	DHS Expiration	LS 81.01.01 , EP 14	Last Review/Update:						
A	1HA-ELEVATOR USE CERTIFICATE	X	SPS 518	LS 81.01.01							
3 Yr	<div>Massive Spread Sheet to Record Your Inspections</div>										
SA											
Always											
Always											
Always											
Always											
Always	III-E-SMOKE BARRIER WALL & DOOR COMPLY	X	Requirements	Require							
Always	III-F-CEILING COMPLIANCE	X	Requirements	Require							
Always	III-G-DECORATION COMPLIANCE	X	Requirements	Require							
Always	III-H-SEPARATION WALL & DOOR COMPLY	X	Requirements	Require							
Always	III-I-FIRE STOP PROGRAM COMPLIANCE	X	Requirements	Require	Last Review/Update:						

# Report Tool Box

## Inspection Report Names

## Check-List (Write-In Option)

**"REPORT TOOL BOX"**  
of LIFE SAFETY DOCUMENTS

Logo

Facility: ABC Health Care, Nauvoo, WI v14.112/22/2016

Developed by Lanes Life Safety Consulting  
Lanes-LLSC.com  
For Support, Contact:  
262-654-3874; laneslifefire@gmail.com

(Format #1 - Date Fill-In)

Frq	Report Name (Ref - NFPA Code Ref)	Code	NFPA/DH S Code	TJC Stand- ard	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Dnc File Loc	Typic- al Inp
Frq	<b>1 - GENERAL &amp; BUILDING</b>	Code	NFPA/DH S Code	TJC Stand- ard	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Dnc File Loc	Typic- al Inp
A	19A - FIRE DOOR, SLIDING-ROLLING-ANNUAL	X	NFPA 88-2818, 55	EC-82.81 5, EP 2						
A	19D - FIRE DOOR, SWINGING-ANNUAL	X	NFPA 88-2818, 55	LS-82.81 5, EP 2						
A	19C - DOORS, ASSEMBLY - ANNUAL	X	LSC-2842, 57	LS-82.81 5, EP 2						
SA	1C - LOCAL FIRE DEPT INSPECTION (LTC)	X	DHS 192.82(3)(i)	LS-81.81 5, EP 8						
Change	1D - FLAME SPREAD DOCUMENTS	X	LSC-2842, 518/45	LS-82.81 5, EP 8						
M	1E - ELEV RECALL-MONTHLY	X	LSC-2842, 53	LS-82.81 5, EP 12						
D	1F - CONSTRUCTION MEANS OF EGRESS	X	LSC-2842, 518/45	LS-81.81 5, EP 8						
Change	1G - LIFE SAFETY PLAN	X	DHS Expiration	LS-81.81 5, EP 8						
A	1HA - ELEVATOR USE CERTIFICATE	X	SPS 318	LS-81.81						
3Yr	1HB - PRESSURE VESSEL CERTIFICATES	X								
SA	1HC - FIRE DEPT INSPECTIONS	X								
Change	1HA - INSPECTOR QUALIFICATIONS (In-house & Vendor)	X								
Change	1ID - EXIT DISCHARGE COMPLIANCE	X	Requirements	Requir-						
Change	1IC - HAZ ROOM COMPLIANCE	X	Requirements	Requir-						
Change	1ID - CORRIDOR WALL & DOOR COMPLIANCE	X	Requirements	Requir-						
Change	1IE - SMOKE BARRIER WALL & DOOR COMPLY	X	Requirements	Requir-						
Change	1IF - CEILING COMPLIANCE	X	Requirements	Requir-						
Change	1IG - DECORATION COMPLIANCE	X	Requirements	Requir-						
Change	1IH - SEPARATION WALL & DOOR COMPLY	X	Requirements	Requir-						
Change	1II - FIRE STOP PROGRAM COMPLIANCE	X	Requirements	Requir-						

Last Review/Update:

Jan 1 Feb 1 Mar 1 Apr 1 May 1 Jun 1 Jul 1 Aug 1 Sep 1 Oct 1 Nov 1 Dec 1


Refer to Log of Daily Inspections

Last Review/Update:

Jan 1 Feb 1 Mar 1 Apr 1 May 1 Jun 1 Jul 1 Aug 1 Sep 1 Oct 1 Nov 1 Dec 1

Goes down > 180 lines

<b>"REPORT TOOL BOX"</b> <b>of LIFE SAFETY</b> <b>DOCUMENTS</b>			<b>Logo</b>	
Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard



### Column Headings

1. Frequency of Inspection: W, M, Q, SA, A, 2yr, etc
2. Report Name (over 120)
3. NFPA Code Hyperlink: read the code requirements
4. NFPA Code Reference
5. TJC Standard Reference

## "REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS

Logo

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

Freq	1 - GENERAL & BUILDING	Code	NFPA/DHS Code	TJC Standard
A	1BA-FIRE DOOR,SLIDING-ROLLING-ANNUAL	X	NFPA 80-2010, \$5	EC.02.03.05, EP 20
A	1BB			LS.02.01.20, EP 32
A	1BC			LS.02.01.20, EP 32
SA	1C - LOCAL FIRE DEPT INSPECTION (LTC)	X	DHS 132.82(3)(c)	LS.01.01.01, EP 04
always	1D - FLAME SPREAD DOCUMENTS	X	LSC-2012, \$18/19	LS.02.01.30, EP 04
M	1E - ELEV RECALL-MONTHLY	X	LSC-2012, \$9	LS.02.01.50, EP 12
D	1F - CONSTRUCTION MEANS OF EGRESS	X	LSC-2012, \$18/19	LS.01.01.01, EP 01
always	1G - LIFE SAFETY PLAN	X	DHS Expectation	LS.01.01.01, EP 01
A	1HA - ELEVATOR USE CERTIFICATE	X	SPS 318	LS.01.01.01, EP 04
3Yr	1HB - PRESSURE VESSEL CERTIFICATES	X	SPS 341.17	LS.01.01.01, EP 04
SA	1HC - FIRE DEPT INSPECTIONS	X	DHS 132.82(3)(c)	LS.01.01.01, EP 04
always	1IA - INSPECTOR QUALIFICATIONS (In-house & 3rd party)	X	misc	misc

&gt;20 Reports

## Groupings of Reports

### 1. General & Building

## "REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS

Logo

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

Freq	2 - SUPPRESSION SYS	Code	NFPA/DHS Code	TJC Standard
M	2AD - SPRINKLER-MONTHLY	X	NFPA 25-2011, \$5 & \$13	LS 02.01.35, EP 14
Q	2AE -			EC.02.03.0 5 EP 10
SA	2AF-SPRINKLER-SEMI-ANNUAL	Δ	\$5 & \$13	EC.02.03.0 5 EP 02
A	2AG - SPRINKLER-ANNUAL	X	NFPA 25-2011, \$5 & \$13	EC.02.03.0 5 EP 09
3 Yr	2AH - SPRINKLER MAINT - 3 YR	X	NFPA 25-2011, \$13	02.01.35, EP 14
5 Yr	2AI - SPRINKLER MAINT - 5 YR	X	NFPA 25-2011, \$13	02.01.35, EP 14
varies	2AJ - SPRINKLER MAINT - >10, 20, 50 YR	X	NFPA 25-2011, \$5	02.01.35, EP 14
W	2AK - STANDPIPE - WEEKLY	X	NFPA 25-2011, \$13	02.01.35, EP 14
Q	2AL - STANDPIPE - QUARTERLY	X	NFPA 25-2011, \$13	02.01.35, EP 14
A	2AM - STANDPIPE - ANNUAL	X	NFPA 25-2011, \$6 & \$13	02.01.35, EP 14
3 Yr	2AN - STANDPIPE MAINT - 3 YR	X	NFPA 25-2011, \$13	02.01.35, EP 14
5 Yr	2AO - STANDPIPE MAINT - 5 YR	X	NFPA 25-2011, \$6 & \$13	02.01.35, EP 14

&gt;50 Reports

## Groupings of Reports

1. General & Building
2. Suppression

#1 CMS Cite

#1 Joint  
Commission Cite

## "REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS

Logo

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

Freq	3- FIRE ALARM SYS	Code	NFPA/DHS Code	TJC Standard
D	3B - ALARM TRANSMISSION-DAILY	X	NFPA 72-2010,\$14	EC 02.01.34, EP 04
W	3C - A	X		02.01.34, EP 04
M	3DA -	X	2010,\$14	02.01.34, EP 04
Q	3DB - FIRE ALARM - QUARTERLY	X	NFPA 72-2010,\$14	EC.02.03.05, EP 01
SA	3DC - FIRE ALARM-SEMI ANNUAL	X	NFPA 72-2010,\$14	EC.02.03.05 EP 01LS
A	3DE - FIRE ALARM - ANNUAL	X	NFPA 72-2010,\$14	EC.02.03.05 EP 03LS
2 Yr	3DF - DETECTOR SENSITIVITY- 2-Yr	X	NFPA 72-2010,\$14	02.01.34, EP 04
10 Yr	3E - CARBON MONOXIDE- 10 Yr	X	NFPA720-2012,\$8	02.01.34, EP 04
W	3FA - SMOKE ALARM, BATTERY-WKLY	X	NFPA 72-2010,\$14	02.01.34, EP 04
SA	3FB - SMOKE ALARM, BATTERY-SEMI-A	X	NFPA 72-2010,\$14	02.01.34, EP 04
10 Yr	3FC - SMOKE ALARM, BATTERY - 10 Yr	X	NFPA 72-2010,\$14	02.01.34, EP 04

12 Reports

## Groupings of Reports

1. General & Building
2. Suppression
3. Fire Alarm

#4 CMS Cite

#1 Joint  
Commission Cite



## "REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS

Logo

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

Freq	4- ELECTRICAL SYS	Code	NFPA/DHS Code	TJC Standard
W	4AA - GENERATOR - WEEKLY	X	NFPA 110-2010 §8	LS.02.01.7C ,EP 04
M	4AB - GENERATOR LOAD BANK - MONTHLY	X	NFPA 110-2010 §8	EC.02.05.0 7,EP 04
A	4AC - GENERATOR LOAD BANK - ANNUAL	X	NFPA 110-2010 §8	EC.02.05.0 7,EP 05
3 Yr	4AD - GENERATOR LOAD BANK-3 YR	X	NFPA 110-2010 §8	EC.02.05.0 7,EP 07
fac pol	4AE - GENERATOR SERVICE REPORTS	X	NFPA 110-2010 §8	EC.02.05.0 7,EP 09
A	4AF - GENERATOR FUEL-ANNUAL	X	NFPA 110-2010 §8	LS.02.01.7C ,EP 04
A	4AG - NATURAL GAS RELIABILITY Letter	X	CMS Letter- 5/9/09	LS.02.01.7C ,EP 04
Maint	4B - TRANSFER SWITCH	X	NFPA 110-2010 §8	LS.02.01.7C ,EP 04
SA	4CA - EMERGENCY BREAKER - SEMI-A	X	NFPA 110-2010 §8	LS.02.01.7C ,EP 04
A	4CB - EMERGENCY BREAKER - ANNUAL	X	NFPA 110-2010 §8	LS.02.01.7C ,EP 04
2 Yr	4CC - EMERGENCY BREAKER - 2 Yr	X	NFPA 110-2010 §8	LS.02.01.7C ,EP 04
fac pol	4D - PARALLELING GEAR	X	NFPA 110-2010 §8	LS.02.01.7C ,EP 04

&gt;25 Reports

## Groupings of Reports

1. General & Building
2. Suppression
3. Fire Alarm
4. Electrical

#8 CMS SNF Cite

## "REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS

Logo

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

Freq	5 - MECHANICAL SYS	Code	NFPA/DHS Code	TJC Standard
install	5AA- FIRE & SMOKE DAMPERS-Install	X	NFPA 80-2010, §19	LS.02.01.50, EP 12
4 or 6 Yr	5AB- FIRE & SMOKE DAMPERS-4 or 6 Yr	X	NFPA 80-2010, §19	EC.02.03.05, EP 18
SA	5BA- FIRE & SMOKE DAMPERS-SEMI-ANNUAL	X	NFPA 80-2010, §19	LS.02.01.50, EP 12
A	5BB -SMOKE CONTROL, NON-DEDICATED-A	X	NFPA 92-2012, §8	LS.02.01.50, EP 12
Q	5CA- LAB HOOD -QUARTERLY	X	NFPA 45-2011, §8	LS.02.01.50, EP 12
A	5CB- LAB HOOD -ANNUAL	X	NFPA 45-2011, §8	LS.02.01.50, EP 12
fac pol	5D - EYEWASH & SHOWERS	X	OSHA 1910.151(c)	LS.01.01.01, EP 04
D	5EA - MEDICAL GASES - Level 3 -DAILY	X	NFPA 99-2012, §5	LS.02.01.50, EP 12
fac pol	5EA - MEDICAL GASES - POLICY	X	NFPA 99-2012, §5	LS.02.01.50, EP 12
install	5EB - MEDICAL GASES - INSTALL	X	NFPA 99-2012, §5	LS.02.01.50, EP 12
fac pol	5EC - MEDICAL GASES - PER FAC POLICY	X	NFPA 99-2012, §5	LS.02.01.50, EP 12
A	5ED-BULK CYROGENIC SYS - ANNUAL	X	NFPA 99-2012, §5	LS.02.01.50, EP 12

6 Reports

## Groupings of Reports

1. General & Building
2. Suppression
3. Fire Alarm
4. Electrical
5. Mechanical

**"REPORT TOOL BOX"  
of LIFE SAFETY  
DOCUMENTS**

**Logo**

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

Freq	6 - FIRE RESPONSE	Code	NFPA/DHS Code	TJC Standard
always	6A - RESIDENT DISASTER PLAN	X	DHS 132.82(3)(a)1	LS.01.01.01, EP 04
always	6B - F	X	DHS 132.82(3)(a)1	EC.02.03.01, EP 10
f Changed	6B - F	X	DHS 132.82(3)(a)1	LS.01.01.01, EP 04
Q	6CA - FIRE DRILLS	X	LSC-2012, §4 & §18/19	EC.02.03.03, EP 01 thru
A	6CB - SURGICAL FIRE DRILL - ANNUAL	X	NFPA 99-2012, §15	LS.01.01.01, EP 04
A	6CC - HYPERBARIC FIRE DRILL - ANNUAL	X	NFPA 99-2012, §14	LS.01.01.01, EP 04
always	6D - REPORT OF FIRES	X	DHS 124.36(11) DHS 132.82(e)1	LS.01.01.01, EP 04

7 Reports

Groupings of  
Reports

1. General & Building
2. Suppression
3. Fire Alarm
4. Electrical
5. Mechanical
6. Fire Response

## "REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS

Logo

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

Freq	7 - POLICIES	Code	NFPA/DHS Code	TJC Standard
always	7AA - SPRINKLER OUTAGE POLICY	X	LSC-2012, §9	LS.02.01.35 , EP 14
always	7AB -			LS.02.01.35 , EP 14
always	7AC -			LS.02.01.35 , EP 14
always	7B - PORTABLE SPACE HEATER POLICY	X	LSC-2012, §18/19	LS.02.01.70 , EP 03
always	7C - SMOKING POLICY	X	LSC-2012, §18/19	EC.02.01.03 EP 01
A	7D - SURGICAL PROCEDURES	X	NFPA 99-2012, §15	LS.01.01.01 EP 04

6 Reports

## Groupings of Reports

1. General & Building
2. Suppression
3. Fire Alarm
4. Electrical
5. Mechanical
6. Fire Response
7. Policies

## "REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS

Logo

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

Freq	8 - JOINT COMMISSION	Code	NFPA/DHS Code	TJC Standard
always	8A-INTERIM LIFE SAFETY MEASURES	X	none	LS.01.02.01 EP 03
always	8B-CO			EC.02.06.0 5 EP 01
always	8C-FIR			EC.01.01.01 EP 3
always	8DA-LIFE SAFETY MANAGEMENT PLAN	X	none	EC.01.01.01 EP 06
always	8DB - STATEMENT OF CONDITIONS	X	none	LS.01.01.01 EP 02
always	8DC - PLANS FOR IMPROVEMENT	X	none	LS.01.01.01 EP 03
always	8C-UTILITY MANAGEMENT PLAN	X	none	EC.02.05.01
always	8D-HAZARDOUS MATERIAL MGMT PLAN	X	none	EC.02.02.01
always	8E-INFORMATION COLLECTION	X	none	EC.04.01.01
always	8F-SAFETY & SECURITY MGMT PLAN	X	none	EC.02.01.01

10 Reports

## Groupings of Reports

1. General & Building
2. Suppression
3. Fire Alarm
4. Electrical
5. Mechanical
6. Fire Response
7. Policies
8. Joint Commission

## "REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS

Logo

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

CUSTOMIZABLE!

3. Fire Alarm

Freq	3- FIRE ALARM SYS	Code	NFPA/DHS Code	TJC Standard
D	3B - ALARM TRANSMISSION-DAILY	X	NFPA 72-2010,\$14	
W	3C - ALARM TRANSMISSION-WEEKLY	X	NFPA 72-2010,\$14	
M	3DA - FIRE ALARM - MONTHLY	X	NFPA 72-2010,\$14	EP 04
Q	3DB - FIRE ALARM - QUARTERLY	X	NFPA 72-2010,\$14	EC.02.03.05, EP 01
SA	3DC - FIRE ALARM-SEMI ANNUAL	X	NFPA 72-2010,\$14	EC.02.03.05 EP 01LS
A	3DE - FIRE ALARM - ANNUAL	X	NFPA 72-2010,\$14	EC.02.03.05 EP 01LS
2 Yr	3DF - DETECTOR SENSITIVITY- 2-Yr	X		
10 Yr	3E - CARBON MONOXIDE- 10 Yr	X		
W	3FA - SMOKE ALARM, BATTERY-WKLY	X	NFPA 72-2010,\$14	
SA	3FB - SMOKE ALARM, BATTERY-SEMI-A	X	NFPA 72-2010,\$14	
10 Yr	3FC - SMOKE ALARM, BATTERY - 10 Yr	X	NFPA 72-2010,\$14	EP 04 02.01.34, EP 04

Don't Have all these systems?

Customize by deleting or hiding those rows !  
(right Click-hide/delete)

## "REPORT TOOL BOX" of LIFE SAFETY DOCUMENTS

Logo

Facility:	ABC Health Care, Nowhere, WI		v14.1 12/22/2016	
Freq	Report Name	Code	NFPA/DHS Code	TJC Standard

CUSTOMIZABLE!

3. Fire Alarm

Freq	3- FIRE ALARM SYS	Code	NFPA/DHS Code	TJC Standard
W	3C - ALARM TRANSMISSION-WEEKLY	X	NFPA 72-2010,\$14	
M	3DA - FIRE ALARM - MONTHLY	X	NFPA 72-2010,\$14	
Q	3DB - FIRE ALARM - QUARTERLY	X	NFPA 72-2010,\$14	
SA	3DC - FIRE ALARM-SEMI ANNUAL	X	NFPA 72-2010,\$14	5 EP 01 LS 02.01.34
A	3DE - FIRE ALARM - ANNUAL	X	NFPA 72-2010,\$14	5 EP 03 LS 02.01.34
2 Yr	3DF - DETECTOR SENSITIVITY- 2-Yr	X	NFPA 72-2010,\$14	02.01.34, EP 04

Your list of required reports got smaller

Keep only the systems that are at your facility





## Right Columns

## Report Tool Box

Freq	1 - GENERAL & BUILDING	Code	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Doc File Loc	Typical Inspector
A	1BA-FIRE DOOR,SLIDING-ROLLING-ANNUAL	X						
A	1BB - FIRE DOOR,SWINGING ANNUAL	X						
A	1BC - DOORS, ASSEMBLY - ANNUAL	X						
SA	1C - LOCAL FIRE DEPT INSPECTION (LTC)	X						
always	1D - FLAME SPREAD DOCUMENTS	X	Last Review/Update:					
M	1E - ELEV RECALL-MONTHLY	X	Jan   Feb   Mar	Apr   May   Jun	Jul   Aug   Sep	Oct   Nov   Dec		
D	1F - CONSTRUCTION MEANS OF EGRESS	X	Refer to Log of Daily Inspections					
always	1G - LIFE SAFETY PLAN	X	Last Review/Update:					
A	1HA - ELEVATOR USE CERTIFICATE	X						
3 Yr	1HB - PRESSURE VESSEL CERTIFICATES	X						
SA	1HC - FIRE DEPT INSPECTIONS							
always	1IA - INSPECTOR QUALIFICATIONS & Vender)							
always	1IB - EXIT DISCHARGE COMPLIANCE							
always	1IC - HAZ ROOM COMPLIANCE							
always	1ID - CORRIDOR WALL & DOOR COMPLIANCE							
always	1IE - SMOKE BARRIER WALL & DOOR COMPLIANCE	X						
always	1IF - CEILING COMPLIANCE							
always	1IG - DECORATION COMPLIANCE							
always	1IH - SEPARATION WALL & DOOR COMPLIANCE	X						
always	1II-FIRE STOP PROGRAM COMPLIANCE	X	Last Review/Update:					

Easy to spot that an inspection was missed!

Can Use as a simple check-off that the inspection was completed

NO surprises! You DON'T want the inspector to be the one to discover it

## Middle Columns

## Report Tool Box

Freq	1 - GENERAL & BUILDING	Code	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Doc File Loc	Typical Inspector
A	1BA - FIRE DOOR, SLIDING-ROLLING-ANNUAL	X						
A	1BB - FIRE DOOR, SWINGING-ANNUAL	X						
A	1BC - DOORS, ASSEMBLY - ANNUAL	X	3/23/17					
SA	1C - LOCAL FIRE DEPT INSPECTION (LTC)	X						
always	1D - FLAME SPREAD DOCUMENTS							
M	1E - ELEV RECALL-MONTHLY							
D	1F - CONSTRUCTION MEANS OF EGRESS							
always	1G - LIFE SAFETY PLAN	X	Last Review/Update:					
A	1HA - ELEVATOR USE CERTIFICATE	X						
3 Yr	1HB - PRESSURE VESSEL CERTIFICATES	X						
SA	1HC - FIRE DEPT INSPECTIONS	X						
always	1IA - INSPECTOR QUALIFICATION & Vender)							
always	1IB - EXIT DISCHARGE COMPLIANCE							
always	1IC - HAZ ROOM COMPLIANCE							
always	1ID - CORRIDOR WALL & DOOR COMPLIANCE							
always	1IE - SMOKE BARRIER WALL & DOOR COMPLIANCE	X						
always	1IF - CEILING COMPLIANCE	X						
always	1IG - DECORATION COMPLIANCE	X						
always	1IH - SEPARATION WALL & DOOR COMPLIANCE	X						
always	1II - FIRE STOP PROGRAM COMPLIANCE	X	Last Review/Update:					

BETTER, write-in the date that a task was completed

No Matter What.  
Regardless of the system you use.  
The goal is → NO surprises!

## Middle Columns

## Report Tool Box

Freq	1 - GENERAL & BUILDING	Code	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr	Doc File Loc	Typical Inspector
A	1BA - FIRE DOOR, SLIDING-ROLLING-ANNUAL	X						
A	1BB - FIRE DOOR, SWINGING-ANNUAL	X						
A	1BC - DOORS, ASSEMBLY - ANNUAL	X	3/23/17				Tab 5	FW
SA	1C - LOCAL FIRE DEPT INSPECTION (LTC)	X						
always	1D - FLAME SPREAD DOCUMENTS	X	Last Review/Update:					
M	1E - ELEV RECALL-MONTHLY	X						
D	1F - CONSTRUCTION MEANS OF EGRESS	X						
always	1G - LIFE SAFETY PLAN	X						
A	1HA - ELEVATOR USE CERTIFICATE	X						
3 Yr	1HB - PRESSURE VESSEL CERTIFICATES	X						
SA	1HC - FIRE DEPT INSPECTIONS	X						
always	1IA - INSPECTOR QUALIFICATIONS (In-house & Vender)	X	Last Review/Update:					
always	1IB - EXIT DISCHARGE COMPLIANCE	X						
always	1IC - HAZ ROOM COMPLIANCE	X						
always	1ID - CORRIDOR HALL & ROOM COMPLIANCE	X						
always	1IE - SM	X						
always	1IF - CEIL	X						
always	1IG - DECORATION COMPLIANCE	X						
always	1IH - SEPARATION WALL & DOOR COMPLY	X						
always	1II - FIRE STOP PROGRAM COMPLIANCE	X	Last Review/Update:					

Write-in location where you filed the report

Write-in who did the inspection

This helps you (or your substitute) locate a report when asked for it during the stress of a survey

## 2. Document Tool Box

Freq	1 - GENERAL & BUILDING	Doc	Jan	Feb	Mar	Apr	May	Jun	
A	1BA - FIRE DOCS								
A	1BB - FIRE DOCS								
A	1BC - DOORS,								
SA	1C - LOCAL FIRE								
always	1D - FLAME SPREAD DOCUMENTS	<a href="#">X</a>							
M	1E - ELEV RECALL-MONTHLY	<a href="#">X</a>				<a href="#">4/04</a>			
D	1F - CONSTRUCTION MEANS OF EGRESS	<a href="#">X</a>							
always	1G - LIFE SAFETY PLAN	<a href="#">X</a>							
A	1HA - ELEVATOR USE CERTIFICATE	<a href="#">X</a>							
always	1IA - INSPECTOR QUALIFICATIONS (In-house & Vender)	<a href="#">X</a>					Copyright, LLSC Dec 2018		80

The strength of the Report Tool Box is it's built-in hyperlink to the Document Tool Box

You don't need to remember any inspection details  
"It's in there !" ... Just Click the 'X'

Code Requirement  
(summarized)NFPA  
RefTJC  
Ref

1E - ELEV RECALL-MONTHLY	NFPA CODE (CMS K160)	TJC STD
<p>♦ <b>Elev Inspection</b> per ASME A17.1-2007; Elevators with fire fighters' service must be tested monthly, with a written record (9.4.6.2). NOTE: Wis DSPS 318 permits quarterly inspections; however LSC 9.4.6.3(2) says that only the AHJ can revise the frequency and CMS considers itself as the only authorized AHJ that can make such changes.</p>	LSC-2012, §9.4.6.1	LS.02.01.50-EP 12
<p>♦ <b>Recall Inspection</b> Includes - ♦ Called car with key?</p>	LSC-2012, §9.4.6.2 ASTM A17.1	LS.02.01.50-EP 12
<p>♦ Door opens/close properly with switch?</p>	ASTM A17.1	LS.02.01.50-EP 12
<p>♦ Test Phone Operation?</p>	ASTM A17.1	LS.02.01.50-EP 12



**TOOLS for REVIEW of**

# Inspection Documentation

1. REALITIES of Document Review
2. Document Review Concepts
3. The Report Tool Box
4. **Evaluate The Big 5 Doc Forms**



## The TOP FOUR INSPECTIONS

CITED BY TJC & CMS →

### “UP & COMING”

#### BUILDING

##### A-Fire Doors

S-Fire Dept Inspection  
D-Flame Spread Doc  
M-Elevator Recall

#### SUPPRESSION

M-Sprinkler

##### Q-Sprinkler

S-Sprinkler

##### A-Sprinkler

3-Sprinkler

5-Sprinkler

W-Standpipe

Q-Standpipe

A-Standpipe

3-Standpipe

5-Standpipe

#### ELECTRICAL

W-Generator

##### M-Generator

A-Generator

A-Load Bank

3-Load Bank

A-Diesel Fuel

A-Natural Gas

A-Transfer Switch

S-Emergency Breakers

A-Emergency Breakers

#### FIRE ALARM

M-Fire Alarm

Q-Fire Alarm

S-Fire Alarm

##### A-Fire Alarm

2-Smoke Detector

# Did you DOWNLOAD ?

[illegible][illegible][illegible][illegible][illegible][illegible]

cockatoo	hawk	meadowlark	pigeon	turkey
crane	hen	moa	plover	vulture
crow	hummingbird	mockingbird	puffin	xenops
dodo	ibis	mynah	quail	wings
dove	kakapo	nandu	quetzal	woodpecker

R	E	N	A	R	C	D	R	I	B	G	N	I	M	M	U	H
O	Q	U	E	T	Z	A	L	P	U	F	F	I	N	E	O	H
A	U	C	A	N	A	R	Y	R	A	W	O	S	S	A	C	A
D																G
R																G
U																O
N																L
N																D
E																F
R																I
A																N
S																C
O																H
G																V
N																B
I																B
M	W	D	U	O	R	I	O	L	E	L	Q	J	U	N	C	O
A	A	I	T	N	K	P	L	O	V	E	R	G	V	R	B	B
L	N	H	T	E	E	K	A	R	A	P	N	I	B	O	R	R
F	X	F	K	X	Y	R	E	T	P	O	E	A	H	C	R	A

An Evaluation is  
Basically a  
**“Code” WORD FIND**  
Puzzle

# Best to Use Forms that are Based On the CODE

1. Use forms that “Quote” the Code
2. Ensure forms are completely filled in
3. Make repairs ASAP

**1 + 2 + 3 = Compliance**



**TOOLS for REVIEW of**

# Inspection Documentation

## 1. FIRE DOORS

Refer to Feb 2018 Lunch & Learn on Fire Door Inspection  
For more detail

# TWO PARTS OF THE REVIEW

## Fire Door Document Review

LLSC INSPECTION REPORT EVALUATION TOOL

5 Most Cited Inspections

Page 1 of 9

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)				
NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010	TJC STD
Report Title:		Date of Report:		
		(1) Report contains (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) Specific CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency		
		(2) Fire doors inspected & tested at least annually;	\$5.2.1	LS.02.01.20 EP 32
		(A) with written & signed record of inspection		
		(B) Testing performed by individuals with knowledge & understanding of the operating components of the door being inspected	\$5.2.3.1	LS.02.01.20 EP 32
		(3) Test Automatic Closing doors to verify the assembly will close under fire conditions.	\$5.2.6	EC.02.03.05 EP 20
		(4) Visual inspection	\$5.2.3.1	LS.02.01.20 EP 32
		(A) performed (prior to testing) from both sides to assess overall condition of door assembly	5.2.4.1	
		(B) No holes or breaks exist in surfaces of either door or frame	\$5.2.4.2(1)	LS.02.01.20 EP 32
		(C) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.	\$5.2.4.2(3)	LS.02.01.20 EP 32
		(D) No parts are missing or broken.	\$5.2.4.2(4)	LS.02.01.20 EP 32
		(E) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.	\$5.2.4.2(5)	LS.02.01.20 EP 32
		(F) The self-closing device is operational (active door completely closes when from the full open position)	\$5.2.4.2(6)	LS.02.01.20 EP 32
		(G) Latching hardware operates and secures the door when it is in the closed position.	\$5.2.4.2(8)	LS.02.01.20 EP 32
		(H) No field modifications to the door assembly have been performed that void the label.	\$5.2.4.2(10)	LS.02.01.20 EP 32
		(I) Hardware shall be examined, and inoperative hardware, parts, or other defects shall be replaced without delay.	\$5.2.9	LS.02.01.20 EP 32

These items are only inspected if present, but form should have space to indicate that item is not present, i.e. not applicable					
NOT APPLIC	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010	TJC STD
			(4) Visual inspection (continued)	\$5.2.4.2(11)	LS.02.01.20 EP 32
			(J) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.		
			(K) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.	\$5.2.4.2(2)	LS.02.01.20 EP 32
			(L) If a coordinator is installed, the inactive leaf closes before the active leaf	\$5.2.4.2(7)	LS.02.01.20 EP 32
			(M) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.	\$5.2.4.2(9)	LS.02.01.20 EP 32
			(5) Maintenance: Guides and bearings shall be kept well lubricated to facilitate operation	\$5.2.12.1	EC.02.03.05 EP 20
			(6) A written Performance Based program for inspection, testing and maintenance is an acceptable alternative to the above if acceptable to the AHJ and provides assurance that the door will perform its intended function under fire conditions	\$5.2.2.1	

### Part 1 - Basics

Inspect ALL rated doors for these items

4 BASIC CHECKPOINTS

### Part 2 – “Ifs”

Inspect these items IF you have them

3 SUPPLEMENTAL CHECKPOINTS



# Fire Door Document Review

## 1. BASICS

**ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM** (best if form "Quotes" the code)

	FORM	FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA 80-2010	TJC STD
Report Title:				Date of Report:	
			(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2). Fire doors inspected & tested at least annually;	§5.2.1	LS.02.01.20 EP 3
			(A) with written & signed record of inspection		
			(B) Testing performed by Individuals with knowledge & understanding of the	§5.2.3.1	LS.02.01.20 EP 3
			<div> <h3><u>ALL CHECKPOINTS ON FORM</u></h3> <h2>Quote the Code</h2> </div>		
			(F) The self-closing device is operational (active door completely closes when from the full open position)	§5.2.4.2(6)	LS.02.01.20 EP 3
			(G) Latching hardware operates and secures the door when it is in the closed position.	§5.2.4.2(8)	LS.02.01.20 EP 3
			(H) No field modifications to the door assembly have been performed that void the label.	§5.2.4.2(10)	LS.02.01.20 EP 3
			(I) Hardware shall be examined, and inoperative hardware, parts, or other defects shall be replaced without delay.	§5.2.9	LS.02.01.20 EP 3

# 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)									
	NOT ON FORM	ON FORM	1. FIRE DOOR,SWINGING ANNUAL						
Report Title:			NFPA CODE NFPA 80-2010  TJC STD  Date of Report:						
			(1). Report contains (A) WHO did inspection; (B) WHEN performed; (C) Itemize LIST of devices; (D) Specific CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency						
			<div>CODE REFERENCES</div> <div>Show where requirement comes from</div>						

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010	TIC STD
Report Title:					Date of Report:
			(1). Report contains (A) <u>WHO</u> did inspection, (B) <u>WHEN</u> performed, (C) itemized <u>LIST</u> of devices, (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2). Fire doors inspected & tested at least annually;	§5.2.1	LS.02.01.20 EP 3
			(3) cor	§5.2.3.1	LS.02.01.20 EP 3
			(4) doc	§5.2.6	EC.02.03.05 EP 2
			(5) s	§5.2.3.1 5.2.4.1	LS.02.01.20 EP 3
			(6) p	§5.2.4.2(1)	LS.02.01.20 EP 3
			(7) t	§5.2.4.2(3)	LS.02.01.20 EP 3
			(8) d	§5.2.4.2(4)	LS.02.01.20 EP 3
			(9) a	§5.2.4.2(5)	LS.02.01.20 EP 3
			(10) b	§5.2.4.2(6)	LS.02.01.20 EP 3
			(11) c	§5.2.4.2(8)	LS.02.01.20 EP 3
			(12) e	§5.2.4.2(10)	LS.02.01.20 EP 3
			(13) f	§5.2.9	LS.02.01.20 EP 3

**TITLE OF REPORT**  
(if reviewing a completed report)

Identify What YOU  
call this Report  
&  
Date of Report

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)					
	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010	TJC STD
Report Title					Date of Report:
			1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			2). Fire doors inspected (A) with written & (B) Testing performed on operating components		LS.02.01.20 EP 3
			3) Test Automatic conditions.		LS.02.01.20 EP 3
			4) Visual inspection (A) performed (p door assembly		EC.02.03.05 EP 2
			(B) No holes or b		LS.02.01.20 EP 3
			(C) The door, fra secured, aligned		LS.02.01.20 EP 3
			(D) No parts are		LS.02.01.20 EP 3
			(E) Door clearan		LS.02.01.20 EP 3
			(F) The self-clos from the full oper		LS.02.01.20 EP 3
			(G) Latching hard position.		LS.02.01.20 EP 3
			(H) No field mod the label.		LS.02.01.20 EP 3
			(I) Hardware shall be examined, and inoperative hardware, parts, or other defects shall be replaced without delay.	\$5.2.9	LS.02.01.20 EP 3

### YOUR EVALUATION

Mark how your form complies with the code for EACH code requirement

↑ ↑ Mark One Box for Each Check Point

# Fire Door Document Review

## 1. BASICS

## 4 BASIC CHECKPOINTS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)					
	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010	TJC STD
Report Title:				Date of Report:	
			(1). <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2). <u>Fire doors inspected &amp; tested</u> at least annually; (A) with written & signed record of inspection	\$5.2.1	LS.02.01.20 EP 3
			(B) Testing performed by Individuals with knowledge & understanding of the operating components of the door being inspected	\$5.2.3.1	LS.02.01.20 EP 3
			(3) <u>Test Automatic Closing</u> doors to verify the assembly will close under fire conditions.	\$5.2.6	EC.02.03.05 EP 2
			(4) <u>Visual inspection</u> (A) performed (prior to testing) from both sides to assess overall condition of door assembly	\$5.2.3.1 5.2.4.1	LS.02.01.20 EP 3
			(B) No holes or breaks exist in surfaces of either door or frame	\$5.2.4.2(1)	LS.02.01.20 EP 3
			(H) No field modifications to the door assembly have been performed that void the label.	\$5.2.4.2(10)	LS.02.01.20 EP 3
			(I) Hardware shall be examined, and inoperative hardware, parts, or other defects shall be replaced without delay.	\$5.2.9	LS.02.01.20 EP 3

## KEY DOCUMENT ELEMENTS

Who, When, List, Checkpoints, Results & Repairs are  
KEY elements of EVERY inspection document



# Fire Door Document Review

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the c

	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010
Report Title:				Date of Report:
			(1). <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
			(2). <u>Fire doors inspected &amp; tested</u> at least annually;	\$5.2.1
			(A) with written & signed record of inspection	
			(B) Testing performed by Individuals with knowledge & understanding of the operating components of the door being inspected	\$5.2.3.1
			(3) <u>Test Automatic Closing</u> doors to verify the assembly will close under fire conditions.	\$5.2.3
			(4) <u>Visual inspection</u>	\$5.2.3.1
			(A) performed (prior to testing) from both sides to assess overall condition of door assembly	5.2.4.1
			(B) No holes or breaks exist in surfaces of either door or frame	\$5.2.4.2(1)
			(C) The door frame, hinges, hardware, and noncombustible threshold are	\$5.2.4.2(3)
				2(4)
				2(5)
				2(6)
				2(8)
			(F) No field modifications to the door assembly have been performed that void the label.	\$5.2.4.2(10)
				\$5.2.4.2

### WHEN & WHO CRITERIA

- ANNUAL = max 365 days from previous inspection
- Do NOT be fooled by TJC position of +/- a month
- Testing can be done in-house

## Fire Door Document Review

## 1. BASICS

**ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM** (best if form "Quotes" the a

	NOT ON FORM	ON FORM	<u>1. FIRE DOOR,SWINGING ANNUAL</u>	NFPA CODE NFPA 80-2010
Report Title:				Date of Report:

		(1). <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
		(2). <u>Fire doors inspected &amp; tested</u> at least annually; (A) with written & signed record of inspection	§5.2.1
		(B) Testing performed by Individuals with knowledge & understanding of the operating components of the door being inspected	§5.2.3.1
		(3) <u>Test Automatic Closing</u> doors to verify the assembly will close under fire conditions.	§5.2.6

## **HOLD OPEN & DETECTOR TESTING**

- Test Release of Hold Open Devices by smoke detector (frequently done during annual FA inspection)
- If using FA Inspection to comply, make sure to doc and that it was performed within 365 days

- ## **HOLD OPEN & DETECTOR TESTING**
- Test Release of Hold Open Devices by smoke detector (frequently done during annual FA inspection)
  - If using FA Inspection to comply, make sure to doc and that it was performed within 365 days

	(H) No field modifications to the door assembly have been performed that void the label.	§5.2.4.2 (10)
--	--	---------------



# Fire Door Document Review

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the c

	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010
Report Title:				Date of Report:
			(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
			(2). Fire doors inspected & tested at least annually;	\$5.2.1
			(A) with written & signed record of inspection	
			(B) Testing performed by Individuals with knowledge & understanding of the operating components of the door being inspected	\$5.2.3.1
			(3) Test Automatic Closing doors to verify the assembly will close under fire conditions.	\$5.2.6
			(4) Visual inspection	\$5.2.3.1
			(A) performed (prior to testing) from both sides to assess overall condition of door assembly	5.2.4.1
			(B) No holes or breaks exist in surfaces of either door or frame	\$5.2.4.2(1)
			(C) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.	\$5.2.4.2(3)
				2(4)
				2(5)
				2(6)
				2(8)
			(H) No field modifications to the door assembly have been performed that void the label.	\$5.2.4.2(10)

### INSPECT BOTH SIDES & SURFACES

- Must show that Both sides of door were inspected
- Must show that door/frame surfaces are intact

# Fire Door Document Review

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the c

	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010
Report Title:				Date of Report:
			(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
			(2). Fire doors inspected & tested at least annually; (A) with written & signed record of inspection	§5.2.1
			<h3><u>PARTS SECURED &amp; WORKING</u></h3> <ul style="list-style-type: none"> <li>Check that all screws are in place &amp; tight</li> <li>Make sure all parts are in place</li> </ul>	
			door assembly	
			(B) No holes or breaks exist in surfaces of either door or frame	§5.2.4.2(1)
			(C) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.	§5.2.4.2(3)
			(D) No parts are missing or broken.	§5.2.4.2(4)
			(E) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.	§5.2.4.2(5)
			(F) The self-closing device is operational (active door completely closes when from the full open position)	§5.2.4.2(6)
			(G) Latching hardware operates and secures the door when it is in the closed position.	§5.2.4.2(8)
			(H) No field modifications to the door assembly have been performed that void the label.	§5.2.4.2(10)

# Fire Door Document Review

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the c

	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010
Report Title:				Date of Report:
			(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
			(2). Fire doors inspected & tested at least annually; (A) with written & signed record of inspection	§5.2.1
<div style="border: 2px solid black; padding: 10px; text-align: center;"> <h3><u>CLEARANCES</u></h3> <ul style="list-style-type: none"> <li>4.8.4 -- undercut &lt;3/4"</li> <li>6.3.1.7 -- Jamb, Header &amp; Meeting: 1/8" on wood; 3/16" on steel; measured on "pull" side</li> </ul> </div>				
			(C) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.	§5.2.4.2(3)
			(D) No parts are missing or broken	§5.2.4.2(4)
			(E) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.	§5.2.4.2(5)
			(F) The self-closing device is operational (active door completely closes when from the full open position)	§5.2.4.2(6)
			(G) Latching hardware operates and secures the door when it is in the closed position.	§5.2.4.2(8)
			(H) No field modifications to the door assembly have been performed that void the label.	§5.2.4.2(10)



# Fire Door Document Review

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the c

	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010
Report Title:				Date of Report:
			(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
			(2). Fire doors inspected & tested at least annually; (A) with written & signed record of inspection	§5.2.1
			<h3><u>CLOSE &amp; LATCH</u></h3> <ul style="list-style-type: none"> <li>Check that door fully closes &amp; latches when released</li> </ul>	
			door assembly	
			(B) No holes or breaks exist in surfaces of either door or frame	§5.2.4.2(1)
			(C) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.	§5.2.4.2(3)
			(D) No parts are missing or broken.	§5.2.4.2(4)
			(E) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.	§5.2.4.2(5)
			(F) The self-closing device is operational (active door completely closes when from the full open position)	§5.2.4.2(6)
			(G) Latching hardware operates and secures the door when it is in the closed position.	§5.2.4.2(8)
			(H) No field modifications to the door assembly have been performed that void the label.	§5.2.4.2(10)

# Fire Door Document Review

## 1. BASICS

ST MUST BE ON A VALID FORM (best if form "Quotes" the c

	NOT ON FORM	ON FORM	1. <u>FIRE DOOR, SWINGING ANNUAL</u>	NFPA CODE NFPA 80-2010
Report Title:				Date of Report:
			(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
			(2). Fire doors inspected & tested at least annually;	§5.2.1
			(A) with written & signed record of inspection	
			(B) Testing performed by Individuals with knowledge & understanding of the operating components of the door being inspected	§5.2.3.1
<div style="border: 2px solid black; padding: 10px; text-align: center;"> <h3><u>FIELD MODIFICATIONS</u></h3> <ul style="list-style-type: none"> <li>• Check that door, frame &amp; hardware have NOT been changed in the field from the way they were originally received from the manufacturer</li> <li>• Usually electric strikes, combo locks, extra screw holes, etc indicate field modifications</li> </ul> </div>				
			(G) Latching hardware operates and secures the door when it is in the closed position	§5.2.4.2(8)
			(H) No field modifications to the door assembly have been performed that void the label.	§5.2.4.2(10)
			(I) Hardware shall be examined, and inoperative hardware, parts, or other defects shall be replaced without delay.	§5.2.9

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the c

**1. BASICS**DOOR, SWINGING ANNUALNFPA CODE  
NFPA 80-2010Report  
Title:

Date of Report:

(1). Report contains (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency(2). Fire doors inspected & tested at least annually;  
(A) with written & signed record of inspection

§5.2.1

(B) Testing performed by Individuals with knowledge &amp; understanding of the operating components of the door being inspected

§5.2.3.1

(3) Test Automatic Closing doors to verify the assembly will close under fire conditions.

§5.2.6

**REPAIRS**

- Must make repairs ASAP
- "Without Delay" is subjective & AHJ determines

(D) No parts are missing or broken.

§5.2.4.2(4)

(E) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.

§5.2.4.2(5)

(F) The self-closing device is operational (active door completely closes when from the full open position)

§5.2.4.2(6)

(G) Latching hardware operates and secures the door when it is in the closed position.

§5.2.4.2(8)

(H) No field modifications to the door assembly have been performed that void the label

§5.2.4.2(10)

(I) Hardware shall be examined, and inoperative hardware, parts, or other defects shall be replaced without delay.

§5.2.9

## 2. “IFs”

### SUPPLEMENTAL CHECKPOINTS

The 2nd part of the inspection depends on what extra items are installed on the door/frame, such as

- Gaskets
- Kickplates
- Windows
- Coordinators
- Auxiliary Hardware

Best to have a place to check **“Not Applicable”** if not installed on a door. These items should never be left off the form, even if there are none in the building.



## 2. “IFs”

NOT APPLIC	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010
			<b>(4) Visual inspection (continued)</b> (J) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.	§5.2.4.2(11)
			(K) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.	§5.2.4.2(2)
			(L) If a coordinator is installed, the inactive leaf closes before the active leaf	§5.2.4.2(7)
			(M) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.	§5.2.4.2(9)
			<b>(5) Maintenance:</b> Guides and bearings shall be kept well lubricated to facilitate operation	§5.2.12.1
			<b>(6) A written Performance Based program</b> for inspection, testing and maintenance is an acceptable alternative to the above if acceptable to the AHJ and provides assurance that the door will perform its intended function under fire	§5.2.2.1

### IF DOOR HAS GASKETS or SEALS

- Healthcare doors DO NOT need to have gaskets or edge seals, but if you have them they must be inspected

The form should have a box to check if door does not have

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010
			<b>(4) Visual inspection (continued)</b> (J) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.	§5.2.4.2(11)
			(K) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.	§5.2.4.2(2)
			(L) If a coordinator is installed, the inactive leaf closes before the active leaf	§5.2.4.2(7)
			(M) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.	§5.2.4.2(9)
			<b>(5) Maintenance:</b> Guides and bearings shall be kept well lubricated to facilitate operation	§5.2.12.1
			<b>(6) A written Performance Based program</b> for inspection, testing and maintenance is an acceptable alternative to the above if acceptable to the AHJ and provides assurance that the door will perform its intended function under fire	§5.2.2.1

### IF DOORS HAVE WINDOWS

Fire doors DO NOT need to have windows, but if you have them they must be inspected. Cross-corridor Smoke Barrier doors must have windows.

The form should have a box to check if door does not have

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010
			<b>(4) Visual inspection (continued)</b> (J) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.	§5.2.4.2(11)
			(K) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.	§5.2.4.2(2)
			(L) If a coordinator is installed, the inactive leaf closes before the active leaf	§5.2.4.2(7)
			(M) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.	§5.2.4.2(9)
			<b>(5) Maintenance:</b> Guides and bearings shall be kept well lubricated to facilitate operation	§5.2.12.1
			<b>(6) A written Performance Based program</b> for inspection, testing and maintenance is an acceptable alternative to the above if acceptable to the AHJ and provides assurance that the door will perform its intended function under fire	§5.2.2.1

### IF DOORS HAVE COORDINATOR

Single fire doors DO NOT need to a coordinator, but single-swing pairs of doors do

The form should have a box to check if door does not have

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	<u>1. FIRE DOOR, SWINGING ANNUAL</u>	NFPA CODE NFPA 80-2010
			<b>(4) Visual inspection (continued)</b> (J) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.	§5.2.4.2(11)
			(K) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.	§5.2.4.2(2)
			(L) If a coordinator is installed, the inactive leaf closes before the active leaf	§5.2.4.2(7)
			(M) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.	§5.2.4.2(9)
			<b>(5) Maintenance:</b> Guides and bearings shall be kept well lubricated to facilitate operation	§5.2.12.1
			<b>(6) A written Performance Based program</b> for inspection, testing and maintenance is an acceptable alternative to the above if acceptable to the AHJ	§5.2.2.1

### IF DOORS HAVE AUXILIARY HARDWARE

Extra hardware is not mandatory, but if equipped, must not inhibit door operation.

Includes: kick plates, hold-opens, signs, etc.

The form should have a box to check if door does not have



## 2. “IFs”

NOT APPLIC	NOT ON FORM	ON FORM	1. FIRE DOOR, SWINGING ANNUAL	NFPA CODE NFPA 80-2010
			<b>(4) Visual inspection (continued)</b> (J) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.	§5.2.4.2(11)
			(K) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.	§5.2.4.2(2)
			(L) If a coordinator is installed, the inactive leaf closes before the active leaf	§5.2.4.2(7)
			(M) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame	§5.2.4.2(9)
			<b>(5) Maintenance:</b> Guides and bearings shall be kept well lubricated to facilitate operation	§5.2.12.1
			<b>(6) A written Performance Based program</b> for inspection, testing and maintenance is an acceptable alternative to the above if acceptable to the AHJ and provides assurance that the door will perform its intended function under fire	§5.2.2.1

### **IF DOORS HAVE GUIDES or BEARINGS**

Bearing hinges are not mandatory, but some doors have bearings that must be lubed

The form should have a box to check if door does not have

# Fire Door Document Review

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	<u>1. FIRE DOOR, SWINGING ANNUAL</u>	NFPA CODE NFPA 80-2010
			<b>(4) Visual inspection (continued)</b> (J) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.	§5.2.4.2(11)
			(K) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.	§5.2.4.2(2)
			(L) If a coordinator is installed, the inactive leaf closes before the active leaf	§5.2.4.2(7)
			(M) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.	§5.2.4.2(9)
			<b>(5) Maintenance:</b> Guides and bearings shall be kept well lubricated to facilitate operation	§5.2.12.1
			<b>(6) A written Performance Based program</b> for inspection, testing and maintenance is an acceptable alternative to the above if acceptable to the AHJ and provides assurance that the door will perform its intended function under fire conditions	§5.2.2.1

### IF MAINTENANCE IS PERFORMANCE BASED

Can use a Performance Based Program instead of these checkpoints, but must be approved by AHJ

The form should have a box to check if door does not have



**TOOLS for REVIEW of**

# **Inspection Documentation**

## **2. Quarterly SPRINKLER**

**QUARTERLY = 4 REPORTS**



# TWO PARTS OF THE REVIEW

## Qtrly Sprinkler Doc Review

LLSC INSPECTION REPORT EVALUATION TOOL

5 Most Cited Inspections

Page 2 of 9

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)				
NOT ON FORM	ON FORM	2. SPRINKLER, QUARTERLY	NFPA CODE NFPA 25-2011	TJC STD
Report Title:		Date of Report:		
(1) Report contains (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) Specific CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency				
		(2) Hydraulic Design Info Sign - (A) Securely Attached to riser with durable method	\$5.2.6	LS 02.01.35 EP 14
		(B) Is sign Legible	\$5.2.6	LS 02.01.35 EP 14
		(3) Fire Dept Connection (FDC) - (A) Are visible and accessible	\$13.7.1(1)	EC 02.03.05 EP 10
		(B) Couplings or swivels not damaged & rotate smoothly	\$13.7.1(2)	EC 02.03.05 EP 10
		(C) Plugs or caps are in place and undamaged	\$13.7.1(3)	EC 02.03.05 EP 10
		(D) Gaskets are in place and in good condition	\$13.7.1(4)	EC 02.03.05 EP 10
		(E) Identification signs are in place	\$13.7.1(5)	EC 02.03.05 EP 10
		(F) Check valve is not leaking	\$13.7.1(6)	EC 02.03.05 EP 10
		(G) Auto drain valve in place and operating	\$13.7.1(7)	EC 02.03.05 EP 10
		(H) Clapper(s) in place and operating properly	\$13.7.1(8)	EC 02.03.05 EP 10
		(I) If plugs or caps are not in place, the interior of the connection shall be inspected for obstructions & verified the clapper is operational over its full range.	\$13.7.2	EC 02.03.05 EP 10

### Part 1 - Basics

Inspect ALL rated sys for these items

3 BASIC CHECKPOINTS

These items are only inspected if present, but form should have space to indicate that item is not present, i.e. not applicable					
NOT APPLIC	NOT ON FORM	ON FORM	2. SPRINKLER, QUARTERLY	NFPA CODE NFPA 25-2011	TJC STD
			(4) Fire Alarm Supervisory Switches tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(i)(6)	EC 02.03.05 EP 01
			(5) Water Flow Alarm Bell - Visual Inspection for Physical Damage, Bird nests, etc	\$5.2.5	LS 02.01.35 EP 14
			(6) Mechanical Water Flow Alarm Bell - Test operation	\$5.3.3.1; \$13.2.6.1	LS 02.01.35 EP 14
			(7) Heat Tape (if any) - Inspected per Mfr instructions	\$5.2.7	LS 02.01.35 EP 14
			(8) Main Drain Test, for at least one downstream sys (if the sole water supply is through a backflow preventer or pressure reducing valve)	\$13.2.5.1	LS 02.01.35 EP 14
			(9) Dry/Preaction Valve - Test. Priming water level in supervised systems per manufacturer's instructions (High priming water levels can adversely affect the operation of supervisory air)	\$13.4.3.2.1; \$13.4.4.2.1	LS 02.01.35 EP 14
			(10) Dry/Preaction Low air pressure alarms (if any) - Test per mfr	\$13.4.3.2.13; \$13.4.4.2.6	EC 02.03.05 EP 01
			(11) Dry/Preaction Quick-Open Device (if provided) - Test	\$13.4.4.2.4	LS 02.01.35 EP 14
			(12) Pressure Reducing Valve (PRV) (if any) -	\$13.5.1.1(1)	LS 02.01.35 EP 14
			(A) In the open position		
			(B) Not leaking	\$13.5.1.1(2)	LS 02.01.35 EP 14
			(C) Maintains downstream pressures per design criteria	\$13.5.1.1(3)	LS 02.01.35 EP 14
			(D) In good condition, with handwheels installed and unbroken	\$13.5.1.1(4)	LS 02.01.35 EP 14

### Part 2 - "Ifs"

Inspect these items IF you have them

9 SUPPLIMENTAL CHECKPOINTS

## 1. BASICS

**ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM** (best if form "Quotes" the code)

### 2. SPRINKLER, QUARTERLY

NFPA CODE  
NFPA 25-2011

TJC STD

Report  
Title:

Date of Report:

(1). **Report contains** (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) Specific CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency

(2) **Hydraulic Design Info Sign** - (A) Securely Attached to riser with durable

§5.2.6

LS 02.01.35 EP 14

## ALL CHECKPOINTS ON FORM

Quote the Code

LS 02.01.35 EP 14

) EC.02.03.05 EP 10

) EC.02.03.05 EP 10

3) EC.02.03.05 EP 10

4) EC.02.03.05 EP 10

) EC.02.03.05 EP 10

) EC.02.03.05 EP 10

) EC.02.03.05 EP 10

(H) Clapper(s) in place and operating properly

§13.7.1(8)

EC.02.03.05 EP 10

(I) If plugs or caps are not in place, the interior of the connection shall be inspected for obstructions & verified the clapper is operational over its full range.

§13.7.2

EC.02.03.05 EP 10

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

### 2. SPRINKLER, QUARTERLY

NFPA CODE  
NFPA 25-2011

TJC STD

Report  
Title:

Date of Report:

(4) Report contains (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) Specific REPAIR of any deficiency

### CODE REFERENCES

Show where  
requirement  
comes from

with durable

§5.2.6

LS 02.01.35 EP 14

§5.2.6

LS 02.01.35 EP 14

le

§13.7.1(1)

EC.02.03.05 EP 10

§13.7.1(2)

EC.02.03.05 EP 10

§13.7.1(3)

EC.02.03.05 EP 10

§13.7.1(4)

EC.02.03.05 EP 10

§13.7.1(5)

EC.02.03.05 EP 10

§13.7.1(6)

EC.02.03.05 EP 10

§13.7.1(7)

EC.02.03.05 EP 10

§13.7.1(8)

EC.02.03.05 EP 10

§13.7.2

EC.02.03.05 EP 10

tion shall be

inspected for obstructions & verified the clapper is operational over its full range.

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

### 2. SPRINKLER, QUARTERLY

NFPA CODE  
NFPA 25-2011

Report  
Title:

Date of Report:

(1). Report contains (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) Specific CHECKPOINTS; (E) RESULTS of each checkpoint; (F) REPAIR of any deficiency

(2) H  
metho

(B)

(3) Fi

(B)

(C)

(D)

(E)

(F)

(G)

(H)

(I) I

insp

ran

### TITLE OF REPORT

(if reviewing a completed report)

Identify What YOU  
call this Report  
&  
Date of Report

§5.2.6

LS 02.01.35 EP 14

§5.2.6

LS 02.01.35 EP 14

§13.7.1(1)

EC.02.03.05 EP 10

§13.7.1(2)

EC.02.03.05 EP 10

§13.7.1(3)

EC.02.03.05 EP 10

§13.7.1(4)

EC.02.03.05 EP 10

§13.7.1(5)

EC.02.03.05 EP 10

§13.7.1(6)

EC.02.03.05 EP 10

§13.7.1(7)

EC.02.03.05 EP 10

§13.7.1(8)

EC.02.03.05 EP 10

§13.7.2

EC.02.03.05 EP 10

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)						
		<u>2. SPRINKLER, QUARTERLY</u>		NFPA CODE NFPA 25-2011	TJC STD	
Report Title:		<h3><u>YOUR EVALUATION</u></h3> <p>Mark how your form complies with the code for EACH code requirement</p>			Report:	
					devices; (D) Specific	
					5.2.6	LS 02.01.35 EP 14
					5.2.6	LS 02.01.35 EP 14
					7.1(1)	EC.02.03.05 EP 10
					7.1(2)	EC.02.03.05 EP 10
					7.1(3)	EC.02.03.05 EP 10
					7.1(4)	EC.02.03.05 EP 10
					7.1(5)	EC.02.03.05 EP 10
					7.1(6)	EC.02.03.05 EP 10
		7.1(7)	EC.02.03.05 EP 10			
		7.1(8)	EC.02.03.05 EP 10			
		8.7.2	EC.02.03.05 EP 10			

↑ ↑ Mark One Box for Each Check Point



## 1. BASICS

## 3 BASIC CHECKPOINTS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

	NOT ON FORM	ON FORM	2. <u>SPRINKLER, QUARTERLY</u>	NFPA CODE NFPA 25-2011	TJC STD
Report Title:				Date of Report:	
			(1). <b>Report contains</b> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2) <u>Hydraulic Design Info Sign</u> - (A) Securely Attached to riser with durable method	§5.2.6	LS 02.01.35 EP 14
			(B) Is sign Legible	§5.2.6	LS 02.01.35 EP 14
			(3) <b>Fire Dept Connection (FDC)</b> - (A) Are visible and accessible	§13.7.1(1)	EC.02.03.05 EP 10
			(B) Couplings or swivels not damaged & rotate smoothly	§13.7.1(2)	EC.02.03.05 EP 10
			(C) Plugs or caps are in place and undamaged	§13.7.1(3)	EC.02.03.05 EP 10
			(D) Gaskets are in place and in good condition	§13.7.1(4)	EC.02.03.05 EP 10
			(E) Identification signs are in place	§13.7.1(5)	EC.02.03.05 EP 10

## KEY DOCUMENT ELEMENTS

- Who, When, List, Checkpoints, Results & Repairs are KEY elements of EVERY inspection document
- Can be performed in-house

## 1. BASICS

### 2. SPRINKLER, QUARTERLY

NFPA CODE  
NFPA 25-2011

Report  
Title:

Date of Report:

(1). Report contains (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency

(2) Hydraulic Design Info Sign - (A) Securely Attached to riser with durable method

§5.2.6

(B) Is sign Legible

§5.2.6

(3) Fire Dept Connection (FDC) - (A) Are visible and accessible

§13.7.1(1)

(B) Couplings or swivels not damaged & rotate smoothly

§13.7.1(2)

(C) Plugs or caps are in place and undamaged

§13.7.1(3)

(D) Gaskets are in place and in good condition

§13.7.1(4)

(E) Identification signs are in place

§13.7.1(5)

(F) Check valve is not leaking

§13.7.1(6)

§13.7.1(7)

§13.7.1(8)

§13.7.2

## HYDRAULIC NAMEPLATE

- Design Nameplate must be posted on each riser if sys was hydraulically designed (most are)



## 1. BASICS

### 2. SPRINKLER, QUARTERLY

NFPA CODE  
NFPA 25-2011

Report  
Title:

Date of Report:

**(1). Report contains** (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency

**(2) Hydraulic Design Info Sign** - (A) Securely Attached to riser with durable method

§5.2.6

(B) Is sign Legible

§5.2.6

**(3) Fire Dept Connection (FDC)** - (A) Are visible and accessible

§13.7.1(1)

(B) Couplings or swivels not damaged & rotate smoothly

§13.7.1(2)

(C) Plugs or caps are in place and undamaged

§13.7.1(3)

(D) Gaskets are in place and in good condition

§13.7.1(4)

(E) Identification signs are in place

§13.7.1(5)

(F) Check valve is not leaking

§13.7.1(6)

(G) Auto drain valve in place and operating

§13.7.1(7)

(H) Clapper(s) in place and operating properly

§13.7.1(8)

(I) If plugs or caps are not in place, the interior of the connection shall be inspected for obstructions & verified the clapper is operational over its full range.

§13.7.2

## FIRE DEPARTMENT CONNECTION

- Outside FDC has many checkpoints
- Accessible means NOTHING is in the way

## 2. “IFs”

### 9 SUPPLIMENTAL CHECKPOINTS

The 2nd part of the inspection depends on what extra items are installed on the sprinkler sys, such as

- Supervisory Switches (not tamperers)
- Water Flow Bells (not flow switches)
- Heat Tape on pipes
- Back Flow Preventer
- Pressure Reducing Valve
- Dry Pipe System
- Preaction System

Best to have a place to check “Not Applicable” if not installed on the system. These items should never be left off the form, even if there are none in the building.

## 2. “IFs”

These items are only inspected if present, but form should have space to indicate that item is not present, i.e. not applicable

NOT APPLIC	NOT ON FORM	ON FORM	2. SPRINKLER, QUARTERLY	NFPA CODE NFPA 25-2011	TJC STD
			(4) Fire Alarm Supervisory Switches tested (Examples: Fire Pump trouble, running, phase re performed as part	NFPA 72-2010, Table 4.5(15)(I)(6)	EC.02.03.05 EP 01
			(5) Water Flow A etc	§5.2.5	LS 02.01.35 EP 14
			(6) Mechanical W	§5.3.3.1; §13.2.6.1	LS 02.01.35 EP 14
			(7) Heat Tape (if	§5.2.7	LS 02.01.35 EP 14
			(8) Main Drain Te through a backflo	§13.2.5.1	LS 02.01.35 EP 14
			(9) Dry/Preaction manufacturer's ins operation of supe	§3.4.3.2.1; §13.4.4.2.1	LS 02.01.35 EP 14
			(10) Dry/Preactio	§3.4.3.2.13; §13.4.4.2.6	EC.02.03.05 EP 01
			(11) Dry/Preactio	§13.4.4.2.4	LS 02.01.35 EP 14
			(12) Pressure Re (A) In the open	§3.5.1.1(1)	LS 02.01.35 EP 14
			(B) Not leaking	§3.5.1.1(2)	LS 02.01.35 EP 14
			(C) Maintains downstream pressures per design criteria	§13.5.1.1(3)	LS 02.01.35 EP 14
			(D) In good condition, with handwheels installed and unbroken	§13.5.1.1(4)	LS 02.01.35 EP 14

### YOUR EVALUATION

Mark how your form complies with the code for EACH code requirement

↑ ↑ ↑ Mark One Box for Each Check Point

NOTE: If marked Not Applicable, it should STILL be on the form (best with a NA check box)

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	2. <u>SPRINKLER, QUARTERLY</u>	NFPA CODE NFPA 25-2011
			(4) <u>Fire Alarm Supervisory Switches</u> tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(I)(6)
			(5) <u>Water Flow Alarm Bell</u> - visual inspection for Physical Damage, Bird nests, etc	§5.2.5
			(6) <u>Mechanical Water Flow Alarm Bell</u> - Test operation	§5.3.3.1;
<div> <p><b><u>IF SYS HAS SUPERVISORY SWITCHES</u></b></p> <p>Supervisory switches for water supply equipment (fire pumps, water tanks, ect) are optional, but if installed must be tested.</p> </div>				
			(11) <u>Dry/Preaction Quick-Open Device</u> (if provided) - Test	§13.4.4.2.6
			(12) <u>Pressure Reducing Valve (PRV)</u> (if any) -	§13.4.4.2.4
			(A) In the open position	§13.5.1.1(1)
			(B) Not leaking	§13.5.1.1(2)
			(C) Maintains downstream pressures per design criteria	§13.5.1.1(3)
			(D) In good condition, with handwheels installed and unbroken	§13.5.1.1(4)

The form should have a box to check if door does not have

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	2. <u>SPRINKLER, QUARTERLY</u>	NFPA CODE NFPA 25-2011
			(4) <u>Fire Alarm Supervisory Switches</u> tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(I)(6)
			(5) <u>Water Flow Alarm Bell</u> - Visual Inspection for Physical Damage, Bird nests, etc	§5.2.5
			(6) <u>Mechanical Water Flow Alarm Bell</u> - Test operation	§5.3.3.1; §13.2.6.1
			(7) <u>Heat Tape</u> (if any) - Inspected per Mfr instructions	§5.2.7
			(8) <u>Main Drain Test</u> , for at least one downstream sys (if the sole water supply is	§13.2.5.1
<div> <h3><u>IF SYS HAS WATER FLOW ALARM BELL</u></h3> <ul style="list-style-type: none"> <li>• Don't confuse with a water flow switch</li> <li>• These are optional in/outside bells used in the days before fire alarm notification was common</li> <li>• Must inspect &amp; test</li> </ul> </div>				
			(C) Maintains downstream pressures per design criteria	§13.5.1.1(3)
			(D) In good condition, with handwheels installed and unbroken	§13.5.1.1(4)

The form should have a box to check if door does not have



## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	2. <u>SPRINKLER, QUARTERLY</u>	NFPA CODE NFPA 25-2011
			(4) <u>Fire Alarm Supervisory Switches</u> tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(I)(6)
			(5) <u>Water Flow Alarm Bell</u> - Visual Inspection for Physical Damage, Bird nests, etc	§5.2.5
			(6) <u>Mechanical Water Flow Alarm Bell</u> - Test operation	§5.3.3.1; §13.2.5.1
			(7) <u>Heat Tape</u> (if any) - Inspected per Mfr instructions	§5.2.7
			(8) <u>Main Drain Test</u> , for at least one downstream sys (if the sole water supply is through a backflow preventer or pressure reducing valve)	§13.2.5.1
			(9) <u>Dry/Preaction Valve</u> - Test Priming water level in supervised systems per	§13.4.3.2.1; §13.4.3.2.2
			(A) In the open position	§13.5.1.1(1)
			(B) Not leaking	§13.5.1.1(2)
			(C) Maintains downstream pressures per design criteria	§13.5.1.1(3)
			(D) In good condition, with handwheels installed and unbroken	§13.5.1.1(4)

### IF BUILDING HAS HEAT TAPE ON PIPES

- Check heat tape that is sometimes used on pipes that tend to freeze

The form should have a box to check if door does not have



## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	2. <u>SPRINKLER, QUARTERLY</u>	NFPA CODE NFPA 25-2011
			(4) <u>Fire Alarm Supervisory Switches</u> tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(I)(6)
			(5) <u>Water Flow Alarm Bell</u> - Visual Inspection for Physical Damage, Bird nests, etc	§5.2.5
			(6) <u>Mechanical Water Flow Alarm Bell</u> - Test operation	§5.3.3.1; §13.2.6.1
			(7) <u>Heat Tape</u> (if any) - Inspected per Mfr instructions	§5.2.7
			(8) <u>Main Drain Test</u> , for at least one downstream sys (if the sole water supply is through a backflow preventer or pressure reducing valve)	§13.2.5.1
			(9) <u>Dry/Predrill Valve</u> - Test Priming water level in supervised systems per	§13.1.3.2.1, §13.1.4.2.1
				13; 6 4 1) 2) 3) 4)

### IF SYS HAS BFP or PRV

- Only applicable if water main has a Back Flow Preventor or Pressure Reducing Valve
- Main Drain Test on only 1 branch
- See annual for details to be recorded

The form should have a box to check if door does not have

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	2. <u>SPRINKLER, QUARTERLY</u>	NFPA CODE NFPA 25-2011
			(4) <u>Fire Alarm Supervisory Switches</u> tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(I)(6)
			(5) <u>Water Flow Alarm Bell</u> - Visual Inspection for Physical Damage, Bird nests,	§5.2.5
<b>IF HAVE DRY PIPE or PREACTION SYS</b> <ul style="list-style-type: none"> <li>4 Extra checkpoints if have a dry pipe or preaction sys</li> </ul>				
			(6) <u>Main Drain Test</u> , for at least one downstream sys (if the sole water supply is through a backflow preventer or pressure reducing valve)	
			(9) <u>Dry/Preaction Valve</u> - Test Priming water level in supervised systems per manufacturer's instructions (High priming water levels can adversely affect the operation of supervisory air)	§13.4.3.2.1; §13.4.4.2.1
			(10) <u>Dry/Preaction Low air pressure alarms</u> (if any) - Test per mfr	§13.4.3.2.13; §13.4.4.2.6
			(11) <u>Dry/Preaction Quick-Open Device</u> (if provided) - Test	§13.4.4.2.4
			(12) <u>Pressure Reducing Valve (PRV)</u> (if any) -	§13.5.1.1(1)
			(A) In the open position	§13.5.1.1(2)
			(B) Not leaking	§13.5.1.1(3)
			(C) Maintains downstream pressures per design criteria	§13.5.1.1(4)
			(D) In good condition, with handwheels installed and unbroken	§13.5.1.1(4)

The form should have a box to check if door does not have

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	2. <u>SPRINKLER, QUARTERLY</u>	NFPA CODE NFPA 25-2011
			(4) <u>Fire Alarm Supervisory Switches</u> tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(I)(6)
			(5) <u>Water Flow Alarm Bell</u> - Visual Inspection for Physical Damage, Bird nests,	§5.2.5
<b><u>IF HAVE DRY/PREACTION VALVE</u></b> <ul style="list-style-type: none"> <li>Use manufacturer's instructions</li> </ul>				
			(6) <u>Main Drain Test</u> , for at least one downstream sys (if the sole water supply is through a backflow preventer or pressure reducing valve)	
			(9) <u>Dry/Preaction Valve</u> - Test Priming water level in supervised systems per manufacturer's instructions (High priming water levels can adversely affect the operation of supervisory air)	§13.4.3.2.1; §13.4.4.2.1
			(10) <u>Dry/Preaction Low air pressure alarms</u> (if any) - Test per mtr	§13.4.3.2.13; §13.4.4.2.6
			(11) <u>Dry/Preaction Quick-Open Device</u> (if provided) - Test	§13.4.4.2.4
			(12) <u>Pressure Reducing Valve (PRV)</u> (if any) -	§13.5.1.1(1)
			(A) In the open position	
			(B) Not leaking	§13.5.1.1(2)
			(C) Maintains downstream pressures per design criteria	§13.5.1.1(3)
			(D) In good condition, with handwheels installed and unbroken	§13.5.1.1(4)

The form should have a box to check if door does not have

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	2. SPRINKLER, QUARTERLY	NFPA CODE NFPA 25-2011
			(4) <u>Fire Alarm Supervisory Switches</u> tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(I)(6)
			(5) <u>Water Flow Alarm Bell</u> - Visual Inspection for Physical Damage, Bird nests,	§5.2.5
<b><u>IF HAVE LOW AIR PRESSURE ALARM</u></b> <ul style="list-style-type: none"> <li>Use manufacturer's instructions</li> </ul>				
			(6) <u>Main Drain Test</u> , for at least one downstream sys (if the sole water supply is through a backflow preventer or pressure reducing valve)	§5.2.5
			(9) <u>Dry/Preaction Valve</u> - Test Priming water level in supervised systems per manufacturer's instructions (High priming water levels can adversely affect the operation of supervisory air)	§13.4.3.2.1; §13.4.4.2.1
			(10) <u>Dry/Preaction Low air pressure alarms</u> (if any) - Test per mfr	§13.4.3.2.13; §13.4.4.2.6
			(11) <u>Dry/Preaction Quick-Open Device</u> (if provided) - Test	§13.4.4.2.4
			(12) <u>Pressure Reducing Valve (PRV)</u> (if any) -	§13.5.1.1(1)
			(A) In the open position	
			(B) Not leaking	§13.5.1.1(2)
			(C) Maintains downstream pressures per design criteria	§13.5.1.1(3)
			(D) In good condition, with handwheels installed and unbroken	§13.5.1.1(4)

The form should have a box to check if door does not have



## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	2. <u>SPRINKLER, QUARTERLY</u>	NFPA CODE NFPA 25-2011
			(4) <u>Fire Alarm Supervisory Switches</u> tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(I)(6)
			(5) <u>Water Flow Alarm Bell</u> - Visual Inspection for Physical Damage, Bird nests,	§5.2.5
<b><u>IF HAVE QUICK-OPENING DEVICE</u></b> <ul style="list-style-type: none"> <li>Use manufacturer's instructions</li> </ul>				
			(6) <u>Main Drain Test</u> , for at least one downstream sys (if the sole water supply is through a backflow preventer or pressure reducing valve)	§13.4.3.2.1; §13.4.4.2.1
			(9) <u>Dry/Preaction Valve</u> - Test Priming water level in supervised systems per manufacturer's instructions (High priming water levels can adversely affect the operation of supervisory air)	§13.4.3.2.13; §13.4.4.2.4
			(10) <u>Dry/Preaction Low air pressure alarms</u> (if any) - Test per mfr	§13.5.1.1(1)
			(11) <u>Dry/Preaction Quick-Open Device</u> (if provided) - Test	§13.5.1.1(2)
			(12) <u>Pressure Reducing Valve (PRV)</u> (if any) -	§13.5.1.1(3)
			(A) In the open position	§13.5.1.1(4)
			(B) Not leaking	§13.5.1.1(2)
			(C) Maintains downstream pressures per design criteria	§13.5.1.1(3)
			(D) In good condition, with handwheels installed and unbroken	§13.5.1.1(4)

The form should have a box to check if door does not have

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	2. <u>SPRINKLER, QUARTERLY</u>	NFPA CODE NFPA 25-2011
			(4) <u>Fire Alarm Supervisory Switches</u> tested (Examples: Fire Pump trouble, running, phase reversal, power; low water level on tank, etc (Note: These may be performed as part of the fire alarm testing sys)	NFPA 72-2010, Table 14.4.5(15)(1)(6)
			(5) <u>Water Flow Alarm Bell</u> - Visual Inspection for Physical Damage, Bird nests,	§5.2.5
<b><u>IF HAVE PRESSURE REDUCING VALVE</u></b> <ul style="list-style-type: none"> <li>4 Checkpoints</li> </ul>				
			(8) <u>Main Drain Test</u> , for at least one downstream sys (if the sole water supply is through a backflow preventer or pressure reducing valve)	§13.4.3.2.1; §13.4.4.2.1
			(9) <u>Dry/Preaction Valve</u> - Test Priming water level in supervised systems per manufacturer's instructions (High priming water levels can adversely affect the operation of supervisory air)	§13.4.3.2.1; §13.4.4.2.1
			(10) <u>Dry/Preaction Low air pressure alarms</u> (if any) - Test per mfr	§13.4.3.2.13; §13.4.4.2.6
			(11) <u>Dry/Preaction Quick Open Device</u> (if provided) - Test	§13.4.4.2.4
			(12) <u>Pressure Reducing Valve (PRV)</u> (if any) -	§13.5.1.1(1)
			(A) In the open position	§13.5.1.1(2)
			(B) Not leaking	§13.5.1.1(3)
			(C) Maintains downstream pressures per design criteria	§13.5.1.1(4)
			(D) In good condition, with handwheels installed and unbroken	§13.5.1.1(4)

The form should have a box to check if door does not have





**TOOLS for REVIEW of**

# Inspection Documentation

## 3. Annual SPRINKLER

- MORE Checkpoints than Quarterly
- If Annual & Quarterly done together, Form must include Separate Checkpoints for each

# TWO PARTS OF THE REVIEW

## Annual Sprinkler Doc Review

LLSC INSPECTION REPORT EVALUATION TOOL 5 Most Cited Inspections Page 3 of 9

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)				
NOT ON FORM	ON FORM	3. SPRINKLER- ANNUAL	NFPA CODE NFPA 25-2011	TJC STD
Report Title:		Date of Report:		
(1) Report contains (A) WHO did inspection, (B) WHEN performed, (C) Itemized LIST of devices, (D) Specific CHECKPOINTS (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency				
		(2) Sprinklers, visible - (A) Checked for signs of leakage	\$5.2.1.1	LS 02.01.35 EP 14
		(B) Foreign Mtl (dust or any other material)	\$5.2.1.1	LS 02.01.35 EP 14
		(C) Paint (any amount, if not placed by head mfr)	\$5.2.1.1	LS 02.01.35 EP 14
		(D) Corrosion (any amount)	\$5.2.1.1	LS 02.01.35 EP 14
		(E) Physical Damage	\$5.2.1.1	LS 02.01.35 EP 14
		(F) Deflector Orientation (generally required to be parallel to the ceiling)	\$5.2.1.1	LS 02.01.35 EP 14
		(3) Sprinkler Obstruction - (A) Min clearance provided below	\$5.2.1.2	LS 02.01.35 EP 14
		(4) Pipe, visible - (A) Checked for Leaks	\$5.2.2	LS 02.01.35 EP 14
		(B) Corrosion	\$5.2.2	LS 02.01.35 EP 14
		(C) External loads either resting on the pipe or hung from the pipe	\$5.2.2.2	LS 02.01.35 EP 14
		(D) Good Condition	\$5.2.2	LS 02.01.35 EP 14
		(E) Mechanical Damage	\$5.2.2	LS 02.01.35 EP 14
		(5) Hangers, visible - (A) Checked for Damage	\$5.2.3.1	LS 02.01.35 EP 14
		(B) Looseness	\$5.2.3.1	LS 02.01.35 EP 14
		(6) Hydraulic Design Info Sign - (A) Attached to riser with durable method	\$5.2.8	LS 02.01.35 EP 14
		(B) Is sign Legible	\$5.2.8	LS 02.01.35 EP 14
		(7) Spares - (A) Checked for Min 2 for each style, deflector type, response time, temp range, orifice size, coating (if any) Must have the same sprinkler identification numbers (SINs)	\$ 5.2.1.4; \$5.4.1.1	LS 02.01.35 EP 14
		(B) Additional spares are required as follows: (1) Min 12 for facilities having 300	\$5.4.1.5	LS 02.01.35 EP 14

## Part 1 - Basics

Inspect ALL rated sys for these items

7 BASIC CHECKPOINTS

LLSC INSPECTION REPORT EVALUATION TOOL 5 Most Cited Inspections Page 4 of 9

These items are only inspected if present, but form should have space to indicate that item is not present, i.e. not applicable					
NOT APPLIC	NOT ON FORM	ON FORM	3. SPRINKLER- ANNUAL	NFPA CODE NFPA 25-2011	TJC STD
			(10) System PRV (if any)	\$13.5.1.3	LS 02.01.35 EP 14
			(A) Partial-Flow Test (to move valve from its seat)		
			(11) Backflow Assemblies, (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)	\$13.6.2.1; \$13.6.2.1.4	LS 02.01.35 EP 14
			Forward-Flow Test includes - (B) hose stream demand, where hydrants or inside hose stations are located downstream of the backflow preventer	\$13.6.2.1	LS 02.01.35 EP 14
			(12) Bldg - prior to winter - (A) Ck for Freeze Protection	\$4.1.1.1	LS 02.01.35 EP 14
			(13) Anti-Freeze Sys - (A) Recorded Specific Gravity	\$5.3.4	LS 02.01.35 EP 14
			(B) Checked readings to code tables	\$5.3.4.1	LS 02.01.35 EP 14
			(14) Dry/Preaction Ice Obstruction Inspection - (A) Internal inspection of piping (Re: pipes that protect or passes through freezers or cold storage rooms for ice obstructions where the piping enters the refrigerated area)	\$14.4	LS 02.01.35 EP 14
			(15) Dry/Preaction Enclosure - (A) Low Temperature Alarm for heating sys (if provided) test at start of heating season	\$13.4.3.1.2; \$13.4.3.2.14	LS 02.01.35 EP 14
			(B) Auxiliary Drains operated before onset of freezing conditions	\$13.4.3.3.3	LS 02.01.35 EP 14
			(16) Dry/Preaction Valve - (A) Partial-Flow Trip Test (In yrs that full flow test is not required), If there's a quick-opening device that controls flow to the device	\$13.4.3.2.4; \$13.4.4.2.2.3	LS 02.01.35 EP 14
			(B) Main drain valve is fully opened to clear foreign material from pipes	\$13.4.3.2.12	LS 02.01.35 EP 14
			(C) Sys air psi and supply water psi are recorded	\$13.4.3.2.12; \$13.4.4.2.2.3	LS 02.01.35 EP 14
			(D) Tripping Time - Recorded (Using a stop watch, records time that air psi valve trips)	\$13.4.3.2.12; \$13.4.4.2.2.3	LS 02.01.35 EP 14
			(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)	\$13.4.3.2.12; \$13.4.4.2.2.3	LS 02.01.35 EP 14
			(17) Dry/Preaction Valve - (A) Interior thoroughly cleaned	\$13.4.3.3.2; \$13.4.4.1.5	LS 02.01.35 EP 14
			(18) Dry/Preaction Low Air Pressure - (A) Test per mfr	\$13.4.3.2.4	LS 02.01.35 EP 14
			(19) Preaction Detectors - (A) Condition of Detection Devices	\$13.4.3.1.7	LS 02.01.35 EP 14
			(20) Preaction Valve Manual Operator - (A) Operate actuation device	\$13.4.3.2.9	LS 02.01.35 EP 14

## Part 2 - "Ifs"

Inspect these items IF you have them

11 SUPPLEMENTAL CHECKPOINTS

## 1. BASICS

**ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM** (best if form "Quotes" the code)

FORM	FORM	3. <u>SPRINKLER- ANNUAL</u>	NFPA 25-2011	TJC STD
Report Title:		Date of Report:		
		(1). <b>Report contains</b> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
		(2) <b>Sprinklers, visible</b> - (A) Checked for signs of leakage	\$5.2.1.1	LS 02.01.35 EP 14
		(B) Foreign Mtl (dust or any other material)	\$5.2.1.1	LS 02.01.35 EP 14
		(C) Paint (any amount, if not placed by head mfr)	\$5.2.1.1	LS 02.01.35 EP 14
		(D) Corrosion (any amount)	\$5.2.1.1	LS 02.01.35 EP 14
		(E) Physical Damage	\$5.2.1.1	LS 02.01.35 EP 14
				LS 02.01.35 EP 14
				LS 02.01.35 EP 14
				LS 02.01.35 EP 14
				LS 02.01.35 EP 14
				LS 02.01.35 EP 14
				LS 02.01.35 EP 14
				LS 02.01.35 EP 14
				LS 02.01.35 EP 14
				LS 02.01.35 EP 14
				LS 02.01.35 EP 14
		(B) Is sign Legible	\$5.2.8	LS 02.01.35 EP 14
		(7) <b>Spares</b> - (A) Checked for Min 2 for each style, deflector type, response time, temp range, orifice size, coating (if any) Must have the same sprinkler identification numbers (SINs)	\$ 5.2.1.4; \$5.4.1.1	LS 02.01.35 EP 14
		(B) Additional spares are required as follows: (1) Min 12 for facilities having 300 to 1000 sprinklers; (2) Min 24 for facilities having over 1000 sprinklers	\$5.4.1.5	LS 02.01.35 EP 14
		(C ) Wrench(s) nearby that fit all heads (Adjustable wrench not acceptable)	\$5.4.1.6	LS 02.01.35 EP 14
		(D) Spare Sprinkler List - New installations after July 2016 must post in cabinet a dated spare sprinkler list that includes the SIN, general description & quantity of each sprinkler to be in the cabinet	\$5.4.1.4.1	LS 02.01.35 EP 14
		(8) <b>Control Valves</b> - (A) Operate its full range & return to normal position	\$13.3.3.1	LS 02.01.35 EP 14
		If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on rod; then back off 1/4 turn to prevent jamming	\$13.3.3.2	LS 02.01.35 EP 14

**ALL CHECKPOINTS ON FORM**

Quote the Code

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

		NOT ON FORM	ON FORM	3. SPRINKLER- ANNUAL	NFPA CODE NFPA 25-2011	TJC STD
Report Title:					Date of Report:	
				(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	<u>LIST</u> of devices; (D) Specific	
				(2) <u>Sprinklers, visible</u> - (A) Checked for signs of leakage	\$5.2.1.1	LS 02.01.35 EP 14
				(B) Foreign MTL (dust or any other material)	\$5.2.1.1	LS 02.01.35 EP 14
					\$5.2.1.1	LS 02.01.35 EP 14
					\$5.2.1.1	LS 02.01.35 EP 14
					\$5.2.1.1	LS 02.01.35 EP 14
					\$5.2.1.1	LS 02.01.35 EP 14
					\$5.2.1.2	LS 02.01.35 EP 14
					\$5.2.2	LS 02.01.35 EP 14
					\$5.2.2	LS 02.01.35 EP 14
					\$5.2.2.2	LS 02.01.35 EP 14
					\$5.2.2	LS 02.01.35 EP 14
					\$5.2.2	LS 02.01.35 EP 14
					\$5.2.3.1	LS 02.01.35 EP 14
					\$5.2.3.1	LS 02.01.35 EP 14
					\$5.2.8	LS 02.01.35 EP 14
					\$5.2.8	LS 02.01.35 EP 14
					\$ 5.2.1.4; \$5.4.1.1	LS 02.01.35 EP 14
					\$5.4.1.5	LS 02.01.35 EP 14
					\$5.4.1.6	LS 02.01.35 EP 14
					\$5.4.1.4.1	LS 02.01.35 EP 14
					\$13.3.3.1	LS 02.01.35 EP 14
					\$13.3.3.2	LS 02.01.35 EP 14

## CODE REFERENCES

Show where  
requirement  
comes from



## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

NOT ON

ON

### 3. SPRINKLER- ANNUAL

NFPA CODE

EP 14

Report  
Title:

Date of Report:

(1) Report contains (A) WHO did inspection, (B) WHEN performed, (C) itemized LIST of devices, (D) Specific CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency

(2) Sprinklers, visible - (A) Checked for signs of leakage

§5.2.1.1

LS 02.01.35 EP 14

(B) Foreign Mtl (dust or any other material)

§5.2.1.1

LS 02.01.35 EP 14

(C) Paint (any amount, if not placed by head mfr)

§5.2.1.1

LS 02.01.35 EP 14

## TITLE OF REPORT

(if reviewing a completed report)

Identify What YOU  
call this Report  
&  
Date of Report

§5.2.1.1

LS 02.01.35 EP 14

§5.2.1.1

LS 02.01.35 EP 14

§5.2.1.1

LS 02.01.35 EP 14

§5.2.1.1

LS 02.01.35 EP 14

§5.2.1.2

LS 02.01.35 EP 14

§5.2.2

LS 02.01.35 EP 14

§5.2.2

LS 02.01.35 EP 14

§5.2.2.2

LS 02.01.35 EP 14

§5.2.2

LS 02.01.35 EP 14

§5.2.2

LS 02.01.35 EP 14

§5.2.2

LS 02.01.35 EP 14

§5.2.3.1

LS 02.01.35 EP 14

§5.2.3.1

LS 02.01.35 EP 14

§5.2.8

LS 02.01.35 EP 14

§5.2.8

LS 02.01.35 EP 14

§ 5.2.1.4;

LS 02.01.35 EP 14

§5.4.1.1

§5.4.1.5

LS 02.01.35 EP 14

§5.4.1.6

LS 02.01.35 EP 14

§5.4.1.4.1

LS 02.01.35 EP 14

of each sprinkler to be in the cabinet

(8) Control Valves - (A) Operate its full range & return to normal position

§13.3.3.1

LS 02.01.35 EP 14

If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on rod; then back off 1/4 turn to prevent jamming

§13.3.3.2

LS 02.01.35 EP 14

## 1. BASICS

ALL CHECKPOINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)			
<div> <div>NOT ON FORM</div> <div>ON FORM</div> </div>		3. <u>SPRINKLER- ANNUAL</u>	<div> <div>NFPA CODE NFPA 25-2011</div> <div>TJC STD</div> </div>
Report Title:		Date of Report:	
		1) Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
		2) <u>Sprinklers, visible</u> - (A) Checked for signs of leakage	§5.2.1.1 LS 02.01.35 EP 14
		(B) Foreign Mtl	LS 02.01.35 EP 14
		(C) Paint (any a	LS 02.01.35 EP 14
		(D) Corrosion (a	LS 02.01.35 EP 14
		(E) Physical Da	LS 02.01.35 EP 14
		(F) Deflector Or	LS 02.01.35 EP 14
		3) <u>Sprinkler Obs</u>	LS 02.01.35 EP 14
		4) <u>Pipe, visible</u> -	LS 02.01.35 EP 14
		(B) Corrosion	LS 02.01.35 EP 14
		(C) External loa	LS 02.01.35 EP 14
		(D) Good Condi	LS 02.01.35 EP 14
		(E) Mechanical	LS 02.01.35 EP 14
		5) <u>Hangers, visi</u>	LS 02.01.35 EP 14
		(B) Looseness	LS 02.01.35 EP 14
		6) <u>Hydraulic Des</u>	LS 02.01.35 EP 14
		(B) Is sign Legib	LS 02.01.35 EP 14
		7) <u>Spares</u> - (A) C	LS 02.01.35 EP 14
		temp range, orific	
		identification num	
		(B) Additional sp	LS 02.01.35 EP 14
		to 1000 sprinklers, (2) min 24 for facilities having over 1000 sprinklers	
		(C ) Wrench(s) nearby that fit all heads (Adjustable wrench not acceptable)	§5.4.1.6 LS 02.01.35 EP 14
		(D) Spare Sprinkler List - New installations after July 2016 must post in cabinet a dated spare sprinkler list that includes the SIN, general description & quantity of each sprinkler to be in the cabinet	§5.4.1.4.1 LS 02.01.35 EP 14
		8) <u>Control Valves</u> - (A) Operate its full range & return to normal position	§13.3.3.1 LS 02.01.35 EP 14
		If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on	§13.3.3.2 LS 02.01.35 EP 14

### YOUR EVALUATION

Mark how your form complies with the code for EACH code requirement

↑ ↑ Mark One Box for Each Check Point



## 1. BASICS

## 7 BASIC CHECKPOINTS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

	NOT ON FORM	ON FORM	3. <u>SPRINKLER- ANNUAL</u>	NFPA CODE NFPA 25-2011	TJC STD
Report Title:				Date of Report:	
			(1) <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2) <u>Sprinklers, visible</u> - (A) Checked for signs of leakage	\$5.2.1.1	LS 02.01.35 EP 14
			(B) Foreign Mtl (dust or any other material)	\$5.2.1.1	LS 02.01.35 EP 14
			(C) Paint (any amount, if not placed by head mfr)	\$5.2.1.1	LS 02.01.35 EP 14
			(D) Corrosion (any amount)	\$5.2.1.1	LS 02.01.35 EP 14

## KEY DOCUMENT ELEMENTS

Who, When, List, Checkpoints, Results & Repairs are  
KEY elements of EVERY inspection document

		(E) Mechanical Damage	\$5.2.2	LS 02.01.35 EP 14
		(5) <u>Hangers, visible</u> - (A) Checked for Damage	\$5.2.3.1	LS 02.01.35 EP 14
		(B) Looseness	\$5.2.3.1	LS 02.01.35 EP 14
		(6) <u>Hydraulic Design Info Sign</u> - (A) Attached to riser with durable method	\$5.2.8	LS 02.01.35 EP 14
		(B) Is sign Legible	\$5.2.8	LS 02.01.35 EP 14
		(7) <u>Spares</u> - (A) Checked for Min 2 for each style, deflector type, response time, temp range, orifice size, coating (if any) Must have the same sprinkler identification numbers (SINs)	\$ 5.2.1.4; \$5.4.1.1	LS 02.01.35 EP 14
		(B) Additional spares are required as follows: (1) Min 12 for facilities having 300 to 1000 sprinklers; (2) Min 24 for facilities having over 1000 sprinklers	\$5.4.1.5	LS 02.01.35 EP 14
		(C ) Wrench(s) nearby that fit all heads (Adjustable wrench not acceptable)	\$5.4.1.6	LS 02.01.35 EP 14
		(D) Spare Sprinkler List - New installations after July 2016 must post in cabinet a dated spare sprinkler list that includes the SIN, general description & quantity of each sprinkler to be in the cabinet	\$5.4.1.4.1	LS 02.01.35 EP 14
		(8) <u>Control Valves</u> - (A) Operate its full range & return to normal position	\$13.3.3.1	LS 02.01.35 EP 14
		If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on rod; then back off 1/4 turn to prevent jamming	\$13.3.3.2	LS 02.01.35 EP 14

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

	NOT ON FORM	ON FORM	3. <u>SPRINKLER- ANNUAL</u>	NFPA CODE NFPA 25-2011	TJC STD
Report Title:				Date of Report:	
			(1) <b>Report contains</b> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2) <b>Sprinklers, visible</b> - (A) Checked for signs of leakage	\$5.2.1.1	LS 02.01.35 EP 14
			(B) Foreign Mtl (dust or any other material)	\$5.2.1.1	LS 02.01.35 EP 14
			(C) Paint (any amount, if not placed by head mfr)	\$5.2.1.1	LS 02.01.35 EP 14
			(D) Corrosion (any amount)	\$5.2.1.1	LS 02.01.35 EP 14
			(E) Physical Damage	\$5.2.1.1	LS 02.01.35 EP 14
			(F) Deflector Orientation (generally required to be parallel to the ceiling)	\$5.2.1.1	LS 02.01.35 EP 14
			(3) <b>Sprinkler Obstruction</b> - (A) Min clearance provided below	\$5.2.1.2	LS 02.01.35 EP 14
			(4) <b>Pipe, visible</b> - (A) Checked for Leaks	\$5.2.2	LS 02.01.35 EP 14
			(B) Corrosion	\$5.2.2	LS 02.01.35 EP 14
			(C) External loads either resting on the pipe or hung from the pipe	\$5.2.2.2	LS 02.01.35 EP 14
			(D) Good Condition	\$5.2.2	LS 02.01.35 EP 14

## VISIBLE SPRINKLER INSPECTION

- Walk-around visual of all exposed sprinklers
- Look especially for dust on heads
- Use zero-tolerance
- If vender does not do it, perhaps owner should

		a dated spare sprinkler list that includes the SNV, general description & quantity of each sprinkler to be in the cabinet		
		(8) <b>Control Valves</b> - (A) Operate its full range & return to normal position	\$13.3.3.1	LS 02.01.35 EP 14
		If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on rod; then back off 1/4 turn to prevent jamming	\$13.3.3.2	LS 02.01.35 EP 14

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

	NOT ON FORM	ON FORM	3. <u>SPRINKLER- ANNUAL</u>	NFPA CODE NFPA 25-2011	TJC STD
Report Title:				Date of Report:	
			(1). <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2) <u>Sprinklers, visible</u> - (A) Checked for signs of leakage	\$5.2.1.1	LS 02.01.35 EP 14
			(B) Foreign Mtl (dust or any other material)	\$5.2.1.1	LS 02.01.35 EP 14
			(C) Paint (any amount, if not placed by head mfr)	\$5.2.1.1	LS 02.01.35 EP 14
			(D) Corrosion (any amount)	\$5.2.1.1	LS 02.01.35 EP 14
			(E) Physical Damage	\$5.2.1.1	LS 02.01.35 EP 14
			(F) Deflector Orientation (generally required to be parallel to the ceiling)	\$5.2.1.1	LS 02.01.35 EP 14
			(3) <u>Sprinkler Obstruction</u> - (A) Min clearance provided below	\$5.2.1.2	LS 02.01.35 EP 14
			(4) <u>Pipe, visible</u> - (A) Checked for Leaks	\$5.2.2	LS 02.01.35 EP 14
			(B) Corrosion	\$5.2.2	LS 02.01.35 EP 14
			(C) External loads either resting on the pipe or hung from the pipe	\$5.2.2.2	LS 02.01.35 EP 14
			(D) Good Condition	\$5.2.2	LS 02.01.35 EP 14

## SPRINKLER OBSTRUCTIONS

- Walk-around visual of all exposed sprinklers
- 18" clearance is general rule (but more complicated)
- If vender does not do it, perhaps owner should

		(C ) Wrench(s) nearby that fit all heads (Adjustable wrench not acceptable)	\$5.4.1.6	LS 02.01.35 EP 14
		(D) Spare Sprinkler List - New installations after July 2016 must post in cabinet a dated spare sprinkler list that includes the SIN, general description & quantity of each sprinkler to be in the cabinet	\$5.4.1.4.1	LS 02.01.35 EP 14
		(8) <u>Control Valves</u> - (A) Operate its full range & return to normal position	\$13.3.3.1	LS 02.01.35 EP 14
		If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on rod; then back off 1/4 turn to prevent jamming	\$13.3.3.2	LS 02.01.35 EP 14

## Obstruction of Object on Floor (NFPA 13, 8.6.5.2.2)

A

B

Horiz Dist to  
Obstruction

Min Distance  
Below Deflector

**<6" ..... 3"**

6-9" ..... 4"

9-12" ..... 6"


12-15" ..... 8"

15-18" ..... 9.5"

18-24" ..... 12.5"


24-30" ..... 15.5"

**>30" ..... 18"**



Remember These #

## Obstructions Hanging from Ceiling (NFPA 13, 8.6.5.1.2)



Remember These #

<u>A</u>	<u>B</u>
Distance to Obstruction	Max Distance Below Deflector
<b>&lt;12"</b>	<b>.....0"</b>
<b>12-18"</b>	<b>.....2.5"</b>
<b>18-24"</b>	<b>.....3.5"</b>
<b>24-30"</b>	<b>.....5.5"</b>
<b>30-36"</b>	<b>.....7.5"</b>
<b>36-42"</b>	<b>.....9.5"</b>
<b>42-48"</b>	<b>.....12"</b>
<b>48-54"</b>	<b>.....14"</b>
<b>54-60"</b>	<b>.....16.5"</b>
<b>&gt;60"</b>	<b>.....18"</b>



## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)					
	NOT ON FORM	ON FORM	3. <u>SPRINKLER- ANNUAL</u>	NFPA CODE NFPA 25-2011	TJC STD
Report Title:				Date of Report:	
			(1) <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2) <u>Sprinklers, visible</u> - (A) Checked for signs of leakage	\$5.2.1.1	LS 02.01.35 EP 14
			(B) Foreign Mtl (dust or any other material)	\$5.2.1.1	LS 02.01.35 EP 14
			(C) Paint (any amount, if not placed by head mfr)	\$5.2.1.1	LS 02.01.35 EP 14
			(D) Corrosion (any amount)	\$5.2.1.1	LS 02.01.35 EP 14
			(E) Physical Damage	\$5.2.1.1	LS 02.01.35 EP 14
			(F) Deflector Orientation (generally required to be parallel to the ceiling)	\$5.2.1.1	LS 02.01.35 EP 14
			(3) <u>Sprinkler Obstruction</u> - (A) Min clearance provided below	\$5.2.1.2	LS 02.01.35 EP 14
			(4) <u>Pipe, visible</u> - (A) Checked for Leaks	\$5.2.2	LS 02.01.35 EP 14
			(B) Corrosion	\$5.2.2	LS 02.01.35 EP 14
			(C) External loads either resting on the pipe or hung from the pipe	\$5.2.2.2	LS 02.01.35 EP 14
			(D) Good Condition	\$5.2.2	LS 02.01.35 EP 14
			(E) Mechanical Damage	\$5.2.2	LS 02.01.35 EP 14
			(5) <u>Hangers, visible</u> - (A) Checked for Damage	\$5.2.3.1	LS 02.01.35 EP 14
			(B) Looseness	\$5.2.3.1	LS 02.01.35 EP 14
			(6) <u>Hydraulic Design Info Sign</u> - (A) Attached to riser with durable method	\$5.2.8	LS 02.01.35 EP 14
			(B) Design Label	\$5.2.8	LS 02.01.35 EP 14

## VISIBLE PIPE & HANGER INSPECTION

- Walk-around visual of all exposed pipes & hangers
- Look especially in storage & mechanical rooms w/o ceilings
- Use zero tolerance for anything touching a sprinkler pipe



## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

	NOT ON FORM	ON FORM	3. <u>SPRINKLER- ANNUAL</u>	NFPA CODE NFPA 25-2011	TJC STD
Report Title:				Date of Report:	
			(1) <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2) <u>Sprinklers, visible</u> - (A) Checked for signs of leakage	\$5.2.1.1	LS 02.01.35 EP 14
			(B) Foreign Mtl (dust or any other material)	\$5.2.1.1	LS 02.01.35 EP 14
			(C) Paint (any amount, if not placed by head mfr)	\$5.2.1.1	LS 02.01.35 EP 14
			(D) Corrosion (any amount)	\$5.2.1.1	LS 02.01.35 EP 14
			(E) Physical Damage	\$5.2.1.1	LS 02.01.35 EP 14
			(F) Deflector Orientation (generally required to be parallel to the ceiling)	\$5.2.1.1	LS 02.01.35 EP 14
			(3) <u>Sprinkler Obstruction</u> - (A) Min clearance provided below	\$5.2.1.2	LS 02.01.35 EP 14
			(4) <u>Pipe, visible</u> - (A) Checked for Leaks	\$5.2.2	LS 02.01.35 EP 14
			(B) Corrosion	\$5.2.2	LS 02.01.35 EP 14
			(C) External loads either resting on the pipe or hung from the pipe	\$5.2.2.2	LS 02.01.35 EP 14
			(D) Good Condition	\$5.2.2	LS 02.01.35 EP 14
			(E) Mechanical Damage	\$5.2.2	LS 02.01.35 EP 14
			(5) <u>Hangers, visible</u> - (A) Checked for Damage	\$5.2.3.1	LS 02.01.35 EP 14
			(B) Looseness	\$5.2.3.1	LS 02.01.35 EP 14
			(6) <u>Hydraulic Design Info Sign</u> - (A) Attached to riser with durable method	\$5.2.8	LS 02.01.35 EP 14
			(B) Is sign Legible	\$5.2.8	LS 02.01.35 EP 14
			(7) <u>Spares</u> - (A) Checked for min 2 for each style, deflector type, response time, temp range, orifice size, coating (if any) Must have the same sprinkler	\$5.2.1.4, \$5.4.1.1	LS 02.01.35 EP 14

## HYDRAULIC NAMEPLATE

- Only thing that is duplicated from Qrtly inspection

			of each sprinkler to be in the cabinet		
			(8) <u>Control Valves</u> - (A) Operate its full range & return to normal position	\$13.3.3.1	LS 02.01.35 EP 14
			If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on rod; then back off 1/4 turn to prevent jamming	\$13.3.3.2	LS 02.01.35 EP 14

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM (best if form "Quotes" the code)

	NOT ON FORM	ON FORM	3. <u>SPRINKLER- ANNUAL</u>	NFPA CODE NFPA 25-2011	TJC STD
Report Title:				Date of Report:	
(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency					

## SPARE SPRINKLERS & WRENCH

- Must have 2 for each sprinkler configuration used in building
- Total # depends on size of building
- Must have non-adj wrench(s) that fits all spares
- New installs: must have list on SIN

		(B) Is sign Legible	\$5.2.8	LS 02.01.35 EP 14
		<b>(7) Spares</b> - (A) Checked for Min 2 for each style, deflector type, response time, temp range, orifice size, coating (if any) Must have the same sprinkler identification numbers (SINs)	\$ 5.2.1.4; \$5.4.1.1	LS 02.01.35 EP 14
		(B) Additional spares are required as follows: (1) Min 12 for facilities having 300 to 1000 sprinklers; (2) Min 24 for facilities having over 1000 sprinklers	\$5.4.1.5	LS 02.01.35 EP 14
		(C ) Wrench(s) nearby that fit all heads (Adjustable wrench not acceptable)	\$5.4.1.6	LS 02.01.35 EP 14
		(D) Spare Sprinkler List - New installations after July 2016 must post in cabinet a dated spare sprinkler list that includes the SIN, general description & quantity of each sprinkler to be in the cabinet	\$5.4.1.4.1	LS 02.01.35 EP 14
		<b>(8) Control Valves</b> - (A) Operate its full range & return to normal position	\$13.3.3.1	LS 02.01.35 EP 14
		If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on rod; then back off 1/4 turn to prevent jamming	\$13.3.3.2	LS 02.01.35 EP 14

## 1. BASICS

MUST BE ON A VALID FORM (best if form "Quotes" the code)

FORM	FORM	5. SPRINKLER- ANNUAL	NFPA CODE NFPA 25-2011	TJC STD
Report Title:			Date of Report:	
		(1) <b>Report contains</b> (A) <b>WHO</b> did inspection; (B) <b>WHEN</b> performed; (C) Itemized <b>LIST</b> of devices; (D) Specific <b>CHECKPOINTS</b> ; (E) <b>RESULTS</b> of each checkpoint & (F) Doc <b>REPAIR</b> of any deficiency		
		(2) <b>Sprinklers, visible</b> - (A) Checked for signs of leakage	\$5.2.1.1	LS 02.01.35 EP 14
		(B) Foreign Mtl (dust or any other material)	\$5.2.1.1	LS 02.01.35 EP 14
		(C) Paint (any amount, if not placed by head mfr)	\$5.2.1.1	LS 02.01.35 EP 14
		(D) Corrosion (any amount)	\$5.2.1.1	LS 02.01.35 EP 14
		(E) Physical Damage	\$5.2.1.1	LS 02.01.35 EP 14
		(F) Deflector Orientation (generally required to be parallel to the ceiling)	\$5.2.1.1	LS 02.01.35 EP 14
		(3) <b>Sprinkler Obstruction</b> - (A) Min clearance provided below	\$5.2.1.2	LS 02.01.35 EP 14
		(4) <b>Pipe, visible</b> - (A) Checked for Leaks	\$5.2.2	LS 02.01.35 EP 14
		(B) Corrosion	\$5.2.2	LS 02.01.35 EP 14
		(C) External loads either resting on the pipe or hung from the pipe	\$5.2.2.2	LS 02.01.35 EP 14
		(D) Good Condition	\$5.2.2	LS 02.01.35 EP 14
		(E) Mechanical Damage	\$5.2.2	LS 02.01.35 EP 14
		(5) <b>Hangers, visible</b> - (A) Checked for Damage	\$5.2.3.1	LS 02.01.35 EP 14
		(B) Looseness	\$5.2.3.1	LS 02.01.35 EP 14
		(6) <b>Hydraulic Design Info Sign</b> - (A) Attached to riser with durable method	\$5.2.8	LS 02.01.35 EP 14
		(B) Is sign Legible	\$5.2.8	LS 02.01.35 EP 14
		(7) <b>Spares</b> - (A) Checked for Min 2 for each style, deflector type, response time, temp range, orifice size, coating (if any) Must have the same sprinkler	\$ 5.2.1.4; \$5.4.1.1	LS 02.01.35 EP 14

## CONTROL VALVES

- Must operate each control valve full range of motion

		of each sprinkler to be in the cabinet		
		(8) <b>Control Valves</b> - (A) Operate its full range & return to normal position	\$13.3.3.1	LS 02.01.35 EP 14
		If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on rod; then back off 1/4 turn to prevent jamming	\$13.3.3.2	LS 02.01.35 EP 14
		(9) <b>Main Drain Test</b> , for EACH riser	\$13.2.5	EC.02.03.05 EP 09
		(A) Record Initial psi		
		(B) Record residual (flowing) psi	\$13.2.5	EC.02.03.05 EP 09
		(C) Record time to restore psi	\$13.2.5	EC.02.03.05 EP 09
		(D) Compared to previous Main Drain Test	\$13.2.5.2	EC.02.03.05 EP 09
		(E) Determine cause/correction if >10% psi below full flow psi from prior test	\$13.2.5.2	EC.02.03.05 EP 09



## 1. BASICS

		CHECKPOINTS: (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
		<b>(2) Sprinklers, visible</b> - (A) Checked for signs of leakage	§5.2.1.1	LS 02.01.35 EP 14
		(B) Foreign Mtl (dust or any other material)	§5.2.1.1	LS 02.01.35 EP 14
		(C) Paint (any amount, if not placed by head mfr)	§5.2.1.1	LS 02.01.35 EP 14
		(D) Corrosion (any amount)	§5.2.1.1	LS 02.01.35 EP 14
		(E) Physical Damage	§5.2.1.1	LS 02.01.35 EP 14
		(F) Deflector Orientation (generally required to be parallel to the ceiling)	§5.2.1.1	LS 02.01.35 EP 14
		<b>(3) Sprinkler Obstruction</b> - (A) Min clearance provided below	§5.2.1.2	LS 02.01.35 EP 14
		<b>(4) Pipe, visible</b> - (A) Checked for Leaks	§5.2.2	LS 02.01.35 EP 14
		(B) Corrosion	§5.2.2	LS 02.01.35 EP 14
		(C) External loads either resting on the pipe or hung from the pipe	§5.2.2.2	LS 02.01.35 EP 14
		(D) Good Condition	§5.2.2	LS 02.01.35 EP 14
		(E) Mechanical Damage	§5.2.2	LS 02.01.35 EP 14
		<b>(5) Hangers, visible</b> - (A) Checked for Damage	§5.2.3.1	LS 02.01.35 EP 14
		(B) Looseness	§5.2.3.1	LS 02.01.35 EP 14
		<b>(6) Hydraulic Design Info Sign</b> - (A) Attached to riser with durable method	§5.2.8	LS 02.01.35 EP 14
		(B) Is sign Legible	§5.2.8	LS 02.01.35 EP 14

## MAIN DRAIN TEST

- Main Drain Test on EACH riser
- Must record 3 specified readings
- Must review readings against prior test

		If a Post Indicator Valves (PIV)- Open until spring or torsion pressure is felt on rod; then back off 1/4 turn to prevent jamming	§13.3.3.2	LS 02.01.35 EP 14
		<b>(9) Main Drain Test</b> , for EACH riser	§13.2.5	EC.02.03.05 EP 09
		(A) Record Initial psi		
		(B) Record residual (flowing) psi	§13.2.5	EC.02.03.05 EP 09
		(C) Record time to restore psi	§13.2.5	EC.02.03.05 EP 09
		(D) Compared to previous Main Drain Test	§13.2.5.2	EC.02.03.05 EP 09
		(E) Determine cause/correction if >10% psi below full flow psi from prior test	§13.2.5.2	EC.02.03.05 EP 09

## 2. “IFs”

### 11 SUPPLEMENTAL CHECKPOINTS

The 2nd part of the inspection depends on what extra items are installed on the sprinkler sys, such as

- Back Flow Preventer
- Pressure Reducing Valve
- Freezing Conditions
- Dry Pipe System
- Preaction System

Best to have a place to check “Not Applicable” if not installed on the system. These items should never be left off the form, even if there are none in the building.

## 2. "IFs"

These items are only inspected if present, but form should have space to indicate that item is not present, i.e. not applicable			
NOT APPLIC	NOT ON FORM	ON FORM	
			<b>3. SPRINKLER- ANNUAL</b>
			<b>10) System PRV</b> (if any)
			(A) Partial-Flow Test (to move valve from its seat)
			<b>11) Backflow Assemblies</b> (if any) - (A) Conduct Forward-Flow Test at the
			designed flow rate (to move valve from its seat)
			Forward-Flow Test at the
			inside hose station
			<b>12) Bldg - prior</b>
			<b>13) Anti-Freeze</b>
			(B) Checked re
			<b>14) Dry/Preaction</b>
			Re: pipes that p
			obstructions whe
			<b>15) Dry/Preaction</b>
			provided) test at
			(B) Auxiliary Dr
			<b>16) Dry/Preaction</b>
			(not required), If t
			(B) Main drain
			(C) Sys air psi
			(D) Tripping Tri
			valve trips)
			(E) Trip Test Re
			conducting the
			<b>17) Dry/Preaction Valve</b> - (A) Interior thoroughly cleaned
			<b>18) Dry/Preaction Low Air Pressure</b> - (A) Test per mfr
			<b>19) Preaction Detectors</b> - (A) Condition of Detection Devices
			<b>20) Preaction Valve Manual Operator</b> - (A) Operate actuation device

### YOUR EVALUATION

Mark how your form complies with the code for EACH code requirement

↑ ↑ ↑ Mark One Box for Each Check Point

**NOTE:** If marked Not Applicable, it should STILL be on the form (best with a NA check box)



## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	3. SPRINKLER- ANNUAL	NFPA CODE
			(10) <u>System PRV</u> (if any) (A) Partial-Flow Test (to move valve from its seat)	§13.5.1.3
			(11) <u>Backflow Assemblies</u> (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)	§13.6.2.1; §13.6.2.1.4
<div style="border: 2px solid black; padding: 10px; text-align: center;"> <h3><u>IF HAVE A PRESSURE REDUCING VALVE</u></h3> <ul style="list-style-type: none"> <li>Sys rarely have a pressure reducing valve, but if any, they must be tested</li> </ul> </div>				
			(Re: pipes that protects or passes through freezers or cold storage rooms for ice obstructions where the piping enters the refrigerated area)	
			(15) <u>Dry/Preaction Enclosure</u> - (A) Low Temperature Alarm for heating sys (if provided) test at start of heating season	§13.4.3.1.2; §13.4.3.2.14
			(B) Auxiliary Drains operated before onset of freezing conditions	§13.4.3.3.3
			(16) <u>Dry/Preaction Valve</u> - (A) Partial-Flow Trip Test (In yrs that full flow test is not required), If there's a quick-opening device that controls flow to the device	§13.4.3.2.4; §13.4.4.2.2.3
			(B) Main drain valve is fully opened to clear foreign material from pipes	§13.4.3.2.12
			(C) Sys air psi and supply water psi are recorded	§13.4.3.2.12; §13.4.4.2.2.3
			(D) Tripping Time - Recorded (Using a stop watch, records time that air psi valve trips)	§13.4.3.2.12; §13.4.4.2.2.3
			(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)	§13.4.3.2.12; §13.4.4.2.2.3
			(17) <u>Dry/Preaction Valve</u> - (A) Interior thoroughly cleaned	§13.4.3.3.2; §13.4.4.1.5
			(18) <u>Dry/Preaction Low Air Pressure</u> - (A) Test per mfr	§13.4.3.2.4
			(19) <u>Preaction Detectors</u> - (A) Condition of Detection Devices	§13.4.3.1.7

2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	3. SPRINKLER- ANNUAL	NFPA CODE NFPA 25-2011
			(10) <u>System PRV</u> (if any) (A) Partial-Flow Test (to move valve from its seat)	§13.5.1.3
			(11) <u>Backflow Assemblies</u> (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)	§13.6.2.1; §13.6.2.1.4
			Forward-Flow Test includes - (B) hose stream demand, where hydrants or inside hose stations are located downstream of the backflow preventer	§13.6.2.1
			(12) <u>Bldg - prior to winter</u> - (A) CK for Freeze Protection	§4.1.1.1
			(13) <u>Anti-Freeze Sys</u> - (A) Recorded Specific Gravity	§5.3.4
<div> <p><b><u>IF HAVE BACKFLOW PREVENTOR</u></b></p> <ul style="list-style-type: none"> <li>Sys may have a BFP on incoming line when required by local utility</li> <li>Test required if BFP is bypassed during the annual fire pump flow test</li> </ul> </div>				
			(C) Sys air psi and supply water psi are recorded	§13.4.3.2.12; §13.4.4.2.2.3
			(D) Tripping Time - Recorded (Using a stop watch, records time that air psi valve trips)	§13.4.3.2.12; §13.4.4.2.2.3
			(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)	§13.4.3.2.12; §13.4.4.2.2.3
			(17) <u>Dry/Preaction Valve</u> - (A) Interior thoroughly cleaned	§13.4.3.3.2; §13.4.4.1.5
			(18) <u>Dry/Preaction Low Air Pressure</u> - (A) Test per mfr	§13.4.3.2.4
			(19) <u>Preaction Detectors</u> - (A) Condition of Detection Devices	§13.4.3.1.7

2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	3. SPRINKLER- ANNUAL	NFPA CODE NFPA 25-2011
			(10) <u>System PRV</u> (if any) (A) Partial-Flow Test (to move valve from its seat)	§13.5.1.3
			(11) <u>Backflow Assemblies</u> (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)	§13.6.2.1; §13.6.2.1.4
			Forward-Flow Test includes - (B) hose stream demand, where hydrants or inside hose stations are located downstream of the backflow preventer	§13.6.2.1
			(12) <u>Bldg - prior to winter</u> - (A) Ck for Freeze Protection	§4.1.1.1
			(13) <u>Anti-Freeze Sys</u> - (A) Recorded Specific Gravity	§5.3.4
			(B) Checked readings to code tables	§5.3.4.1
			(14) <u>Dry/Preaction Ice Obstruction Inspection</u> - (A) Internal inspection of piping (Re: pipes that protects or passes through freezers or cold storage rooms for ice obstructions where the piping enters the refrigerated area)	§14.4
			<div> <p><b><u>IF BLDG SUBJECT TO FREEZING</u></b></p> <ul style="list-style-type: none"> <li>Check freeze protection in portions of bldg subject to freezing</li> <li>Must due prior to freezing weather (may be challenged if annual is performed in other than late fall)</li> </ul> </div>	
			(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)	§13.4.3.2.1.2; §13.4.4.2.2.3
			(17) <u>Dry/Preaction Valve</u> - (A) Interior thoroughly cleaned	§13.4.3.3.2; §13.4.4.1.5
			(18) <u>Dry/Preaction Low Air Pressure</u> - (A) Test per mfr	§13.4.3.2.4
			(19) <u>Preaction Detectors</u> - (A) Condition of Detection Devices	§13.4.3.1.7



## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	3. SPRINKLER- ANNUAL	NFPA CODE NFPA 25-2011
			(10) <u>System PRV</u> (if any) (A) Partial-Flow Test (to move valve from its seat)	§13.5.1.3
			(11) <u>Backflow Assemblies</u> (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)	§13.6.2.1; §13.6.2.1.4
			Forward-Flow Test includes - (B) hose stream demand, where hydrants or inside hose stations are located downstream of the backflow preventer	§13.6.2.1
			(12) <u>Bldg - prior to winter</u> - (A) Ck for Freeze Protection	§4.1.1.1
			(13) <u>Anti-Freeze Sys</u> - (A) Recorded Specific Gravity	§5.3.4
			(B) Checked readings to code tables	§5.3.4.1
			(14) <u>Dry/Preaction Ice Obstruction Inspection</u> - (A) Internal inspection of piping (Re: pipes that protects or passes through freezers or cold storage rooms for ice obstructions where the piping enters the refrigerated area)	§14.4
			(C) Sys air psi and supply water psi are recorded	§13.4.3.2.12; §13.4.4.2.2.3
			(D) Tripping Time - Recorded (Using a stop watch, records time that air psi valve trips)	§13.4.3.2.12; §13.4.4.2.2.3
			(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)	§13.4.3.2.12; §13.4.4.2.2.3
			(17) <u>Dry/Preaction Valve</u> - (A) Interior thoroughly cleaned	§13.4.3.3.2; §13.4.4.1.5
			(18) <u>Dry/Preaction Low Air Pressure</u> - (A) Test per mfr	§13.4.3.2.4
			(19) <u>Preaction Detectors</u> - (A) Condition of Detection Devices	§13.4.3.1.7

### IF HAVE ANTI-FREEZE SYSTEM

- Must measure & record specific gravity & compare to required level

## 2. "IFs"

(A) Partial-Flow Test (to move valve from its seat)

**(11) Backflow Assemblies** (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)

§13.6.2.1;  
§13.6.2.1.4

### IF HAVE DRY or PREACTION SYSTEM

- 7 extra checkpoints

(B) Checked readings to code tables

§5.3.4.1

**(14) Dry/Preaction Ice Obstruction Inspection** - (A) Internal inspection of piping (Re: pipes that protects or passes through freezers or cold storage rooms for ice obstructions where the piping enters the refrigerated area)

§14.4

**(15) Dry/Preaction Enclosure** - (A) Low Temperature Alarm for heating sys (if provided) test at start of heating season

§13.4.3.1.2;  
§13.4.3.2.14

(B) Auxiliary Drains operated before onset of freezing conditions

§13.4.3.3.3

**(16) Dry/Preaction Valve** - (A) Partial-Flow Trip Test (In yrs that full flow test is not required), If there's a quick-opening device that controls flow to the device

§13.4.3.2.4;  
§13.4.4.2.2.3

(B) Main drain valve is fully opened to clear foreign material from pipes

§13.4.3.2.12

(C) Sys air psi and supply water psi are recorded

§13.4.3.2.12;  
§13.4.4.2.2.3

(D) Tripping Time - Recorded (Using a stop watch, records time that air psi valve trips)

§13.4.3.2.12;  
§13.4.4.2.2.3

(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)

§13.4.3.2.12;  
§13.4.4.2.2.3

**(17) Dry/Preaction Valve** - (A) Interior thoroughly cleaned

§13.4.3.3.2;  
§13.4.4.1.5

**(18) Dry/Preaction Low Air Pressure** - (A) Test per mfr

§13.4.3.2.4

**(19) Preaction Detectors** - (A) Condition of Detection Devices

§13.4.3.1.7

**(20) Preaction Valve Manual Operator** - (A) Operate actuation device

§13.4.3.2.9

## 2. "IFs"

(A) Partial-Flow Test (to move valve from its seat)

**(11) Backflow Assemblies** (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)

§13.6.2.1;  
§13.6.2.1.4

Forward-Flow Test includes: (B) hose stream demand where hydrants or

§13.6.2.1

### **IF HAVE SPRINKLERS IN FREEZERS**

- Internal pipe inspection of pipes for freezers

**(14) Dry/Preaction Ice Obstruction Inspection** - (A) Internal inspection of piping (Re: pipes that protects or passes through freezers or cold storage rooms for ice obstructions where the piping enters the refrigerated area)

§14.4

**(15) Dry/Preaction Enclosure** - (A) Low Temperature Alarm for heating sys (if provided) test at start of heating season

§13.4.3.1.2;  
§13.4.3.2.14

(B) Auxiliary Drains operated before onset of freezing conditions

§13.4.3.3.3

**(16) Dry/Preaction Valve** - (A) Partial-Flow Trip Test (In yrs that full flow test is not required), If there's a quick-opening device that controls flow to the device

§13.4.3.2.4;  
§13.4.4.2.2.3

(B) Main drain valve is fully opened to clear foreign material from pipes

§13.4.3.2.12

(C) Sys air psi and supply water psi are recorded

§13.4.3.2.12;  
§13.4.4.2.2.3

(D) Tripping Time - Recorded (Using a stop watch, records time that air psi valve trips)

§13.4.3.2.12;  
§13.4.4.2.2.3

(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)

§13.4.3.2.12;  
§13.4.4.2.2.3

**(17) Dry/Preaction Valve** - (A) Interior thoroughly cleaned

§13.4.3.3.2;  
§13.4.4.1.5

**(18) Dry/Preaction Low Air Pressure** - (A) Test per mfr

§13.4.3.2.4

**(19) Preaction Detectors** - (A) Condition of Detection Devices

§13.4.3.1.7

**(20) Preaction Valve Manual Operator** - (A) Operate actuation device

§13.4.3.2.9



## 2. "IFs"

### IF HAVE ENCLOSURE SUBJECT TO FREEZING

- Sometimes valves are located where it freezes
- Check low temp alarm & drain operation

(A) Partial-Flow Test (to move valve from its seat)

**(11) Backflow Assemblies** (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)

§13.6.2.1;  
§13.6.2.1.4

Forward-Flow Test includes: (B) hose stream demand where hydrants or

§13.6.2.1

obstructions where the piping enters the refrigerated area)

**(15) Dry/Preaction Enclosure** - (A) Low Temperature Alarm for heating sys (if provided) test at start of heating season

§13.4.3.1.2;  
§13.4.3.2.14

(B) Auxiliary Drains operated before onset of freezing conditions

§13.4.3.3.3

**(16) Dry/Preaction Valve** - (A) Partial-Flow Trip Test (In yrs that full flow test is not required), If there's a quick-opening device that controls flow to the device

§13.4.3.2.4;  
§13.4.4.2.2.3

(B) Main drain valve is fully opened to clear foreign material from pipes

§13.4.3.2.12

(C) Sys air psi and supply water psi are recorded

§13.4.3.2.12;  
§13.4.4.2.2.3

(D) Tripping Time - Recorded (Using a stop watch, records time that air psi valve trips)

§13.4.3.2.12;  
§13.4.4.2.2.3

(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)

§13.4.3.2.12;  
§13.4.4.2.2.3

**(17) Dry/Preaction Valve** - (A) Interior thoroughly cleaned

§13.4.3.3.2;  
§13.4.4.1.5

**(18) Dry/Preaction Low Air Pressure** - (A) Test per mfr

§13.4.3.2.4

**(19) Preaction Detectors** - (A) Condition of Detection Devices

§13.4.3.1.7

**(20) Preaction Valve Manual Operator** - (A) Operate actuation device

§13.4.3.2.9

## 2. "IFs"

		(A) Partial-Flow Test (to move valve from its seat)	
		<b>(11) Backflow Assemblies</b> (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)	§13.6.2.1; §13.6.2.1.4
		Forward-Flow Test includes - (B) hose stream demand, where hydrants or inside hose stations are located downstream of the backflow preventer	§13.6.2.1
		<b>(12) Bldg - prior to winter</b> - (A) Ck for Freeze Protection	§4.1.1.1
		<b>(13) Anti-Freeze Sys</b> - (A) Recorded Specific Gravity	§5.3.4

### **IF HAVE QUICK-OPENING DEVICE**

- Partial Flow Trip Test, with specific records

		<b>(15) Dry/Preaction Enclosure</b> - (A) Low Temperature Alarm for heating sys (if provided) test at start of heating season	§13.4.3.1.2; §13.4.3.2.14
		(B) Auxiliary Drains operated before onset of freezing conditions	§13.4.3.2.3
		<b>(16) Dry/Preaction Valve</b> - (A) Partial-Flow Trip Test (In yrs that full flow test is not required), If there's a quick-opening device that controls flow to the device	§13.4.3.2.4; §13.4.4.2.2.3
		(B) Main drain valve is fully opened to clear foreign material from pipes	§13.4.3.2.12
		(C) Sys air psi and supply water psi are recorded	§13.4.3.2.12; §13.4.4.2.2.3
		(D) Tripping Time - Recorded (Using a stop watch, records time that air psi valve trips)	§13.4.3.2.12; §13.4.4.2.2.3
		(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)	§13.4.3.2.12; §13.4.4.2.2.3
		<b>(17) Dry/Preaction Valve</b> - (A) Interior thoroughly cleaned	§13.4.3.3.2; §13.4.4.1.5
		<b>(18) Dry/Preaction Low Air Pressure</b> - (A) Test per mfr	§13.4.3.2.4
		<b>(19) Preaction Detectors</b> - (A) Condition of Detection Devices	§13.4.3.1.7
		<b>(20) Preaction Valve Manual Operator</b> - (A) Operate actuation device	§13.4.3.2.9

## 2. "IFs"

		(A) Partial-Flow Test (to move valve from its seat)	
		<b>(11) Backflow Assemblies</b> (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)	§13.6.2.1; §13.6.2.1.4
		Forward-Flow Test includes - (B) hose stream demand, where hydrants or inside hose stations are located downstream of the backflow preventer	§13.6.2.1
		<b>(12) Bldg - prior to winter</b> - (A) Ck for Freeze Protection	§4.1.1.1
		<b>(13) Anti-Freeze Sys</b> - (A) Recorded Specific Gravity	§5.3.4
		(B) Checked readings to code tables	§5.3.4.1
		<b>(14) Dry/Preaction Ice Obstruction Inspection</b> - (A) Internal inspection of piping (Re: pipes that protects or passes through freezers or cold storage rooms for ice obstructions where the piping enters the refrigerated area)	§14.4
		<b>(15) Dry/Preaction Enclosure</b> - (A) Low Temperature Alarm for heating sys (if provided) test at start of heating season	§13.4.3.1.2; §13.4.3.2.14
		(B) Auxiliary Drains operated before onset of freezing conditions	§13.4.3.3.3
		<b>(16) Dry/Preaction Valve</b> - (A) Partial-Flow Trip Test (In yrs that full flow test is not required), If there's a quick-opening device that controls flow to the device	§13.4.3.2.4; §13.4.4.2.2.3
<div> <h3><u>IF HAVE DRY/PREACTION VALVE</u></h3> <ul style="list-style-type: none"> <li>Clean interior of valve</li> </ul> </div>			
		(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)	§13.4.3.2.12; §13.4.4.2.2.3
		<b>(17) Dry/Preaction Valve</b> - (A) Interior thoroughly cleaned	§13.4.3.3.2; §13.4.4.1.5
		<b>(18) Dry/Preaction Low Air Pressure</b> - (A) Test per mfr	§13.4.3.2.4
		<b>(19) Preaction Detectors</b> - (A) Condition of Detection Devices	§13.4.3.1.7
		<b>(20) Preaction Valve Manual Operator</b> - (A) Operate actuation device	§13.4.3.2.9



## 2. "IFs"

		(A) Partial-Flow Test (to move valve from its seat)	
		<b>(11) Backflow Assemblies</b> (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)	§13.6.2.1; §13.6.2.1.4
		Forward-Flow Test includes - (B) hose stream demand, where hydrants or inside hose stations are located downstream of the backflow preventer	§13.6.2.1
		<b>(12) Bldg - prior to winter</b> - (A) Ck for Freeze Protection	§4.1.1.1
		<b>(13) Anti-Freeze Sys</b> - (A) Recorded Specific Gravity	§5.3.4
		(B) Checked readings to code tables	§5.3.4.1
		<b>(14) Dry/Preaction Ice Obstruction Inspection</b> - (A) Internal inspection of piping (Re: pipes that protects or passes through freezers or cold storage rooms for ice obstructions where the piping enters the refrigerated area)	§14.4
		<b>(15) Dry/Preaction Enclosure</b> - (A) Low Temperature Alarm for heating sys (if provided) test at start of heating season	§13.4.3.1.2; §13.4.3.2.14
		(B) Auxiliary Drains operated before onset of freezing conditions	§13.4.3.3.3
		<b>(16) Dry/Preaction Valve</b> - (A) Partial-Flow Trip Test (In yrs that full flow test is not required), If there's a quick-opening device that controls flow to the device	§13.4.3.2.4; §13.4.4.2.2.3
		(B) Main drain valve is fully opened to clear foreign material from pipes	§13.4.3.2.12
<b><u>IF LOW AIR PRESSURE ALARM</u></b>			
• Test per manufacturer			
		(E) Trip Test Records show date last tripped, individual & organization conducting the test (generally requires 2 persons)	§13.4.3.2.12; §13.4.4.2.2.3
		<b>(17) Dry/Preaction Valve</b> - (A) Interior thoroughly cleaned	§13.4.3.3.2; §13.4.4.2.5
		<b>(18) Dry/Preaction Low Air Pressure</b> - (A) Test per mfr	§13.4.3.2.4
		<b>(19) Preaction Detectors</b> - (A) Condition of Detection Devices	§13.4.3.1.7
		<b>(20) Preaction Valve Manual Operator</b> - (A) Operate actuation device	§13.4.3.2.9

## 2. "IFs"

		(A) Partial-Flow Test (to move valve from its seat)	
		<b>(11) Backflow Assemblies</b> (if any) - (A) Conduct Forward-Flow Test at the designed flow rate (Not required if annual fire pump test causes the system demand to flow through the backflow preventer device)	§13.6.2.1; §13.6.2.1.4
		Forward-Flow Test includes - (B) hose stream demand, where hydrants or inside hose stations are located downstream of the backflow preventer	§13.6.2.1
		<b>(12) Bldg - prior to winter</b> - (A) Ck for Freeze Protection	§4.1.1.1
		<b>(13) Anti-Freeze Sys</b> - (A) Recorded Specific Gravity	§5.3.4
		(B) Checked readings to code tables	§5.3.4.1
		<b>(14) Dry/Preaction Ice Obstruction Inspection</b> - (A) Internal inspection of piping (Re: pipes that protects or passes through freezers or cold storage rooms for ice obstructions where the piping enters the refrigerated area)	§14.4
		<b>(15) Dry/Preaction Enclosure</b> - (A) Low Temperature Alarm for heating sys (if provided) test at start of heating season	§13.4.3.1.2; §13.4.3.2.14
		(B) Auxiliary Drains operated before onset of freezing conditions	§13.4.3.3.3
		<b>(16) Dry/Preaction Valve</b> - (A) Partial-Flow Trip Test (In yrs that full flow test is not required), If there's a quick-opening device that controls flow to the device	§13.4.3.2.4; §13.4.4.2.2.3
		(B) Main drain valve is fully opened to clear foreign material from pipes	§13.4.3.2.12
<div> <h3><u>IF HAVE PREACTION SYS</u></h3> <ul style="list-style-type: none"> <li>• Check condition of smoke detectors</li> <li>• Operate Preaction manual operator</li> </ul> </div>			
		<b>(17) Dry/Preaction Valve</b> - (A) Interior thoroughly cleaned	§13.4.3.3.2; §13.4.4.1.5
		<b>(18) Dry/Preaction Low Air Pressure</b> - (A) Test per mfr	§13.4.3.2.4
		<b>(19) Preaction Detectors</b> - (A) Condition of Detection Devices	§13.4.3.1.7
		<b>(20) Preaction Valve Manual Operator</b> - (A) Operate actuation device	§13.4.3.2.9





**TOOLS for REVIEW of**

# Inspection Documentation

## 4. Monthly Generator

# ONE PART OF THE REVIEW

## Mo. Generator Doc Review

### Part 1 - Basics

Inspect ALL rated sys  
for these items

7 BASIC CHECKPOINTS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM

NOT ON FORM	ON FORM	5. GENERATOR EXERCISE - MONTHLY	NFPA CODE NFPA 110-2010	
Report Title:		Date of Report:		
		(1) <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
		(2) <u>Properly instructed individuals</u> must oversee the routine maintenance and operational testing program	§8.4.8	LS.02.01.70 EP 04
		(3) <u>Test Interval</u> - minimum of 20 days; maximum of 40 days; EPSSs, including all appurtenant components, shall be exercised under load at least monthly;	§8.4.1 NFPA 99-2012 §6.4.4.1.1.4A;	EC.02.05.07 EP 04
		(3) <u>Start-Up</u> (A) Load tests of generator sets shall include complete cold starts	§8.4.4	LS.02.01.70 EP 04
		(B) Initiated by simulating a power outage by either: (a) Using the test switch(es) on the ATSS, or (b) By opening a normal breaker	§8.3.2.1; §8.4.3	LS.02.01.70 EP 04
		The 10-second start criterion shall not apply during the monthly generator test; If the 10-second criterion is not met during the monthly test, an <u>annual test</u> must confirm the capability of the life safety & critical branches start within 10 sec	NFPA 99-2012, §6.4.4.1.1.2	LS.02.01.70 EP 04
		(4) <u>Duration</u> - must be exercised for at least 30 min under (A) <u>Diesel generator</u> . Use any of the following load criteria:	§8.4.2	EC.02.05.07 EP 04
		(a) Loading that maintains the minimum exhaust gas temperatures as recommended by the manufacturer, or (b) Under operating temperature conditions and at not less than 30% of the EPS nameplate kW rating, or (c) Annual Load Bank (see separate test document) and exercised monthly under the available load	§8.4.2; §8.4.2.3	EC.02.05.07 EP 05
		(B) <u>Spark-ignited generator</u> (ie. Natural gas/propane) Use any of the following load criteria:	§8.4.2.4	EC.02.05.07 EP 04
		(a) Available EPSS Load or (b) Until the water temperature and the oil pressure have stabilized	§8.4.2.4	EC.02.05.07 EP 05
		(5) <u>Battery Electrolyte Condition</u> - Monthly. Must either a). measure & record spec gravity of each cell, or b). Perform battery conductance testing	§8.3.7.1	LS.02.01.70 EP 04
		(6) <u>Transfer Switch Test</u> - (A) Must operate every automatic and manual transfer switch each month. Transfer shall consist of electrically operating the transfer switch from the standard position to the alternate position and then a return to the standard position	§8.4.6; §8.3.2.1; §8.4.6.1	LS.02.01.70 EP 04
		(7) <u>Time-Delays</u> : (A) Must have a minium 1 second Time delay on start	§8.4.5(1)	LS.02.01.70 EP 04
		(B) Must have a minium 5 minute Time delay on shut-down (Cool-Down)	§8.4.5(4)	LS.02.01.70 EP 04

# 1. BASICS

## Mo. Generator Doc Review

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM

FORM		FORM		5. GENERATOR EXERCISE - MONTHLY	NFPA 110-2010	TJC STD	
Report Title:				Date of Report:			
		(1) <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency					
		(2) <u>Properly instructed individuals</u> must oversee the routine maintenance and operational testing program				§8.4.8	LS.02.01.70 EP 04
		(3) <u>Test Interval</u> - minimum of 20 days; maximum of 40 days; EPSSs, including all appurtenant components, shall be exercised under load at least monthly;				§8.4.1 NFPA 99-2012 §6.4.4.1.1.4A;	EC.02.05.07 EP 04
		(3) <u>Start-Up</u> : (A) Load tests of generator sets shall include complete cold starts				§8.4.4	LS.02.01.70 EP 04
<div style="border: 2px solid black; padding: 10px; text-align: center;"> <h3><u>ALL CHECKPOINTS ON FORM</u></h3> <h2>Quote the Code</h2> </div>						02.01.70 EP 04	
						02.01.70 EP 04	
						02.05.07 EP 04	
						02.05.07 EP 05	
		(b) Under operating temperature conditions and at not less than 30% of the EPS nameplate kW rating, or (c) Annual Load Bank (see separate test document) and exercised monthly under the available load					
		(B) <u>Spark-ignited generator</u> (ie. Natural gas/propane) Use any of the following load criteria:				§8.4.2.4	EC.02.05.07 EP 04
		(a) Available EPSS Load or				§8.4.2.4	EC.02.05.07 EP 05
		(b) Until the water temperature and the oil pressure have stabilized					
		(5) <u>Battery Electrolyte Condition</u> - Monthly, Must either a). measure & record spec gravity of each cell, or b). Perform battery conductance testing				§8.3.7.1	LS.02.01.70 EP 04

## 1. BASICS

## Mo. Generator Doc Review

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM

NOT ON FORM		ON FORM		5. GENERATOR EXERCISE - MONTHLY		NFPA CODE NFPA 110-2010		TJC STD					
Report Title:						Date of Report:							
<div><div>CODE REFERENCES</div><div>Show where requirement comes from</div></div>						(1). <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemize <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency				<u>LIST</u> of devices; (D) Specific deficiency			
						(2) <u>Properly instructed individuals</u> must oversee the routine maintenance and operational testing program				\$8.4.8		LS.02.01.70 EP 04	
						(3) <u>Test Interval</u> - minimum of 20 days; maximum of 40 days; EPSSs, including all appurtenant components, shall be exercised under load at least monthly;				\$8.4.1 NFPA 99-2012 \$6.4.4.1.1.4A;		EC.02.05.07 EP 04	
						...te cold starts				\$8.4.4		LS.02.01.70 EP 04	
										\$8.3.2.1; \$8.4.3		LS.02.01.70 EP 04	
						...generator test; annual test start within 10				NFPA 99-2012, \$6.4.4.1.1.2		LS.02.01.70 EP 04	
										\$8.4.2		EC.02.05.07 EP 04	
						...res as				\$8.4.2; \$8.4.2.3		EC.02.05.07 EP 05	
						...30% of the							
						(3) <u>Minimum Load</u> - Minimum load shall be exercised monthly under the available load							
(B) <u>Spark-ignited generator</u> (ie. Natural gas/propane) Use any of the following load criteria:						\$8.4.2.4		EC.02.05.07 EP 04					
(a) Available EPSS Load or						\$8.4.2.4		EC.02.05.07 EP 05					
(b) Until the water temperature and the oil pressure have stabilized													
(5) <u>Battery Electrolyte Condition</u> - Monthly, Must either a). measure & record spec gravity of each cell, or b). Perform battery conductance testing						\$8.3.7.1		LS.02.01.70 EP 04					

# 1. BASICS

## Mo. Generator Doc Review

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM				
	NOT ON	ON	5. GENERATOR EXERCISE - MONTHLY	NFPA CODE
Report Title:				Date of Report:
			(4) Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) <u>What</u> <u>LIST</u> of deficiencies; (D) <u>Qualifications</u> of personnel; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
			(2) <u>Properly instructed individuals</u> must oversee the routine maintenance and operational testing program	\$8.4.8 LS.02.01.70 EP 04
			(3) <u>Test Interval</u> - minimum of 20 days; maximum of 40 days; EPSSs, including all appurtenant components, shall be exercised under load at least monthly;	\$8.4.1 NFPA 99-2012 §6.4.4.1.1.4A; EC.02.05.07 EP 04
			(3)	\$8.4.4 LS.02.01.70 EP 04
				§8.3.2.1; § 8.4.3 LS.02.01.70 EP 04
				NFPA 99-2012, §6.4.4.1.1.2 LS.02.01.70 EP 04
			(4)	\$8.4.2 EC.02.05.07 EP 04
				§8.4.2; §8.4.2.3 EC.02.05.07 EP 05
				\$8.4.2.4 EC.02.05.07 EP 04
				\$8.4.2.4 EC.02.05.07 EP 05
			(5)	\$8.3.7.1 LS.02.01.70 EP 04
			spec gravity of each cell, or b). Perform battery conductance testing	

**TITLE OF REPORT**  
(if reviewing a completed report)

Identify What YOU  
call this Report  
&  
Date of Report



# 1. BASICS

## Mo. Generator Doc Review

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM				
		5. GENERATOR EXERCISE - MONTHLY	NFPA CODE NFPA 110-2010	TJC STD
Report Title:			Date of Report:	
		(1) <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
		(2) <u>Properly in</u> operational test		LS.02.01.70 EP 04
		(3) <u>Test Interval</u> all appurtenant	12 A;	EC.02.05.07 EP 04
		(3) <u>Start-Up:</u> (A)		LS.02.01.70 EP 04
		(B) Initiated by	4.3	LS.02.01.70 EP 04
		(a) Using th		
		(b) By oper		
		The 10-second	12, 2	LS.02.01.70 EP 04
		If the 10-second must confirm sec		
		(4) <u>Duration</u> -		EC.02.05.07 EP 04
		(A) <u>Diesel ge</u>		
		(a) Loading recommend	2.3	EC.02.05.07 EP 05
		(b) Under op		
		EPS namep		
		(c) Annual Load Bank (see separate test document) and exercised monthly under the available load		
		(B) <u>Spark-ignited generator</u> (ie. Natural gas/propane) Use any of the following load criteria:	\$8.4.2.4	EC.02.05.07 EP 04
		(a) Available EPSS Load or	\$8.4.2.4	EC.02.05.07 EP 05
		(b) Until the water temperature and the oil pressure have stabilized		
		(5) <u>Battery Electrolyte Condition</u> - Monthly, Must either a). measure & record spec gravity of each cell, or b). Perform battery conductance testing	\$8.3.7.1	LS.02.01.70 EP 04

### YOUR EVALUATION

Mark how your form complies with the code for EACH code requirement

↑ ↑ Mark One Box for Each Check Point

# 1. BASICS

## Mo. Generator Doc Review

### 7 BASIC CHECKPOINTS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM

	NOT ON FORM	ON FORM	5. GENERATOR EXERCISE - MONTHLY	NFPA CODE NFPA 110-2010	TJC STD
Report Title:				Date of Report:	
			(1) <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
			(2) <u>Properly instructed individuals</u> must oversee the routine maintenance and operational testing program	\$8.4.8	LS.02.01.70 EP 04
			(3) <u>Test Interval</u> - minimum of 20 days; maximum of 40 days; EPSSs, including all appurtenant components, shall be exercised under load at least monthly;	\$8.4.1 NFPA 99-2012 §6.4.4.1.1.4A;	EC.02.05.07 EP 04
			(3) <u>Start-Up</u> : (A) Load tests of generator sets shall include complete cold starts	\$8.4.4	LS.02.01.70 EP 04
			(B) Initiated by simulating a power outage by either:	\$8.3.2.1-§8.4.3	LS.02.01.70 EP 04

## KEY DOCUMENT ELEMENTS

Who, When, List, Checkpoints, Results & Repairs are  
KEY elements of EVERY inspection document

		(a) Loading that maintains the minimum exhaust gas temperatures as recommended by the manufacturer, or (b) Under operating temperature conditions and at not less than 30% of the EPS nameplate kW rating, or (c) Annual Load Bank (see separate test document) and exercised monthly under the available load	\$8.4.2; \$8.4.2.3	EC.02.05.07 EP 05
		(B) <u>Spark-ignited generator</u> (ie. Natural gas/propane) Use any of the following load criteria:	\$8.4.2.4	EC.02.05.07 EP 04
		(a) Available EPSS Load or (b) Until the water temperature and the oil pressure have stabilized	\$8.4.2.4	EC.02.05.07 EP 05
		(5) <u>Battery Electrolyte Condition</u> - Monthly, Must either a). measure & record spec gravity of each cell, or b). Perform battery conductance testing	\$8.3.7.1	LS.02.01.70 EP 04

# 1. BASICS

## Mo. Generator Doc Review

	NOT ON FORM	ON FORM	5. GENERATOR EXERCISE - MONTHLY	NFPA CODE NFPA 110-2010
Report Title:				Date of Report:
			(1). <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
			(2) <u>Properly instructed individuals</u> must oversee the routine maintenance and operational testing program	§8.4.8
			(3) <u>Test interval</u> - minimum of 20 days; maximum of 40 days; EPSSs, including all appurtenant components, shall be exercised under load at least monthly;	§8.4.1 NFPA 99-2012 §6.4.4.1.1.4A:

## INSPECTOR QUALIFICATIONS

- Can be performed by qualified in-house staff

		(b) By opening a normal breaker	
		The 10-second start criterion shall not apply during the monthly generator test; If the 10-second criterion is not met during the monthly test, an <u>annual test</u> must confirm the capability of the life safety & critical branches start within 10 sec	NFPA 99-2012, §6.4.4.1.1.2
		(4) <u>Duration</u> - must be exercised for at least 30 min under (A) <u>Diesel generator</u> . Use any of the following load criteria:	§8.4.2
		(a) Loading that maintains the minimum exhaust gas temperatures as recommended by the manufacturer, or (b) Under operating temperature conditions and at not less than 30% of the EPS nameplate kW rating, or (c) Annual Load Bank (see separate test document) and exercised monthly under the available load	§8.4.2; §8.4.2.3
		(B) <u>Spark-ignited generator</u> (ie. Natural gas/propane) Use any of the following load criteria:	§8.4.2.4
		(a) Available EPSS Load or	§8.4.2.4

# 1. BASICS

## Mo. Generator Doc Review

	NOT ON FORM	ON FORM	5. GENERATOR EXERCISE - MONTHLY	NFPA CODE NFPA 110-2010
Report Title:				Date of Report:
			(1) <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
			(2) <u>Properly instructed individuals</u> must oversee the routine maintenance and operational testing program	§8.4.8
			(3) <u>Test Interval</u> - minimum of 20 days; maximum of 40 days; EPSSs, including all appurtenant components, shall be exercised under load at least monthly;	§8.4.1 NFPA 99-2012 §6.4.4.1.1.4A;
			(3) <u>Start-Up</u> : (A) Load tests of generator sets shall include complete cold starts	§8.4.4
			(B) Initiated by simulating a power outage by either:	§8.3.2.1-§8.4.3

## FREQUENCY

- “Month” has Flexibility: 20-40 days apart

		must confirm the capability of the life safety & critical branches start within 10 sec	
		(4) <u>Duration</u> - must be exercised for at least 30 min under (A) <u>Diesel generator</u> . Use any of the following load criteria:	§8.4.2
		(a) Loading that maintains the minimum exhaust gas temperatures as recommended by the manufacturer, or (b) Under operating temperature conditions and at not less than 30% of the EPS nameplate kW rating, or (c) Annual Load Bank (see separate test document) and exercised monthly under the available load	§8.4.2; §8.4.2.3
		(B) <u>Spark-ignited generator</u> (ie. Natural gas/propane) Use any of the following load criteria:	§8.4.2.4
		(a) Available EPSS Load or	§8.4.2.4



# 1. BASICS

## Mo. Generator Doc Review

FORM		FORM		5. GENERATOR EXERCISE - MONTHLY		NFPA CODE NFPA 110-2010	
Report Title:						Date of Report:	
		(1). <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency					
		(2) <u>Properly instructed individuals</u> must oversee the routine maintenance and operational testing program					§8.4.8
		(3) <u>Test Interval</u> - minimum of 20 days; maximum of 40 days; EPSSs, including all appurtenant components, shall be exercised under load at least monthly;					§8.4.1 NFPA 99-2012 §6.4.4.1.1.4A;
		(3) <u>Start-Up</u> : (A) Load tests of generator sets shall include complete cold starts					§8.4.4
		(B) Initiated by simulating a power outage by either: (a) Using the test switch(es) on the ATSS, or (b) By opening a normal breaker					§8.3.2.1; § 8.4.3
		The 10-second start criterion shall not apply during the monthly generator test; If the 10-second criterion is not met during the monthly test, an <u>annual test</u> must confirm the capability of the life safety & critical branches start within 10 sec					NFPA 99-2012, §6.4.4.1.1.2
		(4) <u>Duration</u> - must be exercised for at least 30 min under (A) <u>Diesel generator</u> . Use any of the following load criteria:					§8.4.2

## START OF TEST

- Must be a Cold Start
- Use ATS Test Switch or Turn off normal breaker
- Do NOT need to verify 10 sec start each month
- Annual verification of 10 sec start

(5) Battery Electrolyte Condition - Monthly, Must either a). measure & record

§8.3.7.1



# 1. BASICS

## Mo. Generator Doc Review

(1) Report contains (A) WHO did inspection; (B) WHEN performed; (C) itemized LIST of devices; CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency

(2) Properly instructed individuals must oversee the routine maintenance and

§8.4.8

### DURATION OF TEST & LOAD

- Depends on Type Generator
  - Diesel: for 30 min at 30% Nameplate KWH or min Exhaust Temp or Annual Load Bank
  - Natural Gas: Until reach operating temp & pressure at the available load

(4) Duration - must be exercised for at least 30 min under

§8.4.2

(A) Diesel generator. Use any of the following load criteria:

- (a) Loading that maintains the minimum exhaust gas temperatures as recommended by the manufacturer, or
- (b) Under operating temperature conditions and at not less than 30% of the EPS nameplate kW rating, or
- (c) Annual Load Bank (see separate test document) and exercised monthly under the available load

§8.4.2; §8.4.2.3

(B) Spark-ignited generator (ie. Natural gas/propane) Use any of the following load criteria:

§8.4.2.4

- (a) Available EPSS Load or
- (b) Until the water temperature and the oil pressure have stabilized

§8.4.2.4

(5) Battery Electrolyte Condition - Monthly, Must either a). measure & record spec gravity of each cell, or b). Perform battery conductance testing

§8.3.7.1

# 1. BASICS

## Mo. Generator Doc Review

		(B) Initiated by simulating a power outage by either: (a) Using the test switch(es) on the ATSS, or (b) By opening a normal breaker	§8.3.2.1; § 8.4.3
		The 10-second start criterion shall not apply during the monthly generator test; If the 10-second criterion is not met during the monthly test, an <u>annual test</u> must confirm the capability of the life safety & critical branches start within 10 sec	NFPA 99-2012, §6.4.4.1.1.2
		(4) <b>Duration</b> - must be exercised for at least 30 min under	§8.4.2

### BATTERY INSPECTION

- Choice of method:
  - Specific Gravity of each cell (must record)
  - Measure Battery Conductance

		load criteria:	
		(a) Available EPSS Load or (b) Until the water temperature and the oil pressure have stabilized	§8.4.2.4
		(5) <b><u>Battery Electrolyte Condition</u></b> - Monthly, Must either a). measure & record spec gravity of each cell, or b). Perform battery conductance testing	§8.3.7.1
		(6) <b><u>Transfer Switch Test</u></b> - (A) Must operate every automatic and manual transfer switch each month. Transfer shall consist of electrically operating the transfer switch from the standard position to the alternate position and then a return to the standard position	§8.4.6; §8.3.2.1; §8.4.6.1
		(7) <b><u>Time-Delays</u></b> : (A) Must have a minimum 1 second Time delay on start	§8.4.5(1)
		(B) Must have a minimum 5 minute Time delay on shut-down (Cool-Down)	§8.4.5(4)

# 1. BASICS

## Mo. Generator Doc Review

		(B) Initiated by simulating a power outage by either: (a) Using the test switch(es) on the ATSS, or (b) By opening a normal breaker	§8.3.2.1; § 8.4.3
		The 10-second start criterion shall not apply during the monthly generator test; If the 10-second criterion is not met during the monthly test, an <u>annual test</u> must confirm the capability of the life safety & critical branches start within 10 sec	NFPA 99-2012, §6.4.4.1.1.2
		(4) <u>Duration</u> - must be exercised for at least 30 min under (A) <u>Diesel generator.</u> Use any of the following load criteria:	§8.4.2
		(a) Loading that maintains the minimum exhaust gas temperatures as recommended by the manufacturer, or (b) Under operating temperature conditions and at not less than 30% of the EPS nameplate kW rating, or (c) Annual Load Bank (see separate test document) and exercised monthly	§8.4.2; §8.4.2.3

## TRANSFER SWITCHES

- Operate all Transfer Switches (manual & automatic)

		(b) Until the water temperature and the oil pressure have stabilized	
		(5) <u>Battery Electrolyte Condition</u> - Monthly, Must either a). measure & record spec gravity of each cell, or b). Perform battery conductance testing	§8.3.7.1
		(6) <u>Transfer Switch Test</u> - (A) Must operate every automatic and manual transfer switch each month. Transfer shall consist of electrically operating the transfer switch from the standard position to the alternate position and then a return to the standard position	§8.4.6; §8.3.2.1; §8.4.6.1
		(7) <u>Time-Delays:</u> (A) Must have a minium 1 second Time delay on start	§8.4.5(1)
		(B) Must have a minium 5 minute Time delay on shut-down (Cool-Down)	§8.4.5(4)



# 1. BASICS

## Mo. Generator Doc Review

		(B) Initiated by simulating a power outage by either: (a) Using the test switch(es) on the ATSS, or (b) By opening a normal breaker	§8.3.2.1; § 8.4.3
		The 10-second start criterion shall not apply during the monthly generator test; If the 10-second criterion is not met during the monthly test, an <u>annual test</u> must confirm the capability of the life safety & critical branches start within 10 sec	NFPA 99-2012, §6.4.4.1.1.2
		(4) <u>Duration</u> - must be exercised for at least 30 min under (A) <u>Diesel generator.</u> Use any of the following load criteria:	§8.4.2
		(a) Loading that maintains the minimum exhaust gas temperatures as recommended by the manufacturer, or (b) Under operating temperature conditions and at not less than 30% of the EPS nameplate kW rating, or (c) Annual Load Bank (see separate test document) and exercised monthly	§8.4.2; §8.4.2.3

## TIME DELAYS

### • Document Start-up & Shut-down Time Delays

		(b) Until the water temperature and the oil pressure have stabilized	
		(5) <u>Battery Electrolyte Condition</u> - Monthly, Must either a). measure & record spec gravity of each cell, or b). Perform battery conductance testing	§8.3.7.1
		(6) <u>Transfer Switch Test</u> - (A) Must operate every automatic and manual transfer switch each month. Transfer shall consist of electrically operating the transfer switch from the standard position to the alternate position and then a return to the standard position	§8.4.6; §8.3.2.1; §8.4.6.1
		(7) <u>Time-Delays:</u>	§8.4.5(1)
		(A) Must have a minium 1 second Time delay on start	
		(B) Must have a minium 5 minute Time delay on shut-down (Cool-Down)	§8.4.5(4)



**TOOLS for REVIEW of**

# **Inspection Documentation**

## **5. Annual FIRE ALARM**

The BIGGEST of all Reports !

4 Pages of Requirements!



# TWO PARTS OF THE REVIEW

## Annual Fire A Doc Review

### Part 1 - Basics

Inspect ALL rated sys  
for these items

### 9 BASIC CHECKPOINTS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM				
Report Title:			Date of Report:	
NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2011	TJC STD
		(1) Report contains (A) WHO did inspection; (B) WHEN performed; (C) Itemized LIST of devices; (D) Specific CHECKPOINTS; (E) RESULTS of each checkpoint & (F) Doc REPAIR of any deficiency		
		<b>• NFPA 72 Frequency Definitions (use ONLY for FA)</b> ◊ Weekly = 52 per year, once per calendar week ◊ Monthly = 12 per year, once per calendar month ◊ Quarterly = 4 per year, min 2 months, max 4 months ◊ Semiannual = 2 per year, min 4 months, max 8 months ◊ Annual = 1 per year, min 9 months, max 15 months	3.3.106	LS 02.01.34 EP 04
		(2) Control Panels - Visual - (A) Fuses, for appearance, Condition, Damage, Proper installation	Table 14.3.1(1a)	LS 02.01.34 EP 04
		(B) Lamps, LEDs	Table 14.3.1(1c)	LS 02.01.34 EP 04
		(C) Primary Power Supplies, for physical condition, Noise, Heat, Corrosion at terminals	Table 14.3.1(1d)	LS 02.01.34 EP 04
		(3) Transient Suppressors - (A) Visual - per mfr recommendations & after any lightning strike	Table 14.3.1(4) Method: Table 14.4.2(9)	LS 02.01.34 EP 04
		(4) Control Panels - Test - (A) Verify Functions (a) correct receipt of alarm, supervisory, and trouble signals (inputs) (b) operation of evacuation signals and auxiliary functions (outputs) (c) circuit supervision, including detection of open circuits and ground faults (d) power supply supervision for detection of loss of ac power and disconnection of secondary batteries (e) Input/output control equipment functions proper operation (checking of functions internal to the equipment, such as software algorithms & communications protocols (sometimes called firmware), is not intended)	Table 14.4.5(1a) Method: Table 14.4.2(1a)	LS 02.01.34 EP 04
		(B) Fuses - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1) Method: Table 14.4.2(1b)	
		(C) Lamps, LEDs - Illuminated	Table 14.4.5(1)	
		(D) Primary Power Supplies - (a) Disconnect all secondary power; (b) Test under maximum load (including all alarm appliances requiring simultaneous operation)	Table 14.4.5(1) Method: Table 14.4.2(1e)	
		(E) Secondary Power Supplies - (a) Disconnect all primary power; (b) Verify trouble signal for loss of primary power; (c) Measure standby and alarm current demand & verify vs mfr data to meet standby and alarm requirements; (d) Operate general alarm systems for min 5 minutes; (e) Operate emerg voice comm sys min 15 minutes	Table 14.4.5(5) Method: Table 14.4.2(3)	
		(F) Transponders	Table 14.4.5(1)	
		(G) Trouble Signals (a) Verify Audible and visual Operation & ring-back feature for systems using a trouble-silencing switch that requires resetting. (b) Test each Disconnect switches (if any) for performance of intended function & receipt of trouble signal when a supervised function is disconnected (c) Verify indication of Ground-fault monitoring (if any) by grounding any conductor location (d) Activate an Initiating device and verify receipt of alarm signal at the off-premises location (e) Create a trouble condition & verify receipt of trouble signal at the off-premises location (f) Activate a supervisory device & verify receipt of supervisory signal at the off-premises location (g) If a transmission carrier is capable of operation under a single- or multiple-fault condition, Activate an initiating device during a fault condition & verify receipt of both a trouble and alarm signal at the off-premises location	Table 14.4.5(1) Method: Table 14.4.2(10)	

NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2011	TJC STD
		(5) Batteries		
		If Lead-Acid: (A) Charger Test - (1) With the batteries fully charged and connected to the charger, measure voltage across the batteries (2) Verify voltage is min 2.30 volts per cell $\pm 0.02$ volts at 77°F or per mfr	NFPA 72-2010, Table 14.4.5(6a)(1) Method: Table 14.4.2(2)(b)(1)	LS 02.01.34 EP 04
		If Sealed Lead Acid: (A) Charger Test - (1) With the batteries fully charged and connected to the charger, measure voltage across the batteries; (2) Verify voltage is 2.30 volts per cell $\pm 0.02$ volts at 77°F or per mfr	NFPA 72-2010, Table 14.4.5(6d)(1) Method: Table 14.4.2(2)(d)(1)	LS 02.01.34 EP 04
		(B) Discharge Test (30 min) - (1) Disconnect charger; (2) Load test per mfr; (3) Voltage remains above mfr recommendation	NFPA 72-2010, Table 14.4.5(6d)(2) Method: Table 14.4.2(2)(d)	LS 02.01.34 EP 04
		(6) Special Procedures - (A) Alarm verification - Verify Time delay and alarm response for smoke detector circuits	Table 14.4.5(23) Method: Table 14.4.2(25a)	LS 02.01.34 EP 04
		(7) Supervisory Station Transmitter - Test - per mfr instructions; (A) Actuate Initiating device & verify receipt within 90 sec of the correct initiating device signal at the supervising station	Table 14.4.5(22) Method: Table 14.4.2(18)	LS 02.01.34 EP 04
		(8) Initiating Devices:		
		(A) Manual Fire Alarm Boxes	Table 14.4.5(15f)	EC 02.03.05 EP 03
		(B) Smoke Detectors (Functional Test) - per mfr instr; Smoke must enter sensing chamber & activate alarm	Table 14.4.5(15h) Method: Table 14.4.2(14g)	EC 02.03.05 EP 03
		(C) Smoke Alarms - per mgr recommendation	Table 14.4.5(15j)	EC 02.03.05 EP 03
		(D) Duct Detectors - per mfr recommendation; (a) Smoke must enter sensing chamber & activate alarm; (b) Duct detectors with sampling tubes must verify the correct pressure differential between the inlet and exhaust tubes is per mfr recommendation	Table 14.4.5(15a) Method: Table 14.4.2(14g)(6)	EC 02.03.05 EP 03
		(E) Heat Alarms - per mgr recommendation	Table 14.4.5(15k)	EC 02.03.05 EP 03
		(F) Heat Detectors - per mfr recommendations	Table 14.4.5(15l)	EC 02.03.05 EP 03
		(G) Radiant Energy Fire Detectors - per mfr recommendations	Table 14.4.5(15g) Method: Table 14.4.2(14f)	EC 02.03.05 EP 03
		(H) ElectroMech Release Devices - Remove fusible link & verify operation of the device. Lube any moving parts as necessary	Table 14.4.5(15b) Method: Table 14.4.2(14a)	EC 02.03.05 EP 03
		(I) Suppression Switches - Mechanically or electrically operate suppression sys switch & Verify receipt of signal by the fire alarm control unit	Table 14.4.5(15c) Method: Table 14.4.2(14b)	EC 02.03.05 EP 03
		(9) Notification Appliance Tests		
		(A) Audible Bells, Horns, Chimes in areas with building, system, or occupancy changes - (a) Measure sound pressure levels per requirements in Chapter 18 (using a sound level meter meeting ANSI S1.4a, Type 2, using the time-weighted characteristic F)	Table 14.4.5(20) Method: Table 14.4.2(15a)	EC 02.03.05 EP 04
		(B) Visual Strobes - (a) Loc per approved layout; (b) No floor plan changes	Table 14.4.5(20)	EC 02.03.05 EP 04

# TWO PARTS OF THE REVIEW

## Annual Fire A Doc Review

### Part 2 – “IFs”

Inspect these items  
IF you have them

### 16 SUPPLEMENTAL CHECKPOINTS

These items are only inspected if present, but form should have space to indicate that item is not present, i.e. not applicable			
NOT APPLIC	NOT ON FORM	ON FORM	
			<b>4. FIRE ALARM - ANNUAL (Continued)</b>
			<b>(11) Remote Annunciators - Test</b> - (A) Verify correct operation and identification of annunciators & correct operation under a fault condition
			NFPA CODE NFPA 72-2011 Method: Table 14.4.2.2(11)
			TJC STD LS 02.01.34 EP 04
			<b>(12) Mass Notification Sys-Visual (supervised)</b> (if any)
			Table 14.3.1(19)
			LS 02.01.34 EP 04
			(A) Mass Notification Antenna (if any) - Visual
			Table 14.3.1(21)
			LS 02.01.34 EP 04
			(B) Mass Notification Transceivers (if any) - Visual
			Table 14.3.1(22)
			LS 02.01.34 EP 04
			<b>(13) Mass Notification Sys-Test (supervised)</b> (if any)
			(A) Verify input control equip correctly receives alarm, supervisory & trouble signals;
			(B) Outputs operate evac signals & aux functions;
			(C) circuit supervision, including detection of open circuits & ground faults;
			(D) power supply supervision for detection of loss of ac power & disconnection of secondary batteries;
			(E) Fuses, lamps, power supplies, interface equip, notification devices & control unit properly operates
			Table 14.3.1(19) Method: Table 14.4.2.2(27)
			LS 02.01.34 EP 04
			<b>(14) Supervisory Device Tests</b>
			(A) <b>Fire Pump Alarm</b> (if any) - Verify supervisory signal received when pump starts
			Table 14.4.5(15)(7)
			LS 02.01.34 EP 04
			(B) <b>Generator Alarms</b> (if any) - Verify supervisory signal received when generator starts
			Table 14.4.5(15)(7)
			LS 02.01.34 EP 04
			<b>(15) Voice/Alarm Communication Equip</b>
			(A) Operate Call-in; Verify receipt of correct visual/audible signal;
			(B) Install Phone set or remove from hook; Verify receipt of signal at control unit;
			(C) Visually inspect Phone jack;
			(D) Activated Phone set & verify correct operation;
			(E) Verify sys performance with min of 5 handsets simultaneously; (F) Verify Voice quality and clarity
			Table 14.4.5(26) Method: Table 14.4.2.2(20)
			LS 02.01.34 EP 04
			<b>(16) Special Procedures</b> - Multiplex verification -
			(a) Verify comm between sending & receiving units under both primary & secondary power
			(b) Verify comm between sending & receiving units under open circuit & short circuit trouble conditions
			(c) Verify comm between sending & receiving units in all directions if there are multiple comm pathways
			(d) Verify redundant central control equip (if any) swtchover and required functions & operations of secondary control equipment
			(e) Verify all system functions and features per mfr instructions
			Table 14.4.5(23) Method: Table 14.4.2.2(25b)
			LS 02.01.34 EP 04

			<b>(17) Combination Sys - Test</b> - (A) <b>Fire Extinguisher Electronic Monitoring</b> (if any) - Test proper signals are received at the fire alarm control	Table 14.4.5(17a) Method: Table 14.4.2.2(21)	LS 02.01.34 EP 04
			<b>(18) Carbon Monoxide Detection Sys</b>	Table 14.3.1(11b) NFPA 720-2011, Table 8.3.1	EC.02.03.05 EP 03
			(A) Visual on Control System & Fiber-Optic cable connection	Table 14.4.5(17b) NFPA 720-2011, Table 8.4.3	EC.02.03.05 EP 03
			(B) Tests: (1) Control equip, per Table item 1; (2) Sealed Lead Acids, Charger Test, Discharge Test, per Table item 6c; (3) Fiber-Optic Cable Power per Table item 11b; (4) Control Unit Trouble Signal per Table item 8; (5) Remote Annunciator per Table item 9; (6) Initiating Devices per Table item 12; (7) Interface Equip per Table items 15,16; (8) Alarm Notification per Table item 13; (9) Special procedures per Table item 17. Note: Use NFPA 7-page example form 8.6.2.2 or equivalent	8.4.4.1	EC.02.03.05 EP 03
			(C) Test Carbon Monoxide Detectors by introduction of CO into the sensor element (electronic checks not acceptable)	Table 14.4.5(21) Table 14.4.2.2(16)	
			<b>(19) Exit Marking Notif - Test</b> - (if any) Tests shall be performed in accordance with manufacturer's published instructions	Table 14.4.5(21) Table 14.4.2.2(16)	
			<b>(20) Interface Device Tests</b> - Includes: (a) simulated interface operation, b) check of wiring connections via simulated open & single ground to verify proper indication of wire integrity, and (c) check of supervisory via placing in simulated trouble condition to verify proper receipt & reaction at control unit	Table 14.4.2.2(1c) Method: Table 14.4.2.2(22)	LS 02.01.34 EP 04
			(A) <b>Pre-Action Operation</b> (if any) - operate or simulate equip being supervised & verify signal received at control unit	Method: Table 14.4.2.2(22)	LS 02.01.34 EP 04
			(B) <b>Dry Pipe Operation</b> (if any) - operate or simulate equip being supervised & verify signal received at control unit	Method: Table 14.4.2.2(22)	LS 02.01.34 EP 04
			(C) <b>Clean Agent Operation</b> (if any) - operate or simulate equip being supervised & verify signal received at control unit	Method: Table 14.4.2.2(22)	LS 02.01.34 EP 04
			(D) <b>Other Connections</b> to FA - operate or simulate equip being supervised & verify signal received at control unit	Method: Table 14.4.2.2(22)	LS 02.01.34 EP 04
			(E) <b>Fire Pump</b> (if any) - operate or simulate equip being supervised & verify signal received at alarm panel	Method: Table 14.4.2.2(22)	LS 02.01.34 EP 04
			<b>(21) Emergency Control Interface Tests</b>	Table 14.4.5(18)	
			(A) Delayed Egress Release - operate or simulate equip being supervised & verify lock release	Method: Table 14.4.2.2(23)	LS 02.01.34 EP 04
			(B) Rolling Door Release - operate or simulate equip being supervised & verify door closure	Method: Table 14.4.2.2(23)	LS 02.01.34 EP 04
			(C) Elevator Recall - operate or simulate equip being supervised & verify	Method: Table	LS 02.01.34 EP 04

## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM

Report		Date of Report:	
Title:			
NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2011
		(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	TJC STD
		<b>♦ NFPA 72 Frequency Definitions (use ONLY for FA)</b> ♦ Weekly = 52 per year, once per calendar week ♦ Monthly = 12 per year, once per calendar month ♦ Quarterly = 4 per year, min 2 months, max 4 months ♦ Semiannual = 2 per year, min 4 months, max 8 months ♦ Annual = 1 per year, min 9 months, max 15 months	3.3.106
		<div style="border: 2px solid black; padding: 10px; text-align: center;"> <h3><u>ALL CHECKPOINTS ON FORM</u></h3> <h2>Quote the Code</h2> </div>	LS 02.01.34 EP 04
			LS 02.01.34 EP 04
			LS 02.01.34 EP 04
			LS 02.01.34 EP 04
			LS 02.01.34 EP 04
		equipment functions proper operation (checking of functions internal to the equipment, such as software algorithms & communications protocols (sometimes called firmware), is not intended)	
		(B) <b>Fuses</b> - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1b) Method: Table 14.4.2.2(1b)
		(C) <b>Lamps</b> , LEDs - Illuminated	Table 14.4.5(1d)
		(D) <b>Primary Power Supplies</b> - (a) Disconnect all secondary power; (b) Test under maximum load (including all alarm appliances requiring simultaneous operation)	Table 14.4.5(1e) Method: Table 14.4.2.2(1e)





## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM

Report Title:	Date of Report:
---------------	-----------------

NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2011	TJC STD
		(1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
		<p>♦ <u>NFPA 72 Frequency Definitions (use ONLY for FA)</u></p> <p>◊ Weekly = 52 per year, once per calendar week</p> <p>◊ Monthly = 12 per year, once per calendar month</p> <p>◊ Quarterly = 4 per year, min 2 months, max 4 months</p>	3.3.106	LS 02.01.34 EP 04
		<div> <p><b><u>TITLE OF REPORT</u></b></p> <p>(if reviewing a completed report)</p> <p>Identify What <b>YOU</b> call this Report &amp; Date of Report</p> </div>	Table 14.3.1(1a)	LS 02.01.34 EP 04
			Table 14.3.1(1c)	LS 02.01.34 EP 04
			Table 14.3.1(1d)	LS 02.01.34 EP 04
			Table 14.3.1(4) Method: Table 14.4.2.2(9)	LS 02.01.34 EP 04
			Table 14.4.5(1a) Method: Table 14.4.2.2(1a)	LS 02.01.34 EP 04
			Table 14.4.5(1b) Method: Table 14.4.2.2(1b)	LS 02.01.34 EP 04
			Table 14.4.5(1d)	LS 02.01.34 EP 04
			Table 14.4.5(1e) Method: Table 14.4.2.2(1e)	LS 02.01.34 EP 04



## 1. BASICS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM				
Report Title:		Date of Report:		
NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2011	TJC STD
		1). Report contains (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific		
		CHECKPOINT		
		♦ NFPA		LS 02.01.34 EP 04
		♦ Weekly		
		♦ Monthly		
		♦ Quarterly		
		♦ Semiannual		
		♦ Annual		
		2) Control Panel		
		Proper installation	(1a)	LS 02.01.34 EP 04
		(B) Lamps, LEDs	(1c)	LS 02.01.34 EP 04
		(C) Primary Power Supplies	(1d)	LS 02.01.34 EP 04
		terminals		
		3) Transient		
		lightning strikes	(1(4)	LS 02.01.34 EP 04
			Table 14.4.2.2(1e)	
		4) Control Panel		
		supervisory, alarm, and auxiliary functions	(5(1a)	LS 02.01.34 EP 04
		circuits and ground	Table 14.4.2.2(1a)	
		power and distribution		
		equipment function		
		equipment, such as		
		firmware), is not intended)		
		(B) <b>Fuses</b> - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1b) Method: Table 14.4.2.2(1b)	LS 02.01.34 EP 04
		(C) <b>Lamps, LEDs</b> - Illuminated	Table 14.4.5(1d)	LS 02.01.34 EP 04
		(D) <b>Primary Power Supplies</b> - (a) Disconnect all secondary power; (b) Test under maximum load (including all alarm appliances requiring simultaneous operation)	Table 14.4.5(1e) Method: Table 14.4.2.2(1e)	LS 02.01.34 EP 04

### YOUR EVALUATION

Mark how your form complies with the code for EACH code requirement

↑ ↑ Mark One Box for Each Check Point

## 1. BASICS

## 9 BASIC CHECKPOINTS

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM				
Report Title:			Date of Report:	
NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2014	TIC STD
		(1) <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) Specific <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency		
		<u>NFPA 72 Frequency Definitions (use ONLY for FA)</u> ◇ Weekly = 52 per year, once per calendar week ◇ Monthly = 12 per year, once per calendar month ◇ Quarterly = 4 per year, min 2 months, max 4 months ◇ Semiannual = 2 per year, min 4 months, max 8 months ◇ Annual = 1 per year, min 9 months, max 15 months	14.3.100	LS 02.01.34 EP 04
		(2) <u>Control Panels - Visual</u> - (A) Fuses, for appearance, Condition, Damage, Proper installation	Table 14.3.1(1a)	LS 02.01.34 EP 04
		(B) <u>Lamps, LEDs</u>	Table 14.3.1(1c)	LS 02.01.34 EP 04
		power and disconnection of secondary batteries (e) Input/output control equipment functions proper operation (checking of functions internal to the equipment, such as software algorithms & communications protocols (sometimes called firmware), is not intended)		
		(B) <u>Fuses</u> - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1b) Method: Table 14.4.2.2(1b)	LS 02.01.34 EP 04
		(C) <u>Lamps, LEDs</u> - Illuminated	Table 14.4.5(1d)	LS 02.01.34 EP 04
		(D) <u>Primary Power Supplies</u> - (a) Disconnect all secondary power; (b) Test under maximum load (including all alarm appliances requiring simultaneous operation)	Table 14.4.5(1e) Method: Table 14.4.2.2(1e)	LS 02.01.34 EP 04

## KEY DOCUMENT ELEMENTS

Who, When, List, Checkpoints, Results & Repairs are KEY elements of EVERY inspection document

## 1. BASICS

NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2011
		(1). <u>Report contains</u> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
		<p>♦ <u>NFPA 72 Frequency Definitions (use ONLY for FA)</u></p> <ul style="list-style-type: none"> <li>♦ Weekly = 52 per year, once per calendar week</li> <li>♦ Monthly = 12 per year, once per calendar month</li> <li>♦ Quarterly = 4 per year, min 2 months, max 4 months</li> <li>♦ Semiannual = 2 per year, min 4 months, max 8 months</li> <li>♦ Annual = 1 per year, min 9 months, max 15 months</li> </ul>	3.3.106
		(2) <u>Control Panels - Visual</u> - (A) Fuses, for appearance, Condition, Damage, Proper installation	Table 14.3.1(1a)
		(B) Lamps, LEDs	Table 14.3.1(1c)
<h3><u>NFPA 72 FREQUENCY - FLEXIBILITY</u></h3> <ul style="list-style-type: none"> <li>• More tolerance than other NFPA codes</li> </ul>			
		(4) <u>Control Panels - Test</u> - (A) <u>Verify Functions</u> (a) correct receipt of alarm, supervisory, and trouble signals (inputs) (b) operation of evacuation signals and auxiliary functions (outputs) (c) circuit supervision, including detection of open circuits and ground faults (d) power supply supervision for detection of loss of ac power and disconnection of secondary batteries (e) Input/output control equipment functions proper operation (checking of functions internal to the equipment, such as software algorithms & communications protocols (sometimes called firmware), is not intended)	Table 14.4.5(1a) Method: Table 14.4.2.2(1a)
		(B) <u>Fuses</u> - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1b) Method: Table 14.4.2.2(1b)
		(C) <u>Lamps</u> , LEDs - Illuminated	Table 14.4.5(1d)
		(D) <u>Primary Power Supplies</u> - (a) Disconnect all secondary power; (b) Test	Table 14.4.5(1e)



# 1. BASICS

NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2011
		(1) <b>Report contains</b> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
		<b>♦ NFPA 72 Frequency Definitions (use ONLY for FA)</b> ♦ Weekly = 52 per year, once per calendar week ♦ Monthly = 12 per year, once per calendar month ♦ Quarterly = 4 per year, min 2 months, max 4 months ♦ Semiannual = 2 per year, min 4 months, max 8 months ♦ Annual = 1 per year, min 9 months, max 15 months	3.3.106
		(2) <b>Control Panels - Visual</b> - (A) Fuses, for appearance, Condition, Damage, Proper installation	Table 14.3.1(1a)
		(B) Lamps, LEDs	Table 14.3.1(1c)
		(C) Primary Power Supplies, for physical condition, Noise, Heat, Corrosion at terminals	Table 14.3.1(1d)
		(3) <b>Transient Suppressors</b> - (A) visual - per mfr recommendations & after any lightning strike	Table 14.3.1(1e) Method: Table 14.4.2.2(9)
		(4) <b>Control Panels - Test</b> - (A) <u>Verify Functions</u> (a) correct receipt of alarm, supervisory, and trouble signals (inputs); (b) operation of evacuation signals and	Table 14.4.5(1a) Method: Table 14.4.5(1a)
<h2><u>CONTROL PANEL - VISUAL</u></h2> <ul style="list-style-type: none"> <li>Multiple Checkpoints of fuses, lamps, primary power</li> </ul>			
		equipment, such as software algorithms & communications protocols (sometimes called firmware), is not intended)	
		(B) <b>Fuses</b> - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1b) Method: Table 14.4.2.2(1b)
		(C) <b>Lamps</b> , LEDs - Illuminated	Table 14.4.5(1d)
		(D) <b>Primary Power Supplies</b> - (a) Disconnect all secondary power; (b) Test	Table 14.4.5(1e)

# 1. BASICS

NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2011
		(1). <b>Report contains</b> (A) <u>WHO</u> did inspection; (B) <u>WHEN</u> performed; (C) Itemized <u>LIST</u> of devices; (D) <u>CHECKPOINTS</u> ; (E) <u>RESULTS</u> of each checkpoint & (F) Doc <u>REPAIR</u> of any deficiency	
		<b>♦ NFPA 72 Frequency Definitions (use ONLY for FA)</b> ♦ Weekly = 52 per year, once per calendar week ♦ Monthly = 12 per year, once per calendar month ♦ Quarterly = 4 per year, min 2 months, max 4 months ♦ Semiannual = 2 per year, min 4 months, max 8 months ♦ Annual = 1 per year, min 9 months, max 15 months	3.3.106
		(2) <b>Control Panels - Visual</b> - (A) Fuses, for appearance, Condition, Damage, Proper installation	Table 14.3.1(1a)
		(B) Lamps, LEDs	Table 14.3.1(1c)
		(C) Primary Power Supplies, for physical condition, Noise, Heat, Corrosion at terminals	Table 14.3.1(1d)
		(3) <b>Transient Suppressors</b> - (A) Visual - per mfr recommendations & after any lightning strike	Table 14.3.1(4) Method: Table 14.4.2.2(9)
		(4) <b>Control Panels - Test</b> - (A) <u>Verify Functions</u> (a) correct receipt of alarm, supervisory, and trouble signals (inputs); (b) operation of evacuation signals and	Table 14.4.5(1a) Method: Table 14.4.5(1a)
<h2><u>TRANSIENT SUPPRESSORS</u></h2> <ul style="list-style-type: none"> <li>Visual of lightning suppressors</li> </ul>			
		equipment, such as software algorithms & communications protocols (sometimes called firmware), is not intended)	
		(B) <b>Fuses</b> - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1b) Method: Table 14.4.2.2(1b)
		(C) <b>Lamps</b> , LEDs - Illuminated	Table 14.4.5(1d)
		(D) <b>Primary Power Supplies</b> - (a) Disconnect all secondary power; (b) Test	Table 14.4.5(1e)



## 1. BASICS

		terminals	
		<b>(3) Transient Suppressors</b> - (A) Visual - per mfr recommendations & after any lightning strike	Table 14.3.1(4) Method: Table 14.4.2.2(9)
		<b>(4) Control Panels - Test</b> - (A) <b>Verify Functions</b> (a) correct receipt of alarm, supervisory, and trouble signals (inputs) (b) operation of evacuation signals and auxiliary functions (outputs) (c) circuit supervision, including detection of open circuits and ground faults (d) power supply supervision for detection of loss of ac power and disconnection of secondary batteries (e) Input/output control equipment functions proper operation (checking of functions internal to the equipment, such as software algorithms & communications protocols (sometimes called firmware), is not intended)	Table 14.4.5(1a) Method: Table 14.4.2.2(1a)
		(B) <b>Fuses</b> - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1b) Method: Table 14.4.2.2(1b)
		(C) <b>Lamps</b> , LEDs - Illuminated	Table 14.4.5(1d)
		(D) <b>Primary Power Supplies</b> - (a) Disconnect all secondary power; (b) Test under maximum load (including all alarm appliances requiring simultaneous operation)	Table 14.4.5(1e) Method: Table 14.4.2.2(1e)
		(E) <b>Secondary Power Supplies</b> - (a) Disconnect all primary power; (b) Verify trouble signal for loss of primary power; (c) Measure standby and alarm current demand & verify vs mfr data to meet standby and alarm requirements; (d) Operate general alarm systems for min 5 minutes; (e) Operate emerg voice comm sys min 15 minutes	Table 14.4.5(5) Method: Table 14.4.2.2(3)

## CONTROL PANEL - TESTS

- Many, Many tests

(c) Verify indication of Ground-fault monitoring (if any) by grounding any conductor location

# 1. BASICS

terminals

**(3) Transient Suppressors** - (A) Visual - per mfr recommendations & after any lightning strike

Table 14.3.1(4)  
Method: Table  
14.4.2.2(9)

**(4) Control Panels - Test** - (A) **Verify Functions** (a) correct receipt of alarm, supervisory, and trouble signals (inputs) (b) operation of evacuation signals and auxiliary functions (outputs) (c) circuit supervision, including detection of open circuits and ground faults (d) power supply supervision for detection of loss of ac power and disconnection of secondary batteries (e) Input/output control equipment functions proper operation (checking of functions internal to the equipment, such as software algorithms & communications protocols (sometimes called firmware), is not intended)

Table 14.4.5(1a)  
Method: Table  
14.4.2.2(1a)

(B) **Fuses** - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester

Table 14.4.5(1b)  
Method: Table

## CONTROL PANEL - FUNCTIONS

- Signal Receipt (alarm, supervisory, trouble)
- Evac & Aux Outputs
- Circuit Supervision
- Primary Power
- Control Equip Operation

feature for systems using a trouble-silencing switch that requires resetting.  
(b) Test each Disconnect switches (if any) for performance of intended function & receipt of trouble signal when a supervised function is disconnected  
(c) Verify indication of Ground-fault monitoring (if any) by grounding any conductor location

Method: Table  
14.4.2.2(10)

# 1. BASICS

		terminals	
		<b>(3) Transient Suppressors</b> - (A) Visual - per mfr recommendations & after any lightning strike	Table 14.3.1(4) Method: Table 14.4.2.2(9)
		<b>(4) Control Panels - Test</b> - (A) <b>Verify Functions</b> (a) correct receipt of alarm, supervisory, and trouble signals (inputs) (b) operation of evacuation signals and auxiliary functions (outputs) (c) circuit supervision, including detection of open circuits and ground faults (d) power supply supervision for detection of loss of ac power and disconnection of secondary batteries (e) Input/output control equipment functions proper operation (checking of functions internal to the equipment, such as software algorithms & communications protocols (sometimes called firmware), is not intended)	Table 14.4.5(1a) Method: Table 14.4.2.2(1a)
		(B) <b>Fuses</b> - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1b) Method: Table 14.4.2.2(1b)
		(C) <b>Lamps</b> , LEDs - Illuminated	Table 14.4.5(1d)
		(D) <b>Primary Power Supplies</b> - (a) Disconnect all secondary power; (b) Test under maximum load (including all alarm appliances requiring simultaneous	Table 14.4.5(1e) Method: Table
<div data-bbox="376 921 1532 981" data-label="Section-Header"> <h2><u>CONTROL PANEL – FUSES &amp; LAMPS</u></h2> </div> <div data-bbox="106 996 1139 1136" data-label="List-Group"> <ul style="list-style-type: none"> <li>• Confirm Fuse ratings &amp; continuity</li> <li>• Verify LED operation</li> </ul> </div>			
		(F) <b>Transponders</b>	Table 14.4.5(1f)
		(G) <b>Trouble Signals</b> : (a) Verify Audible and visual Operation & ring-back feature for systems using a trouble-silencing switch that requires resetting. (b) Test each Disconnect switches (if any) for performance of intended function & receipt of trouble signal when a supervised function is disconnected (c) Verify indication of Ground-fault monitoring (if any) by grounding any conductor location	Table 14.4.5(9) Method: Table 14.4.2.2(10)



# 1. BASICS

	terminals	
	<b>(3) Transient Suppressors</b> - (A) Visual - per mfr recommendations & after any lightning strike	Table 14.3.1(4) Method: Table 14.4.2.2(9)
	<b>(4) Control Panels - Test</b> - (A) <b>Verify Functions</b> (a) correct receipt of alarm, supervisory, and trouble signals (inputs) (b) operation of evacuation signals and auxiliary functions (outputs) (c) circuit supervision, including detection of open	Table 14.4.5(1a) Method: Table 14.4.2.2(1a)
<h2><u>CONTROL PANEL – PRIMARY POWER</u></h2> <ul style="list-style-type: none"> <li>Disconnect battery &amp; test load</li> </ul>		
	(B) <b>Fuses</b> - Verify rating & Supervision. Remove from receptacle & confirm operation with a continuity tester	Table 14.4.5(1b) Method: Table 14.4.2.2(1b)
	(C) <b>Lamps</b> LEDs - Illuminated	Table 14.4.5(1d)
	(D) <b>Primary Power Supplies</b> - (a) Disconnect all secondary power; (b) Test under maximum load (including all alarm appliances requiring simultaneous operation)	Table 14.4.5(1e) Method: Table 14.4.2.2(1e)
	(E) <b>Secondary Power Supplies</b> - (a) Disconnect all primary power; (b) Verify trouble signal for loss of primary power; (c) Measure standby and alarm current demand & verify vs mfr data to meet standby and alarm requirements; (d) Operate general alarm systems for min 5 minutes; (e) Operate emerg voice comm sys min 15 minutes	Table 14.4.5(5) Method: Table 14.4.2.2(3)
	(F) <b>Transponders</b>	Table 14.4.5(1f)
	(G) <b>Trouble Signals</b> : (a) Verify Audible and visual Operation & ring-back feature for systems using a trouble-silencing switch that requires resetting. (b) Test each Disconnect switches (if any) for performance of intended function & receipt of trouble signal when a supervised function is disconnected (c) Verify indication of Ground-fault monitoring (if any) by grounding any conductor location	Table 14.4.5(9) Method: Table 14.4.2.2(10)

# 1. BASICS

	terminals	
	<b>(3) Transient Suppressors</b> - (A) Visual - per mfr recommendations & after any lightning strike	Table 14.3.1(4) Method: Table 14.4.2.2(9)
	<b>(4) Control Panels - Test</b> - (A) <b>Verify Functions</b> (a) correct receipt of alarm, supervisory, and trouble signals (inputs) (b) operation of evacuation signals and auxiliary functions (outputs) (c) circuit supervision, including detection of open	Table 14.4.5(1a) Method: Table 14.4.2.2(1a)
<div style="border: 2px solid black; padding: 10px; text-align: center;"> <h2><u>CONTROL PANEL – SECONDARY POWER</u></h2> <ul style="list-style-type: none"> <li>• Disconnect primary &amp; verify trouble signal</li> <li>• Measure currents</li> <li>• Operate general alarm for 5 min</li> <li>• Operate emergency voice for 15 min</li> </ul> </div>		
	under maximum load (including all alarm appliances requiring simultaneous operation)	14.4.2.2(1e)
	(E) <b>Secondary Power Supplies</b> - (a) Disconnect all primary power; (b) Verify trouble signal for loss of primary power; (c) Measure standby and alarm current demand & verify vs mfr data to meet standby and alarm requirements; (d) Operate general alarm systems for min 5 minutes; (e) Operate emerg voice comm sys min 15 minutes	Table 14.4.5(5) Method: Table 14.4.2.2(3)
	(F) <b>Transponders</b>	Table 14.4.5(1f)
	(G) <b>Trouble Signals:</b> (a) Verify Audible and visual Operation & ring-back feature for systems using a trouble-silencing switch that requires resetting. (b) Test each Disconnect switches (if any) for performance of intended function & receipt of trouble signal when a supervised function is disconnected (c) Verify indication of Ground-fault monitoring (if any) by grounding any conductor location	Table 14.4.5(9) Method: Table 14.4.2.2(10)



# 1. BASICS

## CONTROL PANEL – TRANSPONDERS & TROUBLE

- Verify Trouble Signals
- Test Disconnect Switches
- Verify Ground-Fault Monitoring
- Operate Initiating Devices & verify Alarm
- Operate Supervisory Device & verify signal

### (F) Transponders

(G) Trouble Signals: (a) Verify Audible and visual Operation & ring-back feature for systems using a trouble-silencing switch that requires resetting.  
 (b) Test each Disconnect switches (if any) for performance of intended function & receipt of trouble signal when a supervised function is disconnected  
 (c) Verify indication of Ground-fault monitoring (if any) by grounding any conductor location  
 (d) Activate an Initiating device and verify receipt of alarm signal at the off-premises location  
 (e) Create a trouble condition & verify receipt of trouble signal at the off-premises location  
 (f) Activate a supervisory device & verify receipt of supervisory signal at the off premises location  
 (g) If a transmission carrier is capable of operation under a single- or multiple-fault condition, Activate an initiating device during a fault condition & verify receipt of both a trouble and alarm signal at the off-premises location

Table 14.4.5(1f)

Table 14.4.5(9)  
Method: Table  
14.4.2.2(10)

# 1. BASICS

NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2014
		<b>(5) Batteries</b>	
		<b>If Lead-Acid:</b> (A) <b>Charger Test</b> - (1) With the batteries fully charged and connected to the charger, measure voltage across the batteries (2) Verify voltage is min 2.30 volts per cell $\pm 0.02$ volts at 77°F or per mfr	NFPA 72-2010, Table 14.4.5(6a)(1) Method: Table 14.4.2.2(6b)1
		<b>if Sealed Lead Acid:</b> (A) <b>Charger Test</b> - (1) With the batteries fully charged and connected to the charger, measure voltage across the batteries; (2) Verify voltage is 2.30 volts per cell $\pm 0.02$ volts at 77°F or per mfr	NFPA 72-2010, Table 14.4.5(6d)(1) Method: Table 14.4.2.2(6d)1
		(B) <b>Discharge Test</b> (30 min) - (1) Disconnect charger; (2) Load test per mfr; (3) Voltage remains above mfr recommendation	NFPA 72-2010, Table 14.4.5(6d)(2) Method: Table 14.4.2.2(6d)
		<b>(6) Special Procedures</b> - (A) Alarm verification - Verify Time delay and alarm response for smoke detector circuits	Table 14.4.5(23) Method: Table 14.4.2.2(23)
<div style="border: 2px solid black; padding: 10px; text-align: center;"> <h2><u>BATTERIES</u></h2> <ul style="list-style-type: none"> <li>Charger &amp; Discharge Test – Depends on type Battery</li> </ul> </div>			
		<b>(8) Initiating Devices:</b>	
		(A) <b>Manual Fire Alarm Boxes</b>	Table 14.4.5(15f)
		(B) <b>Smoke Detectors</b> (Functional Test) - per mfr instr; Smoke must enter sensing chamber & activate alarm	Table 14.4.5(15h) Method: Table 14.4.2.2(14g)
		(C) <b>Smoke Alarms</b> - per mgr recommendation	Table 14.4.5(15j)
		(D) <b>Duct Detectors</b> - per mfr recommendation; (a) Smoke must enter sensing chamber & activate alarm; (b) Duct detectors with sampling tubes must verify the	Table 14.4.5(15a) Method: Table 14.4.2.2(15a)

# 1. BASICS

NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL	NFPA CODE NFPA 72-2011
		<b>(5) Batteries</b>	
		<b>If Lead-Acid:</b> (A) <b>Charger Test</b> - (1) With the batteries fully charged and connected to the charger, measure voltage across the batteries (2) Verify voltage is min 2.30 volts per cell $\pm 0.02$ volts at 77°F or per mfr	NFPA 72-2010, Table 14.4.5(6a)(1) Method: Table 14.4.2.2(6b)1
		<b>if Sealed Lead Acid:</b> (A) <b>Charger Test</b> - (1) With the batteries fully charged and connected to the charger, measure voltage across the batteries; (2) Verify voltage is 2.30 volts per cell $\pm 0.02$ volts at 77°F or per mfr	NFPA 72-2010, Table 14.4.5(6d)(1) Method: Table 14.4.2.2(6d)1
		(B) <b>Discharge Test</b> (30 min) - (1) Disconnect charger; (2) Load test per mfr; (3) Voltage remains above mfr recommendation	NFPA 72-2010, Table 14.4.5(6d)(2) Method: Table 14.4.2.2(6d)
		<b>(6) Special Procedures</b> - (A) Alarm verification - Verify Time delay and alarm response for smoke detector circuits	Table 14.4.5(23) Method: Table 14.4.2.2(25a)
		<b>(7) Supervisory Station Transmitter - Test</b> - per mfr instructions; (A) Actuate Initiating device & verify receipt within 90 sec of the correct initiating device signal at the supervising station	Table 14.4.5(22) Method: Table 14.4.2.2(18)
		<b>(8) Initiating Devices:</b>	
		(A) <b>Manual Fire Alarm Boxes</b>	Table 14.4.5(15f)
<b><u>SPECIAL PROCEDURES</u></b>			5(15h) Table 14g) 5(15j) 5(15a)
<ul style="list-style-type: none"> <li>Verify Time Delay &amp; Smoke Detector Response</li> </ul>			Method: Table
		(B) <b>Duct Detectors</b> - per mfr recommendation; (a) Smoke must enter sensing chamber & activate alarm; (b) Duct detectors with sampling tubes must verify the	



# 1. BASICS

NOT ON FORM	ON FORM	4. <u>FIRE ALARM - ANNUAL</u>	NFPA CODE NFPA 72-2011
		<b>(5) Batteries</b>	
		<b>If Lead-Acid:</b> (A) <b>Charger Test</b> - (1) With the batteries fully charged and connected to the charger, measure voltage across the batteries (2) Verify voltage is min 2.30 volts per cell $\pm 0.02$ volts at 77°F or per mfr	NFPA 72-2010, Table 14.4.5(6a)(1) Method: Table 14.4.2.2(6b)1
		<b>if Sealed Lead Acid:</b> (A) <b>Charger Test</b> - (1) With the batteries fully charged and connected to the charger, measure voltage across the batteries; (2) Verify voltage is 2.30 volts per cell $\pm 0.02$ volts at 77°F or per mfr	NFPA 72-2010, Table 14.4.5(6d)(1) Method: Table 14.4.2.2(6d)1
		(B) <b>Discharge Test</b> (30 min) - (1) Disconnect charger; (2) Load test per mfr; (3) Voltage remains above mfr recommendation	NFPA 72-2010, Table 14.4.5(6d)(2) Method: Table 14.4.2.2(6d)
		<b>(6) Special Procedures</b> - (A) Alarm verification - Verify Time delay and alarm response for smoke detector circuits	Table 14.4.5(23) Method: Table 14.4.2.2(25a)
		<b>(7) Supervisory Station Transmitter - Test</b> - per mfr instructions; (A) Actuate Initiating device & verify receipt within 90 sec of the correct initiating device signal at the supervising station	Table 14.4.5(22) Method: Table 14.4.2.2(18)
		<b>(8) Initiating Devices:</b>	
		(A) <b>Manual Fire Alarm Boxes</b>	Table 14.4.5(15f)
<b><u>TRANSMITTER</u></b>			5(15h) Table 14g) 5(15j) 5(15a)
<ul style="list-style-type: none"> <li>Verify 90 sec Receipt of alarm at Monitoring Sta</li> </ul>			Method: Table
		(B) <b>Duct Detectors</b> - per mfr recommendation; (a) Smoke must enter sensing chamber & activate alarm; (b) Duct detectors with sampling tubes must verify the	

# 1. BASICS

## INITIATING DEVICES

- Functional Test per Mfr Recommendations

Initiating device & verify receipt within 90 sec of the correct initiating device signal at the supervising station	Method: Table 14.4.2.2(18)
---	----------------------------

### (8) Initiating Devices:

(A) Manual Fire Alarm Boxes

Table 14.4.5(15f)

(B) Smoke Detectors (Functional Test) - per mfr instr; Smoke must enter sensing chamber & activate alarm

Table 14.4.5(15h)  
Method: Table 14.4.2.2(14g)

(C) Smoke Alarms - per mgr recommendation

Table 14.4.5(15j)

(D) Duct Detectors - per mfr recommendation; (a) Smoke must enter sensing chamber & activate alarm; (b) Duct detectors with sampling tubes must verify the correct pressure differential between the inlet and exhaust tubes is per mfr recommendation

Table 14.4.5(15a)  
Method: Table 14.4.2.2(14g)(6)

(E) Heat Alarms - per mgr recommendation

Table 14.4.5(15k)

(F) Heat Detectors - per mfr recommendations

Table 14.4.5(15e)

(G) Radiant Energy Fire Detectors - per mfr recommendations

Table 14.4.5(15g)  
Method: Table 14.4.2.2(14f)

(H) ElectroMech Release Devices - Remove fusible link & verify operation of the device. Lube any moving parts as necessary

Table 14.4.5(15b)  
Method: Table 14.4.2.2(14a)

(I) Supression Switches - Mechanically or electrically operate supression sys switch & Verify ecept of signal by the fire alarm control unit

Table 14.4.5(15c)  
Method: Table 14.4.2.2(14h)

### (9) Notification Appliance Tests

(A) Audible Bells, Horns, Chimes in areas with building, system, or

Table 14.4.5(20)  
Method: Table



# 1. BASICS

(C) <u>Smoke Alarms</u> - per mgr recommendation	Table 14.4.5(15j)
(D) <u>Duct Detectors</u> - per mfr recommendation; (a) Smoke must enter sensing chamber & activate alarm; (b) Duct detectors with sampling tubes must verify the correct pressure differential between the inlet and exhaust tubes is per mfr recommendation	Table 14.4.5(15a) Method: Table 14.4.2.2(14g)(6)
(E) <u>Heat Alarms</u> - per mgr recommendation	Table 14.4.5(15k)
(F) <u>Heat Detectors</u> - per mfr recommendations	Table 14.4.5(15e)
(G) <u>Radiant Energy Fire Detectors</u> - per mfr recommendations	Table 14.4.5(15g) Method: Table

## NOTIFICATION APPLIANCES

- Functional Test per Mfr Recommendations

(F) <u>Suppression Switches</u> - Mechanically or electrically operate suppression system switch & Verify receipt of signal by the fire alarm control unit	Table 14.4.5(15c) Method: Table 14.4.2.2(14h)
--	--

### (9) Notification Appliance Tests

(A) <u>Audible Bells, Horns, Chimes</u> in areas with building, system, or occupancy changes - (a) Measure sound pressure levels per requirements in Chapter 18 (using a sound level meter meeting ANSI S1.4a, Type 2, using the time-weighted characteristic F)	Table 14.4.5(20) Method: Table 14.4.2.2(15a)
(B) <u>Visual Strobes</u> - (a) Loc per approved layout; (b) No floor plan changes affect the approved layout; (c) Verify candela rating agrees with the approved drawing; (d) Confirm appliance flashes	Table 14.4.5(20) Method: Table 14.4.2.2(15c)
(C) <u>Voice Speakers</u> - (a) Test same as Audible; (b) Verify message is distinguishable and understandable	Table 14.4.5(20) Method: Table 14.4.2.2(15b)

## 2. “IFs”

### 16 SUPPLIMENTAL CHECKPOINTS

The 2nd part of the inspection depends on what extra items are installed on the fire alarm sys, such as

- Remote annunciators
- Mass notification sys
- Supervisory Devices
- Voice alarm sys
- Multiplex sys
- Extinguisher/Exit Sign monitoring
- Carbon monoxide sys
- Interface devices

Best to have a place to check “Not Applicable” if not installed on the system. These items should never be left off the form, even if there are none in the building.

## 2. "IFs"

NOT APPLIC			NOT ON FORM			ON FORM		
4. FIRE ALARM - ANNUAL (Continued)								
11) Remote Annunciators - Test - (A) Verify correct operation and identification of annunciators & correct operation under a fault condition						NFPA CODE NFPA 72-2011 Table 14.4.5(14) Method: Table 14.4.2.2(11)		TJC STD LS 02.01.34 EP 04
12) Mass Notification Sys-Visual (supervised) (if any)						Table 14.3.1(19)		LS 02.01.34 EP 04
(A) Mass No								21) LS 02.01.34 EP 04
(B) Mass No								22) LS 02.01.34 EP 04
13) Mass Not								
(A) Verify inp								19) LS 02.01.34 EP 04
signals;								
(B) Outputs c								
(C) circuit su								
(D) power su								
of secondary								
(E) Fuses, la								
control unit p								
14) Superviso								LS 02.01.34 EP 04
(A) Fire Pum								7)
starts								
(B) Generato								LS 02.01.34 EP 04
generator sta								7)
15) Voice/Ala								
(A) Operate								26) LS 02.01.34 EP 04
(B) Install Ph								le
unit;								)
(C) Visually i								
(D) Activated								
(E) Verify sys performance with min of 5 handsets simultaneously; (F) Verify Voice quality and clarity								
16) Special Procedures - Multiplex verification -						Table 14.4.5(23) Method: Table		LS 02.01.34 EP 04

### YOUR EVALUATION

Mark how your form complies with the code for EACH code requirement

↑
↑
↑

Mark One Box for Each Check Point

**NOTE:** If marked Not Applicable, it should STILL be on the form (best with a NA check box)

2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL (Continued)	NFPA CODE NFPA 72-2014
			<b>(11) Remote Annunciators - Test</b> - (A) Verify correct operation and identification of annunciators & correct operation under a fault condition	Table 14.4.5(14) Method: Table 14.4.2.2(11)
			<b>(12) Mass Notification Sys-Visual (supervised)</b> (if any)	Table 14.3.1(19)
			(A) Mass Notification Antenna (If any) - Visual	Table 14.3.1(21)
			(B) Mass Notification Transceivers (If any) - Visual	Table 14.3.1(22)
			<b>(13) Mass Notification Sys-Test (supervised)</b> (if any)	
			(A) Verify input control equip correctly receives alarm, supervisory & trouble signals;	Table 14.3.1(19) Method: Table 14.4.2.2(27)
<div> <b><u>IF HAVE REMOTE ANNUNCIATORS</u></b> <ul style="list-style-type: none"> <li>Verify Operation under Normal &amp; Fault Conditions</li> </ul> </div>				
			control unit properly operates	
			<b>(14) Supervisory Device Tests -</b>	Table 14.4.5(15)(7)
			(A) <b>Fire Pump Alarm</b> (if any) - Verify supervisory signal received when pump starts	
			(B) <b>Generator Alarms</b> (if any) - Verify supervisory signal received when generator starts	Table 14.4.5(15)(7)
			<b>(15) Voice/Alarm Communication Equip</b>	
			(A) Operate Call-in; Verify receipt of correct visual/audible signal; (B) Install Phone set or remove from hook; Verify receipt of signal at control unit; (C) Visually inspect Phone jack; (D) Activated Phone set & verify correct operation; (E) Verify sys performance with min of 5 handsets simultaneously; (F) Verify Voice quality and clarity	Table 14.4.5(26) Method: Table 14.4.2.2(20)
			<b>(16) Special Procedures</b> - Multiplex verification - (a) Verify comm between sending & receiving units under both primary &	Table 14.4.5(23) Method: Table 14.4.2.2(25b)



## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL (Continued)	NFPA CODE NFPA 72-2011
			(11) <b>Remote Annunciators - Test</b> - (A) Verify correct operation and identification of annunciators & correct operation under a fault condition	Table 14.4.5(14) Method: Table 14.4.2.2(11)
			(12) <b>Mass Notification Sys-Visual (supervised)</b> (if any)	Table 14.3.1(19)
			(A) Mass Notification Antenna (If any) - Visual	Table 14.3.1(21)
			(B) Mass Notification Transceivers (If any) - Visual	Table 14.3.1(22)
			(13) <b>Mass Notification Sys-Test (supervised)</b> (if any)	
			(A) Verify input control equip correctly receives alarm, supervisory & trouble signals;	Table 14.3.1(19) Method: Table 14.4.2.2(27)
			(B) Outputs operate evac signals & aux functions;	
			(C) circuit supervision, including detection of open circuits & ground faults;	
			(D) power supply supervision for detection of loss of ac power & disconnection of secondary batteries;	
			(E) Fuses, lamps, power supplies, interface equip, notification devices & control unit properly operates	
			(14) <b>Supervisory Device Tests -</b>	Table 14.4.5(15)(7)
<div> <h3><u>IF HAVE MASS NOTIFICATION</u></h3> <ul style="list-style-type: none"> <li>Visual check of Antenna &amp; Transceivers</li> <li>Test Inputs &amp; Outputs, Supervision, Lamps, Etc</li> </ul> </div>				
			unit;	Table 14.4.2.2(20)
			(C) Visually inspect Phone jack;	
			(D) Activated Phone set & verify correct operation;	
			(E) Verify sys performance with min of 5 handsets simultaneously; (F) Verify Voice quality and clarity	
			(16) <b>Special Procedures</b> - Multiplex verification -	Table 14.4.5(23) Method: Table 14.4.2.2(25b)
			(a) Verify comm between sending & receiving units under both primary &	



## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL (Continued)	NFPA CODE NFPA 72-2011
			(11) <b>Remote Annunciators - Test</b> - (A) Verify correct operation and identification of annunciators & correct operation under a fault condition	Table 14.4.5(14) Method: Table 14.4.2.2(11)
			(12) <b>Mass Notification Sys-Visual (supervised)</b> (if any)	Table 14.3.1(19)
			(A) Mass Notification Antenna (If any) - Visual	Table 14.3.1(21)
			(B) Mass Notification Transceivers (If any) - Visual	Table 14.3.1(22)
			(13) <b>Mass Notification Sys-Test (supervised)</b> (if any)	
<div> <h3><u>IF HAVE SUPERVISORY DEVICES</u></h3> <ul style="list-style-type: none"> <li>Verify signal when fire pump/generator starts</li> </ul> </div>				
			of secondary batteries; (E) Fuses, lamps, power supplies, interface equip, notification devices & control unit properly operates	
			(14) <b>Supervisory Device Tests -</b>	Table 14.4.5(15)(7)
			(A) <b>Fire Pump Alarm</b> (if any) - Verify supervisory signal received when pump starts	
			(B) <b>Generator Alarms</b> (if any) - Verify supervisory signal received when generator starts	Table 14.4.5(15)(7)
			(15) <b>Voice/Alarm Communication Equip</b>	
			(A) Operate Call-in; Verify receipt of correct visual/audible signal; (B) Install Phone set or remove from hook; Verify receipt of signal at control unit; (C) Visually inspect Phone jack; (D) Activated Phone set & verify correct operation; (E) Verify sys performance with min of 5 handsets simultaneously; (F) Verify Voice quality and clarity	Table 14.4.5(26) Method: Table 14.4.2.2(20)
			(16) <b>Special Procedures</b> - Multiplex verification - (a) Verify comm between sending & receiving units under both primary &	Table 14.4.5(23) Method: Table 14.4.2.2(25b)

## 2. "IFs"

NOT APPLIC	NOT ON FORM	ON FORM	4. FIRE ALARM - ANNUAL (Continued)	NFPA CODE NFPA 72-2011
			(11) <b>Remote Annunciators - Test</b> - (A) Verify correct operation and identification of annunciators & correct operation under a fault condition	Table 14.4.5(14) Method: Table 14.4.2.2(11)
			(12) <b>Mass Notification Sys-Visual (supervised)</b> (if any)	Table 14.3.1(19)
			(A) Mass Notification Antenna (If any) - Visual	Table 14.3.1(21)
			(B) Mass Notification Transceivers (If any) - Visual	Table 14.3.1(22)
			(13) <b>Mass Notification Sys-Test (supervised)</b> (if any)	
<div style="border: 2px solid black; padding: 10px;"> <p style="text-align: center;"><b><u>IF HAVE VOICE/ALARM COMMUNICATION</u></b></p> <ul style="list-style-type: none"> <li>• Verify phone signal &amp; operation</li> <li>• Verify performance w/5 handsets simultaneously</li> <li>• Verify voice quality &amp; clarity</li> </ul> </div>				
			(A) <b>Fire Pump Alarm</b> (if any) - Verify supervisory signal received when pump starts	14.4.5(15)(7)
			(B) <b>Generator Alarms</b> (if any) - Verify supervisory signal received when generator starts	Table 14.4.5(15)(7)
			<b>(15) Voice/Alarm Communication Equip</b>	
			(A) Operate Call-in; Verify receipt of correct visual/audible signal; (B) Install Phone set or remove from hook; Verify receipt of signal at control unit; (C) Visually inspect Phone jack; (D) Activated Phone set & verify correct operation; (E) Verify sys performance with min of 5 handsets simultaneously; (F) Verify Voice quality and clarity	Table 14.4.5(26) Method: Table 14.4.2.2(20)
			<b>(16) Special Procedures</b> - Multiplex verification - (a) Verify comm between sending & receiving units under both primary &	Table 14.4.5(25) Method: Table 14.4.2.2(25b)

(12) Mass Notification Sys-Visual (supervised) (if any)

14.4.2.2(11)  
Table 14.3.1(19)

(A) Mass Notification Antenna (If any) - Visual

Table 14.3.1(21)

## 2. "IFs"

Receivers (If any) - Visual

Table 14.3.1(22)

Test (supervised) (if any)

(A) Verify input control equip correctly receives alarm, supervisory & trouble signals;

Table 14.3.1(19)  
Method: Table  
14.4.2.2(27)

(B) Outputs operate evac signals & aux functions;

(C) circuit supervision, including detection of open circuits & ground faults;

(D) power supply supervision for detection of loss of ac power & disconnection of secondary batteries;

(E) Fuses, lamps, power supplies, interface equip, notification devices & control unit properly operates

(14) Supervisory Device Tests -

Table  
14.4.5(15)(7)

(A) Fire Pump Alarm (if any) - Verify supervisory signal received when pump

## IF HAVE MULTIPLEX SIGNALS

- Verify operation with primary & secondary power
- Verify operation with open & short circuit conditions
- Verify operation per mfr instructions

(E) Verify sys performance with min of 5 handsets simultaneously; (F) Verify Voice quality and clarity

(16) Special Procedures - Multiplex verification -

Table 14.4.5(23)  
Method: Table  
14.4.2.2(25b)

(a) Verify comm between sending & receiving units under both primary & secondary power

(b) Verify comm between sending & receiving units under open circuit & short circuit trouble conditions

(c) Verify comm between sending & receiving units in all directions if there are multiple comm pathways

(d) Verify redundant central control equip (if any) switchover and required functions & operations of secondary control equipment

(e) Verify all system functions and features per mfr instructions



## 2. “IFs”

			<b>(17) Combination Sys - Test - (A) <u>Fire Extinguisher Electronic Monitoring</u></b> (if any) - Test proper signals are received at the fire alarm control	Table 14.4.5(17a) Method: Table 14.4.2.2(21)
--	--	--	---	---

			<b>(18) <u>Carbon Monoxide Detection Sys</u></b> (A) Visual on Control System & Fiber-Optic cable connection	Table 14.4.5(18b) NFPA 720-2011, Table 8.3.1
			(B) Tests: (1) Control equip, per Table item 1; (2) Sealed Lead Acids, Charger Test, Discharge Test, per Table Item 6c; (3) Fiber-Optic Cable Power per Table Item 11b; (4) Control Unit Trouble Signal per Table item 8; (5) Remote	Table 14.4.5(17b) NFPA 720-2011, Table 8.4.3

### **IF HAVE EXTINGUISHER MONITORING**

- Verify operation

			element (electronic checks not acceptable)	
			<b>(19) <u>Exit Marking Notif - Test</u></b> - (if any) Tests shall be performed in accordance with manufacturer's published instructions	Table 14.4.5(21) Table 14.4.2.2(16)
			<b>(20) <u>Interface Device Tests</u></b> - Includes: (a) simulated interface operation, b) check of wiring connections via simulated open & single ground to verify proper indication of wire integrity, and (c) check of supervisory via placing in simulated trouble condition to verify proper receipt & reaction at control unit	Table 14.4.2.2(1c) Method: Table 14.4.2.2(22)
			(A) <b><u>Pre-Action Operation</u></b> (if any) - operate or simulate equip being supervised & verify signal received at control unit	Method: Table 14.4.2.2(22)
			(B) <b><u>Dry Pipe Operation</u></b> (if any) - operate or simulate equip being supervised & verify signal received at control unit	Table 14.4.5(18) Method: Table 14.4.2.2(22)
			(C) <b><u>Clean Agent Operation</u></b> (if any) - operate or simulate equip being supervised & verify signal received at control unit	Table 14.4.5(18) Method: Table 14.4.2.2(22)
			(D) <b><u>Other Connections</u></b> to FA - operate or simulate equip being supervised & verify signal received at control unit	Table 14.4.5(18) Method: Table 14.4.2.2(22)
			(E) <b><u>Fire Pump</u></b> (if any) - operate or simulate equip being supervised & verify	Table 14.4.5(18)

## 2. "IFs"

			<b>(17) Combination Sys - Test - (A) <u>Fire Extinguisher Electronic Monitoring</u></b> (if any) - Test proper signals are received at the fire alarm control	Table 14.4.5(17a) Method: Table 14.4.2.2(21)
			<b>(18) <u>Carbon Monoxide Detection Sys</u></b> (A) Visual on Control System & Fiber-Optic cable connection	Table 14.3.1(11b) NFPA 720-2011, Table 8.3.1
			(B) Tests: (1) Control equip, per Table item 1; (2) Sealed Lead Acids, Charger Test, Discharge Test, per Table Item 6c; (3) Fiber-Optic Cable Power per Table Item 11b; (4) Control Unit Trouble Signal per Table item 8; (5) Remote Annunciator per Table item 9; (6) Initiating Devices per Table item 12; (7) Interface Equip per Table items 15,16; (8) Alarm Notification per Table item 13; (9) Special procedures per Table item 17. Note: Use NFPA 7-page example form 8.6.2.2 or equivalent	Table 14.4.5(17b) NFPA 720-2011, Table 8.4.3
			(C) Test Carbon Monoxide Detectors by introduction of CO into the sensor element (electronic checks not acceptable)	8.4.4.1
			<b>(19) <u>Exit Marking Notif - Test</u></b> - (if any) Tests shall be performed in accordance with manufacturer's published instructions	Table 14.4.5(21) Table 14.4.2.2(16)

### **IF HAVE CARBON MONOXIDE SYS**

- Verify operation, Batteries, Signals, Annunciator, Interface
- Test Detectors

(C) **Clean Agent Operation** (if any) - operate or simulate equip being supervised & verify signal received at control unit

Table 14.4.5(18)  
Method: Table 14.4.2.2(22)

(D) **Other Connections** to FA - operate or simulate equip being supervised & verify signal received at control unit

Table 14.4.5(18)  
Method: Table 14.4.2.2(22)

(E) **Fire Pump** (if any) - operate or simulate equip being supervised & verify

Table 14.4.5(18)



## 2. "IFs"

			<b>(17) Combination Sys - Test</b> - (A) <b><u>Fire Extinguisher Electronic Monitoring</u></b> (if any) - Test proper signals are received at the fire alarm control	Table 14.4.5(17a) Method: Table 14.4.2.2(21)
			<b>(18) Carbon Monoxide Detection Sys</b> (A) Visual on Control System & Fiber-Optic cable connection	Table 14.3.1(11b) NFPA 720-2011, Table 8.3.1
			(B) Tests: (1) Control equip, per Table item 1; (2) Sealed Lead Acids, Charger Test, Discharge Test, per Table Item 6c; (3) Fiber-Optic Cable Power per Table Item 11b; (4) Control Unit Trouble Signal per Table item 8; (5) Remote Annunciator per Table item 9; (6) Initiating Devices per Table item 12; (7) Interface Equip per Table items 15,16; (8) Alarm Notification per Table item 13; (9) Special procedures per Table item 17. Note: Use NFPA 7-page example form 8.6.2.2 or equivalent	Table 14.4.5(17b) NFPA 720-2011, Table 8.4.3
			(C) Test Carbon Monoxide Detectors by introduction of CO into the sensor element (electronic checks not acceptable)	8.4.4.1
			<b>(19) Exit Marking Notif - Test</b> - (if any) Tests shall be performed in accordance with manufacturer's published instructions	Table 14.4.5(21) Table 14.4.2.2(16)
			<b>(20) Interface Device Tests</b> - Includes: (a) simulated interface operation, b) check of wiring connections via simulated open & single ground to verify proper indication of wire integrity, and (c) check of supervisory via placing in simulated trouble condition to verify proper receipt & reaction at control unit	Table 14.4.2.2(1c) Method: Table 14.4.2.2(22)
<div style="border: 2px solid black; padding: 10px; text-align: center;"> <h3><u>IF HAVE EXIT SIGN MONITORING</u></h3> <ul style="list-style-type: none"> <li>Verify operation per mfr instructions</li> </ul> </div>				
			(C) <b><u>Clean Agent Operation</u></b> (if any) - operate or simulate equip being supervised & verify signal received at control unit	Table 14.4.5(18) Method: Table 14.4.2.2(22)
			(D) <b><u>Other Connections</u></b> to FA - operate or simulate equip being supervised & verify signal received at control unit	Table 14.4.5(18) Method: Table 14.4.2.2(22)
			(E) <b><u>Fire Pump</u></b> (if any) - operate or simulate equip being supervised & verify	Table 14.4.5(18)

## 2. "IFs"

(B) Tests: (1) Control equip, per Table item 1; (2) Sealed Lead Acids, Charger

Table 14.4.5(17b)

### **IF HAVE INTERFACE DEVICES**

- Simulate operation & check supervisory signals
- For Dry Pipe, Preaction, Clean Agent, Fire Pump, Etc

element (electronic checks not acceptable)

**(19) Exit Marking Notif - Test** - (if any) Tests shall be performed in accordance with manufacturer's published instructions

Table 14.4.5(21)  
Table 14.4.2.2(16)

**(20) Interface Device Tests** - Includes: (a) simulated interface operation, b) check of wiring connections via simulated open & single ground to verify proper indication of wire integrity, and (c) check of supervisory via placing in simulated trouble condition to verify proper receipt & reaction at control unit

Table 14.4.2.2(1c)  
Method: Table 14.4.2.2(22)

(A) **Pre-Action Operation** (if any) - operate or simulate equip being supervised & verify signal received at control unit

Method: Table 14.4.2.2(22)

(B) **Dry Pipe Operation** (if any) - operate or simulate equip being supervised & verify signal received at control unit

Table 14.4.5(18)  
Method: Table 14.4.2.2(22)

(C) **Clean Agent Operation** (if any) - operate or simulate equip being supervised & verify signal received at control unit

Table 14.4.5(18)  
Method: Table 14.4.2.2(22)

(D) **Other Connections** to FA - operate or simulate equip being supervised & verify signal received at control unit

Table 14.4.5(18)  
Method: Table 14.4.2.2(22)

(E) **Fire Pump** (if any) - operate or simulate equip being supervised & verify signal received at alarm panel

Table 14.4.5(18)  
Method: Table

## 2. "IFs"

			<b>(21) Emergency Control Interface Tests</b>	Table 14.4.5(18)
			(A) Delayed Egress Release - operate or simulate equip being supervised & verify lock release	Method: Table 14.4.2.2(23)
			(B) Rolling Door Release - operate or simulate equip being supervised & verify door closure	Method: Table 14.4.2.2(23)
			(C) Elevator Recall - operate or simulate equip being supervised & verify elevator recall	Method: Table 14.4.2.2(23)
			(D) Elevator Power Shunt Trip - operate or simulate equip being supervised & verify elevator shutdown	Method: Table 14.4.2.2(23)
			(E) Smoke Control (if any) - operate or simulate equip being supervised & verify activation of smoke control sequence	Method: Table 14.4.2.2(23)

**(22) Special Hazard Equip Test** - Abort Switches (if any) - Operate Abort Switch

Table 14.4.5(19)

### **IF HAVE EMERGENCY INTERFACE DEVICES**

- Simulate operation & check supervisory signals
- For Delayed Egress, Rolling Door Release, Elevator Recall, Smoke Control, Etc

circuits and signals



## 2. “IFs”

			<b>(21) Emergency Control Interface Tests</b>	Table 14.4.5(18)
			(A) Delayed Egress Release - operate or simulate equip being supervised & verify lock release	Method: Table 14.4.2.2(23)
			(B) Rolling Door Release - operate or simulate equip being supervised & verify door closure	Method: Table 14.4.2.2(23)
			(C) Elevator Recall - operate or simulate equip being supervised & verify elevator recall	Method: Table 14.4.2.2(23)
			(D) Elevator Power Shunt Trip - operate or simulate equip being supervised & verify elevator shutdown	Method: Table 14.4.2.2(23)
			(E) Smoke Control (if any) - operate or simulate equip being supervised & verify activation of smoke control sequence	Method: Table 14.4.2.2(23)
			<b>(22) Special Hazard Equip Test</b> - Abort Switches (if any) - Operate Abort switch & verify correct sequence and operation	Table 14.4.5(19) Method: Table 14.4.2.2(17)
			<b>(23) Fiber-Optic Cable Connections - Visual</b>	Table 14.3.1(6)
			<b>(24) Fiber-Optic Cable - Test</b> - Measure & record the relative power loss of the line per mfr instructions with an optical power meter or an optical time domain reflectometer; Repairs needed if power level drops 2% or more from the value recorded during the initial acceptance test	Table 14.4.5(8) Method: Table 14.4.2.2(13b)
			<b>(25) Hyperbaric Chamber Fire detection equipment shall be fully tested</b>	NEPA 99-20102,

## IF HAVE SPECIAL HAZARD EQUIP

- Operate Abort Switch & check correct operation

## 2. "IFs"

### (21) Emergency Control Interface Tests

Table 14.4.5(18)

(A) Delayed Egress Release - operate or simulate equip being supervised & verify lock release

Method: Table 14.4.2.2(23)

(B) Rolling Door Release - operate or simulate equip being supervised & verify door closure

Method: Table 14.4.2.2(23)

(C) Elevator Recall - operate or simulate equip being supervised & verify

Method: Table

### IF HAVE FIBER-OPTIC CABLES

- Visually inspect connections
- Test power loss

& verify correct sequence and operation

14.4.2.2(17)

### (23) Fiber-Optic Cable Connections - Visual

Table 14.3.1(6)

(24) Fiber-Optic Cable - Test - Measure & record the relative power loss of the line per mfr instructions with an optical power meter or an optical time domain reflectometer; Repairs needed if power level drops 2% or more from the value recorded during the initial acceptance test

Table 14.4.5(8)  
Method: Table 14.4.2.2(13b)

(25) Hyperbaric Chamber Fire detection equipment shall be fully tested annually, including discharge of extinguishing media and activation of trouble circuits and signals

NFPA 99-20102,  
§14.3.6.3.2



## 2. "IFs"

### (21) Emergency Control Interface Tests

Table 14.4.5(18)

(A) Delayed Egress Release - operate or simulate equip being supervised & verify lock release

Method: Table 14.4.2.2(23)

(B) Rolling Door Release - operate or simulate equip being supervised & verify door closure

Method: Table 14.4.2.2(23)

(C) Elevator Recall - operate or simulate equip being supervised & verify elevator recall

Method: Table 14.4.2.2(23)

(D) Elevator Power Shunt Trip - operate or simulate equip being supervised & verify elevator shutdown

Method: Table 14.4.2.2(23)

### IF HAVE HYPERBARIC CHAMBER

- Discharge media & verify operation
- Test trouble signals

line per min instructions with an optical power meter or an optical time domain reflectometer; Repairs needed if power level drops 2% or more from the value recorded during the initial acceptance test

Method: Table 14.4.2.2(13b)

**(25) Hyperbaric Chamber Fire detection equipment** shall be fully tested annually, including discharge of extinguishing media and activation of trouble circuits and signals

NFPA 99-20102, §14.3.6.3.2

# Annual Fire A Doc Review

ALL CHECK POINTS ON THIS LIST MUST BE ON A VALID FORM

Report Title:	Date of Report:
NOT ON FORM	ON FORM
4. FIRE ALARM - ANNUAL	
NFPA CODE	TJC STD

WHOOF !  
That was a  
long one

ed if present, but form should have space to indicate that item is not present, i.e. not applicable		
4. FIRE ALARM - ANNUAL (Continued)		
	NFPA CODE NFPA 72-2011	TJC STD
Annunciators - Test - (A) Verify correct operation and identification of annunciators & correct operation under a fault condition	Table 14.4.5(14) Method: Table 14.4.2.2(11)	LS 02.01.34 EP 04
Notification Sys-Visual (supervised) (if any)	Table 14.3.1(19)	LS 02.01.34 EP 04
Notification Antenna (If any) - Visual	Table 14.3.1(21)	LS 02.01.34 EP 04
Notification Transceivers (If any) - Visual	Table 14.3.1(22)	LS 02.01.34 EP 04
Notification Sys-Test (supervised) (if any)		
input control equip correctly receives alarm, supervisory & trouble	Table 14.3.1(19) Method: Table 14.4.2.2(27)	LS 02.01.34 EP 04
its operate evac signals & aux functions;		
t supervision, including detection of open circuits & ground faults;		
supply supervision for detection of loss of ac power & disconnection		
ary batteries;		
s, lamps, power supplies, interface equip, notification devices &		
nit properly operates		
visory Device Tests -		LS 02.01.34 EP 04
ump Alarm (if any) - Verify supervisory signal received upon pump	Table 14.4.5(15)(7)	



NOT ON FORM	ON FORM			
		(5) B		
		If Le		
		conn		
		is mi		
		If Se		
		conn		
		volt		
		(B) Discharge Test (30 min) - (1) Disconnect charger, (2) Load test per mfr; (3) Voltage remains above mfr recommendation	NFPA 72-2011, Table 14.4.5(6d)(2) Method: Table 14.4.2.2(6d)	LS 02.01.34 EP 04
		(6) Special Procedures - (A) Alarm verification - Verify Time delay and alarm response for smoke detector circuits	Table 14.4.5(23) Method: Table 14.4.2.2(25a)	LS 02.01.34 EP 04
		(7) Supervisory Station Transmitter - Test - per mfr instructions; (A) Actuate Initiating device & verify receipt within 90 sec of the correct initiating device signal at the supervising station	Table 14.4.5(22) Method: Table 14.4.2.2(18)	LS 02.01.34 EP 04
		(8) Initiating Devices:		
		(A) Manual Fire Alarm Boxes	Table 14.4.5(15f)	EC 02.03.05 EP 03
		(B) Smoke Detectors (Functional Test) - per mfr instr; Smoke must enter sensing chamber & activate alarm	Table 14.4.5(15h) Method: Table 14.4.2.2(14g)	EC 02.03.05 EP 03
		(C) Smoke Alarms - per mgr recommendation	Table 14.4.5(15j)	EC 02.03.05 EP 03
		(D) Duct Detectors - per mgr recommendation; (a) Smoke must enter sensing chamber & activate alarm; (b) Duct detectors with sampling tubes must verify the correct pressure differential between the inlet and exhaust tubes is per mfr recommendation	Table 14.4.5(15a) Method: Table 14.4.2.2(14g)(6)	EC 02.03.05 EP 03
		(E) Heat Alarms - per mgr recommendation	Table 14.4.5(15k)	EC 02.03.05 EP 03
		(F) Heat Detectors - per mfr recommendations	Table 14.4.5(15e)	EC 02.03.05 EP 03
		(G) Radiant Energy Fire Detectors - per mfr recommendations	Table 14.4.5(15g) Method: Table 14.4.2.2(14f)	EC 02.03.05 EP 03
		(H) ElectroMech Release Devices - Remove fusible link & verify operation of the device. Lube any moving parts as necessary	Table 14.4.5(15b) Method: Table 14.4.2.2(14a)	EC 02.03.05 EP 03
		(I) Supression Switches - Mechanically or electrically operate supression sys switch & Verify receipt of signal by the fire alarm control unit	Table 14.4.5(15c) Method: Table 14.4.2.2(14b)	EC 02.03.05 EP 03
		(9) Notification Appliance Tests		
		(A) Audible Bells, Horns, Chimes in areas with building, system, or occupancy changes - (a) Measure sound pressure levels per requirements in Chapter 18 (using a sound level meter meeting ANSI S1.4a, Type 2, using the time-weighted characteristic F)	Table 14.4.5(20) Method: Table 14.4.2.2(15a)	EC 02.03.05 EP 04
		(B) Visual Strobes - (a) Loc per approved layout; (b) No floor plan changes	Table 14.4.5(20) Method: Table 14.4.2.2(15b)	EC 02.03.05 EP 04

		(D) Other Connections to FA - operate or simulate equip being supervised & verify signal received at control unit	Table 14.4.5(18) Method: Table 14.4.2.2(22)	LS 02.01.34 EP 04
		(E) Fire Pump (if any) - operate or simulate equip being supervised & verify signal received at alarm panel	Table 14.4.5(18) Method: Table 14.4.2.2(22)	LS 02.01.34 EP 04
		(21) Emergency Control Interface Tests	Table 14.4.5(18)	
		(A) Delayed Egress Release - operate or simulate equip being supervised & verify lock release	Method: Table 14.4.2.2(23)	LS 02.01.34 EP 04
		(B) Rolling Door Release - operate or simulate equip being supervised & verify door closure	Method: Table 14.4.2.2(23)	LS 02.01.34 EP 04
		(C) Elevator Recall - operate or simulate equip being supervised & verify	Method: Table	LS 02.01.34 EP 04



**TOOLS for REVIEW of**

# Inspection Documentation

1. REALITIES of Document Review
2. Document Review Concepts
3. The Report Tool Box
4. Evaluate The Big 5 Doc Forms