

Reducing Your Risk

Pete Paletta: *Senior Service Sales (Fire Sprinkler)*

Direct Line: 715.233.2428

Mobile: 715.308.3460

Email: ppaletta@jfahern.com

Sam Karoblis: *Service Manager*

Direct Line: 715.233.2457

Mobile: 715.409.6381

Email: skaroblis@jfahern.com

expert
technicians

one
visit

industry
leaders



**We've inspected
over 34,000
facilities in the last
18 months,** and have had
the ability to repair every
deficiency found.




- 16,000+ sprinkler inspections
- 2,500+ mechanical PM inspections
- 15,700+ fire extinguisher inspections

*****In Ahern's Northwest Region we have performed service work at 76% of the Hospitals listed in the DHS directory.**

WHEA Lunch and Learn

- Pre-inspection Preparations for NFPA 25 Inspections
- Frequency of NFPA Inspection and Requirements
- Building Owner Requirements
- Extended Interval Testing
- NFPA Sprinkler Head Testing



NFPA-25 2011 Edition

What is NFPA 25?

- **National Fire Protection Association (NFPA):**
is a United States trade association that creates and maintains private, copyrighted standards and codes for usage and adoption by local governments.
- **NFPA-25:**The standard for inspection, testing, and maintenance of water-based fire protection systems.

NFPA 25 Definitions

3.3.18 – Inspection: visual examination

3.3.35 – Testing: a procedure used to determine the operational status of a component or system.

3.2.4 – **Shall**: Indicates a mandatory requirement

3.2.5 – **Should**: Indicates a recommendation or that which is advised but not required.

Authority Having Jurisdiction

- 3.2.2 – Authority Having Jurisdiction – examples:
 - Fire department
 - Insurance company
 - State agency
 - Joint Commission

Pre-Inspection Preparation and Frequency of NFPA 25 Inspections and Requirements

- Observations & recommendations for efficient, less disruptive, comprehensive NFPA-25 inspections.

Quarterly
Or
Semi-annual
Or
Annual?

Quarterly/Semi-Annual

- Water flow Alarm Tests
- Valve Supervisory (tamper switch test)
- Other Supervisory Devices
- Main Drain Tests

Water flow alarm tests

Inspectors Test



Water flow alarm tests



Inspector's Test Connection

Main Drain Tests

- 13.2.5.2 Main Drain Tests
 - Pass/fail criteria:
 - Identify and correct a cause of 10% or greater reduction of full flow pressure **when compared with original acceptance test or previously performed tests.**

Main Drain Tests

- Main Drain Tests



Main Drain Tests



Main Drain Test Flowing

Planning Quarterly Inspections

- Best time to test alarms
- Coordinate monitoring of alarm signals
- Water flow:
 - Are test drains piped to floor drains?
 - Do any test drains require temporary hoses?
 - Are there sidewalks, landscaping or parked cars near an outside drain?

Annual

- Arrange for access to inspect & test
- Similar preparation for quarterly inspections
- Annual walk-thru inspection
- Other possible items
 - Fire pump test – water flow and alarm signals
 - Backflow preventer testing – water flow
 - Pressure reducing valves - water flow

Backflow Preventer Testing

- 13.6.2.1 Backflow Preventer Forward-Flow Testing
 - Only the flow rate should be measured, not the pressure.

Backflow Preventer Testing



5315 Freitag Drive
Menomonie, WI 54751-8908
800.481.8009

Calculation Riser Placard for AREA/DENSITY Designed Systems.

System Design Area: 2nd Floor - Remote Area 1

At: 222 Water Street - Any Town, Wisconsin

Contract No.: 123456 Print No.(s): FP - 6 Dated: 3/23/17

This system, as shown on J. F. Ahern Co. drawing, is designed for 19 sprinklers to discharge at a density of 0.10 GPM/SqFt over a minimum area of 947.50 SqFt when supplied with water at the rate of **241.58 GPM** at a pressure of 76.15 PSI at the connection point.

Occupancy Classification: Light Hazard

Commodity Classification: N/A

Inside Hose Stream added at base of riser: 0 GPM

Outside Hose Stream added at source: 100 GPM

Standard / Issue: NFPA 13, 2007 Edition

Antifreeze System Solution: N/A

Antifreeze System Capacity: N/A Gallons; N/A% Antifreeze

Storage Height (max.): N/A

Other Storage: N/A

System
Demand:
241.58 GPM

General Information	Yes	No
High Pile	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Rack Storage	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Hazardous Material	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Idle Pallets	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Flammable/Combustible Liquids	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solid Shelving	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Encapsulation	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Aisle Width (min.)	N/A	Feet

Sprinkler Head Quantity & Type:

Qty.	Make/Vendor	Model/Type	K-Factor	Temp.
13	Tyco	TY-FRB Upright TY2131	4.2	155° F
6	Tyco	TY-FRB Pendent TY2231	4.2	155° F

Backflow Preventer Testing

- Backflow Preventer Forward Flow Test



DC Backflow Assembly



BFP Forward Flow Through FDC

Cross Connection Performance Test



Cross Connection Control Performance Test

Industry Services Division
P.O. Box 7302
Madison, WI 53707-7302
Fax: (608) 267-9723
TTY: through Relay

NOTE: Registrations for all assemblies (except those located in health care facilities) along with all test reports can be done online for reduced fees at <http://dps.wi.gov/SB-PlumbingCcaTestsRegists.html>.

Regulated Object Number: _____

Personal information you provide may be used for secondary purposes [Privacy Law, s.1504 (1)(m)].

Owner Information		Please print clearly in ballpoint pen.	
Owner Name		Street Address	
City	State Zip Code	Owner's Contact Person	Telephone Number
Facility Information			
Facility Name		Street Address	
City	Zip Code	County	
Assembly Location		Assembly is Serving	
Manufacturer		Model	Serial Number
Size	Assembly Type	<input type="checkbox"/> RP	<input type="checkbox"/> RP Detector
		<input type="checkbox"/> PVB	<input type="checkbox"/> SRVB

Water Supply Source: Check One ☐ Municipal Water System ☐ Other than municipal, non-community or private water system. See NR 811 and 812 for definitions.

Initial Test		
RP relief valve	1 st check	2 nd check
Opened at _____ PSID	<input type="checkbox"/> Closed tight	<input type="checkbox"/> Closed tight
<input type="checkbox"/> Did not open	<input type="checkbox"/> Leaked	<input type="checkbox"/> Leaked
	Static _____ PSID	Static _____ PSID

FINAL TEST		
Opened at _____ PSID	<input type="checkbox"/> Closed tight	<input type="checkbox"/> Closed tight
	Static _____ PSID	Static _____ PSID

DETECTOR BYPASS ASSEMBLY INITIAL TEST		
RP relief valve	1 st check	2 nd check
Opened at _____ PSID	<input type="checkbox"/> Closed tight	<input type="checkbox"/> Closed tight
<input type="checkbox"/> Did not open	<input type="checkbox"/> Leaked	<input type="checkbox"/> Leaked
	Static _____ PSID	Static _____ PSID

DETECTOR BYPASS ASSEMBLY FINAL TEST		
Opened at _____ PSID	<input type="checkbox"/> Closed tight	<input type="checkbox"/> Closed tight
	Static _____ PSID	Static _____ PSID

PVB/SRVB INITIAL TEST		PVB/SRVB FINAL TEST	
Air inlet valve	Check valve	Air inlet valve	Check Valve
Opened at _____ PSID	<input type="checkbox"/> Closed tight	Opened at _____ PSID	<input type="checkbox"/> Closed tight
<input type="checkbox"/> Did not open	<input type="checkbox"/> Leaked		Static _____ PSID
	Static _____ PSID		

Assemblies in Fire Protection Systems		Note: Include hose stream demand where applicable
Forward Flow Test		
Designed flow rate _____ GPM	Actual flow rate _____ GPM	
Indicating Control Valves		
<input type="checkbox"/> No, one control valve open	<input type="checkbox"/> No, two control valve open	Valve supervision: <input type="checkbox"/> Tamper switch <input type="checkbox"/> Locked


Part (s) Replaced/Comments	Attach Check Here
Make Checks Payable to DSPS	
Total Amount Due \$30 Per Assembly	

I Hereby Certify the Test Results Are True and the Test Was Conducted by Me Personally.		
Tester Name (print)	Registration No.	Time of Day
Tester Signature	Phone No.	Date


Static _____ FSD _____	
Assemblies in Fire Protection Systems Note: Include hose stream demand where applicable	
<u>Forward Flow Test</u>	
Designed flow rate _____ GPM	Actual flow rate _____ GPM
<u>Indicating Control Valves</u>	
<input type="checkbox"/> No. one control valve open	<input type="checkbox"/> No. two control valve open
Valve supervision: <input type="checkbox"/> Tamper switch <input type="checkbox"/> Locked	
Part (s) Replaced/Comments _____	
Make Checks Payable to DSPS _____	
Total Amount Due \$30 Per Assembly _____	
I Hereby Certify the Test Results Are True and the Test Was Conducted by Me Personally.	
Tester Name (print) _____	Registration No. _____
Tester Signature _____	Phone No. _____
	Time of Day _____
	Date _____
SBD-9927 (R03/13)	Copies: Department, Testers, Owner, Water Purveyor
Revenue Code 7657	
<u>Owner Information</u>	

BFP Forward Flow Through FDC

Forward Flow Provisions



Forward Flow Provisions



Forward Flow Provisions



Annual Pump Test

- 8.3.5.3 Annual Pump Test
 - The pass/fail criteria
 - The test pressure at rated flow is within 95% of the initial certified field test curve.
 - The test pressure is within 95% of the performance characteristics on the pump nameplate.



Annual Fire Pump Tests

- Fire Pump Test



Electric Pump with Bypass



Fire Pump Test

Annual Fire Pump Tests



Fire Pump Test

Building Owner Requirements

- Accessibility 4.1.2
“The property owner or designated representative shall provide ready accessibility to components of water-based fire protection systems that require inspection, testing, and maintenance.”

Building Owner Requirements

- Accessibility 4.1.2 (cont'd)
- Access to valves, drain assemblies, devices

Accessibility



Accessibility



Building Owner Requirements

- Accessibility 4.1.2 (cont'd)
- Should an 'Access Plan' be established prior to the inspection?
 - More efficient, less disruptive inspection
 - More logical progression of inspection

Building Owner Requirements

- Accessibility 4.1.2 (cont'd)
- Does Access Plan consider best time of day to provide access for inspection?

Accessibility



Accessibility



Accessibility



Building Owner Requirements

- Accessibility 4.1.2 (cont'd)
- Any areas require special preparation prior to inspection & testing?

“Inspections from Floor Level”

- “Inspection” – defined by NFPA-25 as, “a visual examination of a system or portion thereof to verify that it appears to be in operating conditions and if free of physical damage (3.3.18).”

“Inspections from Floor Level” (cont’d)

- Sprinklers shall be inspected from the floor level annually (5.2.1.1)
- Sprinklers installed in concealed spaces such as above suspended ceilings shall not require inspection (5.2.1.1.6)
- Sprinkler pipe and fittings shall be inspected annually from the floor level (5.2.2)
- Pipe and fittings installed in concealed spaces such as above suspended ceilings shall not require inspection (5.2.2.3)
- Similar inspection requirements for sprinkler pipe hangers (5.2.3, 5.2.3.3)

NFPA 25



NFPA 25



NFPA 25



What's wrong
here?





Extended Interval Testing

- Extended Interval Testing – required less frequently than annually and often not included in annual or quarterly inspections.


Extended Interval Testing(cont'd)

- Extended Interval Testing Examples:
 - 3-year pressure tests – Dry pipe & Preaction systems
 - 5-year check valve maintenance
 - 5-year interval pipe inspections
 - 5-year standpipe testing

Dry Pipe System

Dry Pipe Valve

- Air pressure in system piping will cause the clapper to close against the air seat and water seat.



Dry System Leakage Test

- 13.4.4.2.9 Dry System Leakage Test – every 3 years
 - Test with air at 40 psi for 2-hours.
 - Turn off the system air source for 4-hours.

Extended-Interval Testing

- 5-Year Internal Check Valve Maintenance.



Swing Check

Extended-Interval Testing

- 5-Year Internal Check Valve Maintenance.



Wafer Check

Extended-Interval Testing

- 5-Year Internal Check Valve Maintenance.



Flanged Swing Check

Extended-Interval Testing

- Obstruction found during an internal inspection of a check valve.



5-Year Testing – Internal Pipe Inspection



- Standard Internal Pipe Exam
 - End of one main
 - End of one branchline
- Internal Pipe Exam for 'at-risk' systems
 - System Valve
 - Riser
 - Cross Main
 - Branch line
- Obstruction Investigation – if certain conditions are present. Complete flushing procedure may be required.



Failing to Internally Inspect Piping



Failing to Internally Inspect Piping



Failing to Internally Inspect Piping



Failing to Internally Inspect Piping



Obstructed Piping May Require
Replacement or Flushing



Repair Plan (cont'd)

- Extended Interval Testing Recommendations:
 - Coordinate with other system repairs or modifications
 - Add 5-year pipe inspections to projects requiring pipe modifications

Future Inspection & Testing

- Recommendations to improve inspection & testing processes:
 - Relocate valves to accessible areas
 - Main drain & test drains piped to proper floor drains, drain risers or to discharge outside

System Zones / Emergency Shut-Down Procedures

- Conduct periodic review of system zoning: location of control valves & system drains
- Conduct periodic drills for emergency shut down procedures

NFPA Sprinkler Head Testing

System Zones / Emergency Shut-Down Procedures (cont'd)

- Example:
 - One (1) sprinkler discharging at 18 GPM x 10 minutes = 180 gallons

NFPA Sprinkler Head Testing

CONVENTIONAL



UPRIGHT



PENDENT



**HORIZONTAL
SIDEWALL**



VERTICAL SIDEWALL



RECESSED PENDENT



RECESSED PENDENT




**CONCEALED
HORIZONTAL SIDEWALL**



**CONCEALED
PENDENT**





Sprinkler Head Identification





Sprinkler Head Identification

Pendent sprinkler
on exposed piping



Pendent Sprinklers are Installed on bottom of piping or through a ceiling

Sprinkler Head Identification




Sidewall Sprinklers are generally installed through a wall



Horizontal Sidewall Sprinkler

Sprinkler Identification

- If sprinklers are of the quick response type they will have Q.R. written on the deflector. This is the safest way to identify quick response sprinklers.
- Most sprinklers will have the manufactured date somewhere on the sprinkler. See picture to the right.




Bulb type elements



Standard response sprinkler with a link instead of a bulb type element

Sprinklers



Dry Sprinklers

NFPA-25 3.3.30.3
Dry Sprinklers. A
sprinkler secured in
an extension nipple
that has a seal at
the inlet end to
prevent water from
entering the nipple
until the sprinkler
operates.










The nipple is
the black piece
of pipe on each
of these
Sprinkler.
There is no
water in these
nipples till the
sprinkle goes off

Sprinkler Temperature Ratings

NFPA 13: Table 6.2.5.1 Temperature Ratings, Classification, and Color Codings				
Maximum Ceiling Temperature	Temperature Rating	Temperature Classification	Color Code	Glass Bulb Colors
100°F / 38°C	135-170°F / 57-77°C	Ordinary	Uncolored or Black	Orange or Red
150°F / 66°C	175-225°F / 79-107°C	Intermediate	White	Yellow or Green
225°F / 107°C	250-300°F / 121-149°C	High	Blue	Blue
300°F / 149°C	325-375°F / 163-191°C	Extra High	Red	Purple
375°F / 191°C	400-475°F / 204-246°C	Very High	Green	Black
475°F / 246°C	500-575°F / 260-302°C	Ultra High	Orange	Black
625°F / 329°C	650°F / 343°C	Ultra High	Orange	Black

Sprinkler Temperature Ratings

Bulb Colour	Temperature	Temperature Rating	maximum Ceiling Temperature
	135°F 57°C	Ordinary	100°F 38°C
	155°F 68°C	Ordinary	100°F 38°C
	175°F 79°C	Intermediate	150°F 65°C
	200 or 212°F 93 or 100°C	Intermediate	150°F 65°C
	286°F 141°C	Intermediate	225°F 107°C
	360°F 182°C	High	300°F 149°C
	500°F 260°C	Extra High	465°F 240°C

Summary Table

5.1.1.2

Below the required sprinkler testing is numbered to correspond to the following slides



Test			
Waterflow alarm devices			
Mechanical devices	Quarterly		5.3.3.1
Vane and pressure switch type devices	Semiannually		5.3.3.2
Valves supervisory alarm devices			Table 13.1
Supervisory signal devices (except valve supervisory switches)			Table 13.1
Main drain			Table 13.1
Antifreeze solution	Annually		5.3.4
1	Sprinklers — extra-high temperature	5 years	5.3.1.1.1.4
2	Sprinklers — fast-response	At 20 years and every 10 years thereafter	5.3.1.1.1.3
3	Sprinklers	At 50 years and every 10 years thereafter	5.3.1.1.1
4	Sprinklers	At 75 years and every 5 years thereafter	5.3.1.1.1.5
5	Sprinklers — dry	At 10 years and every 10 years thereafter	5.3.1.1.1.6

#1 Sprinkler Testing

NFPA-25 5.3.1.1.1.4*

- Solder-type sprinklers, extra high (325 degree Fahrenheit) or greater **shall** be tested at 5-year intervals.



NFPA 13: Table 6.2.5.1 Temperature Ratings, Classification, and Color Codings				
Maximum Ceiling Temperature	Temperature Rating	Temperature Classification	Color Code	Glass Bulb Colors
300°F / 149°C	325-375°F / 163-191°C	Extra High	Red	Purple
375°F / 191°C	400-475°F / 204-246°C	Very High	Green	Black
475°F / 246°C	500-575°F / 260-302°C	Ultra High	Orange	Black
625°F / 329°C	650°F / 343°C	Ultra High	Orange	Black



#2 Sprinkler Testing

NFPA-25 5.3.1.1.1.3**

- Sprinklers manufactured using fast-response (or Q.R. Quick Response) elements **shall** elements that have been in service for 20 years shall be replaced or a representative sample shall be tested and then retested at 10 year intervals.
- Some times it is more cost effective to simply replace all the sprinklers in the space.



- #3 Where sprinkler have been in service for 50 years they shall be replaced or representative sample from one of more sample area shall be tested. Test procedures shall be repeated at 10-year intervals.
- #4 Where sprinklers have been in service for 75 years they shall be replaced or a representative samples from one of more sample area shall be tested. Test procedures shall be repeated at 5-year intervals.
- Sprinklers manufactured prior to 1920 shall be replaced

#5 Dry Type Sprinkler Testing

NFPA 25-2011 (5.3.1.1.16)

Listed Dry-type sprinklers that have been in service for 10 years **shall** be:

- Replaced or
- Representative samples shall be tested and then retested at 10-year intervals.



Sprinkler Testing

(NFPA-25 5.3.1.1.2*)

- Where sprinklers are subject to harsh environments they **shall** be replaced or tested.
- Testing **shall** be repeated at 5-year intervals.
- Harsh environments per the Annex include paper mills, tanneries, steam rooms, areas exposed to outside weather, cold storage areas etc..

Annex Referencing

- Any section like 5.3.1.1.2* that has an asterisk (*) additional information can be found in the Annex.
- The Annex area for sprinkler testing can be found in NFPA 25 on page 70 in the upper left of the page.

Sprinkler Tag for Testing

Please visit UL.com/fieldsprinklertesting to submit an order.
On-Line Submittal Lot No.: _____
If On-Line Lot not created, please complete the following:

Occupant Name: _____
Address: _____
City, State: _____

Submitter Name: _____
Address: **J.F. Ahern Co.**
5315 Freitag Drive
Menomonie, WI 54751
City, State, Zip: _____

(over)

Location of Sample in Bldg: _____
Room Environment (check one):

<input type="checkbox"/> Attic	<input type="checkbox"/> Freezer/Cooler	<input type="checkbox"/> Parking Garage	<input type="checkbox"/> Senior Facility
<input type="checkbox"/> Balcony	<input type="checkbox"/> Hallway/Walkway	<input type="checkbox"/> Plenum	<input type="checkbox"/> Swimming Pool
<input type="checkbox"/> Bathroom	<input type="checkbox"/> Hospital	<input type="checkbox"/> Prison	<input type="checkbox"/> Warehouse
<input type="checkbox"/> Canopy/Porch	<input type="checkbox"/> Hotel	<input type="checkbox"/> Restaurant	<input type="checkbox"/> _____
<input type="checkbox"/> Dwelling Unit	<input type="checkbox"/> Kitchen	Attach tag to sample upon removal. Package sprinklers to prevent damage of parts. Do Not Ship Loose.	
<input type="checkbox"/> Educational	<input type="checkbox"/> Laboratory		
<input type="checkbox"/> Entertainment	<input type="checkbox"/> Loading dock		
<input type="checkbox"/> Factory	<input type="checkbox"/> Marine	Ship to: UL LLC Attn: Field Sprinkler Coordinator 2500 Dundee Road, Bldg. 11 Northbrook, IL 60062	

(over)

FAQs per NFPA

7. What is meant by "individual sprinkler sample" as referenced in Section 5.3.1.2, does this pertain to the style of the sprinkler (such as upright, pendent etc.)?

Individual sprinkler sample refers to each type of sprinkler in a system. For example, if a system contains upright and pendent sprinklers, one percent or not less than four of each type must be removed for testing.

8. If a system has only one riser but serves several tenant spaces, such as a strip mall, should a sprinkler sample be taken from the system as a whole or from each individual tenant space?

In your case, a sample from each tenant space is not required. The sampling requirement in Section 5.3.1.2 is intended to be random sampling, meaning that sprinklers should not be removed from a single branchline but should be taken from a number of different areas in a building (where practical). Removing sprinklers from as many different areas as possible will better represent the condition of all or most of the sprinklers in that system.

9. How many sprinklers must be removed from a system for testing?

Section 5.3.1.2 requires that one percent (or no less than four) be removed and submitted to a testing laboratory for evaluation. If a system contains 500 sprinklers for example (400 upright and 100 pendent) then a total of eight sprinklers must be removed; $400 \times .01 = 4$ and $100 \times .01 = 1$ (but not less than 4).

Thank You



5315 Freitag Drive
Menomonie, WI 54751
main 715.233.1841 | fax 715.233.1846
jfahern.com

Northwest Regional Service Dispatch Team

715-598-5904 **Monday-Friday, 7:30am-4:30pm**
800-481-8009 **Available 24/7**

Fire Sprinkler Service

Angela Spielman, Dispatch
Direct Line: 715-233-2427
Dispatch: 715-598-5904
Email: nwrdispatch@jfahern.com

Pete Paletta, Project Manager
Direct Line: 715-233-2428
Mobile: 715-308-3460
Email: ppaletta@jfahern.com

FSE Service (Fire Extinguisher, Fire Alarm, Special Hazards, Pre-Engineered)

Betty Hill, Dispatch
Direct Line: 715-233-2455
Dispatch: 715-598-5904
Email: nwrdispatch@jfahern.com

Chris Simpson, Project Manager
Direct Line: 715-233-2448
Mobile: 715-279-6240
Email: csimpson@jfahern.com

Mechanical Service (HVAC, Plumbing, Controls)

Dawn Berger, Dispatch
Direct Line: 715-233-2426
Dispatch: 715-598-5904
Email: nwrdispatch@jfahern.com

Tristen Cadotte, Project Manager
Direct Line: 715-233-2458
Mobile: 715-209-8334
Email: tcadotte@jfahern.com