



Welcome to the Feb 2018

WHEA Lunch & Learn

Lauzon
Life Safety
Consulting



Inspection of Rated Doors

Welcome to the Feb 2018

WHEA Lunch & Learn

On Location at

Mercy Health System, Janesville
Hospital & Trauma Center

Consulting



Presenters

Bill Lauzon, PE



1973-2006 - "Facility Engineer"
2006-2011 – AHJ with DHS/DQA
2011-2018 - Consultant

Heather Lauzon Werner



2012-2015 - "Facility Director"
2011-2018 – Consultant

President of Lauzon Life
Safety Consulting



1997-2018

DHS-DQA



“Retired” Plan Reviewer & Surveyor

Lynn’s comments are his own personal interpretations of the codes.

He does not speak on behalf of the Dept of Health.

Rated Door Inspections

1. **NFPA 80 Requirements** (Slides 6-9)
2. **Key Elements of Inspection** (Slides 10-23)
3. **Point-by-Point Inspection** (Slides 24-195)

Enter Questions in the
“Chat Box” ANYTIME


Table of Contents

CONTENTS		80-3
Contents		
Chapter 1 Administration	80- 5	
1.1 Scope	80- 5	
1.2 Purpose	80- 5	
1.3 Restrictivity	80- 5	
1.4 Equivalency	80- 5	
Chapter 2 Referenced Publications	80- 5	
2.1 General	80- 5	
2.2 NFPA Publications	80- 5	
2.3 Other Publications	80- 6	
2.4 References for Extracts in Mandatory Sections	80- 6	
Chapter 3 Definitions	80- 6	
Chapter 9 Special-Purpose Horizontally Sliding Accordion or Folding Doors	80-22	
9.1 Doors	80-22	
9.2 Supporting Construction	80-22	
9.3 Clearances Around Openings	80-22	
9.4 Assembly Components	80-22	
Chapter 10 Vertically Sliding Fire Doors	80-22	
10.1 Doors	80-22	
10.2 Supporting Construction	80-22	
10.3 Clearances	80-23	
10.4 Assembly Components	80-23	

Chapter 5 Care and Maintenance	80-14
5.1 General	80-14
5.2 Inspections	80-14
5.3 Retrofit Operators	80-16

5.1 General	80-14	Chapter 14 Hoistway Doors for Elevators and Dumbwaiters	80-25
5.2 Inspections	80-14	14.1 Doors	80-25
5.3 Retrofit Operators	80-16	14.2 Types of Doors	80-26
Chapter 6 Swinging Doors with Builders Hardware	80-16	14.3 Hoistway Door Vision Panels	80-27
6.1 Doors	80-16	14.4 Door Operation	80-27
6.2 Supporting Construction	80-16	Chapter 15 Chute Doors	80-27
6.3 Openings	80-16	15.1 Doors	80-27
6.4 Assembly Components	80-17	Chapter 16 Access Doors	80-27
6.5 Application, Installation, and Adjustment	80-19	16.1 Doors	80-27
Chapter 7 Swinging Doors with Fire Door Hardware	80-19	16.2 Types of Doors	80-27
7.1 Doors	80-19	Chapter 17 Fire Windows	80-28
7.2 Supporting Construction	80-19	17.1 Windows	80-28
7.3 Openings	80-20	17.2 Glazing Material	80-28
7.4 Assembly Components	80-20	17.3 Types of Windows	80-28
Chapter 8 Horizontally Sliding Doors	80-20	17.4 Installation	80-29
8.1 Doors	80-20	17.5 Closing Devices	80-29
8.2 Supporting Construction	80-21	Chapter 18 Glass Block Assemblies	80-29
8.3 Openings (Reserved)	80-21	18.1 General	80-29
8.4 Assembly Components	80-21	18.2 Installation	80-29


2010 Edition



Chapter 5.2

Inspect and test not less than annually, and a written record maintained

**ANNUAL
REPORT**



Chapter 5.2

5.2.4 Swinging Doors with Builders Hardware or Fire Door Hardware.

5.2.4.1 Fire door assemblies shall be visually inspected from both sides to assess the overall condition of door assembly.

▲ 5.2.4.2 As a minimum, the following items shall be verified:

- ▲ (1) No open holes or breaks exist in surfaces of either the door or frame.
- ▲ (2) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
- ▲ (3) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.
- ▲ (4) No parts are missing or broken.
- ▲ (5) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.
- (6) The self-closing device is operational; that is, the active door completely closes when operated from the full open position.
- (7) If a coordinator is installed, the inactive leaf closes before the active leaf.
- (8) Latching hardware operates and secures the door when it is in the closed position.
- ▲ (9) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.
- (10) No field modifications to the door assembly have been performed that void the label.
- ▲ (11) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.

Swinging Doors (11 Inspection Points)



CMS S&C Letter 17-38

Published July 28, 2017

DEPARTMENT OF HEALTH & HUMAN SERVICES
Centers for Medicare & Medicaid Services
7500 Security Boulevard, Mail Stop C2-21-16
Baltimore, Maryland 21244-1850



Center for Clinical Standards and Quality/Survey & Certification Group

Ref: S&C 17-38-LSC

DATE: July 28, 2017

TO: State Survey Agency Directors

FROM: Director
Survey and Certification Group

SUBJECT: Fire and Smoke Door Annual Testing Requirements in Health Care Occupancies

Memorandum Summary

- In health care occupancies, fire door assemblies are required to be annually inspected and tested in accordance with the 2010 National Fire Protection Association (NFPA) 80.
- In health care occupancies, non-rated doors assemblies including corridor doors to patient care rooms and smoke barrier doors are not subject to the annual inspection and testing requirements of either NFPA 80 or NFPA 105.
- Non-rated doors should be routinely inspected as part of the facility maintenance program.
- Full compliance with the annual fire door assembly inspection and testing in accordance with 2010 NFPA 80 is required by January 1, 2018.
- Life Safety Code (LSC) deficiencies associated with the annual inspection and testing of fire doors should be cited under K211 – *Means of Egress - General*.

Background

The Centers for Medicare & Medicaid Services (CMS) adopted the 2012 edition of the NFPA LSC, which includes requirements for the maintenance, inspection, and testing of fire doors and smoke doors in certain certified health care facilities.

The 2012 LSC added new provisions under Section 7.2.1.15 – *Inspection of Door Openings* for the annual inspection and testing of certain fire doors and smoke doors assemblies in accordance with the 2010 editions of NFPA 80 – *Standard for Fire Doors and Other Opening Protective*, and NFPA 105 – *Standard for Smoke Door Assemblies and Other Opening Protective*.

The new LSC provisions under sections 7.2.1.15.1 and 7.2.1.15.2 require certain fire door and smoke door assemblies to be inspected and tested annually in accordance with the NFPA 80 and NFPA 105. However, section 7.2.1.15.1 states that these requirements only apply where required by Chapters 11 through 43. Therefore, as the LSC health care occupancy chapters (i.e., Chapters 18, 19, 20, 21) do not directly reference section 7.2.1.15, these new annual inspection and testing requirement do not apply to health care occupancies.

- Non-rated corridor & smoke barrier doors do NOT need to be annually inspected

- BUT, should be routinely inspected as part of the facility maintenance program

- Moved Due Date for Fire Door Inspections under NFPA 80 to **Jan 1, 2018**

- New specific door inspection tag: K211

CMS S&C Letter 17-38

Annual Inspection & Testing Requirements in Health Care Occupancies

Although the requirements under LSC section 7.2.1.15 are not applicable to health care occupancies, annual inspection and testing of fire doors assemblies in accordance with NFPA 80 are still required in health care occupancies by LSC section 8.3.3.1, which is applicable to all occupancy chapters.


In addition, with the exception of new doors in horizontal exits, the annual inspection and testing of smoke door assemblies in accordance with NFPA 105 is not required per LSC section 8.5.4.2 as doors in health care occupancies are not required to be smoke-leakage-rated.

- LSC 7.2.1.15 inspections DO NOT apply to health care
- LSC 8.3.3.1 requires inspections of rated doors
- LSC 8.5.4.2 does NOT require smoke barrier door inspection under NFPA 105

1. DOOR INVENTORY

ALL RATED DOORS



- Hazardous Rooms
- Stairwells
- Occupancy Separations
- Building Separation
- Horizontal Exits
- Exit Passageways
- Smoke Barriers (if labeled)
- Corridors (if labeled)
- Other Doors (if labeled)



Recommend
always Including

**USE YOUR
COLORIZED
Life Safety
Plans**

**Inspect all
doors that are
colored**



2. USE QUALIFIED INSPECTORS

- Do NOT need to use a vendor
- No “certification”
- Must be experienced & knowledgeable
- No definitions
- Wide variability of what inspectors think is “qualified”



3. USE APPROPRIATE FORMS

Document Requirements:

- Date of Inspection (M/D/Y)
- Max 365 days between COMPLETION Dates

It's NOT when you start, but when you FINISH the inspection

- Who Performed Inspection (& qualified?)
- What was inspected? (full inventory)
- How performed? (Include all check points; record readings)
- Repairs made? (& date re-tested)

RATED HINGED DOOR ANNUAL INSPECTION		A	RATED HINGED DOORS
Facility: 		Page 1 of 3	
Inspector Name	Inspection Date		
Inspect doors for ALL check-points below and enter results on page 3; If door fails ANY check, enter # of check-point to indicate problem, describe details & corrective action on page 2. EVERY rated hinged door must be included on the Report. Use form 1BC for Sliding or Rolling Rated doors.			
This checklist contains the minimum inspection requirements of NFPA 80 and the major door requirements of the LSC			
Documentation is on file that shows the person who performed tests has knowledge & understanding of the operating components of the door being inspected, per NFPA 80-2010, §5.2.3.1		Y	N
Visual inspection must be performed from both sides of door prior to testing			
1. No parts are <u>missing</u> or broken		NFPA 80 §5.2.4.1	
2. No Damage on <u>Hardware</u> , Door, frame, & hinges secured, aligned		NFPA 80 §5.2.4.1(4)	
3. <u>Closer</u> is operational so each doors completely close from the full open position		NFPA 80 §5.2.4.1(3)	
4. <u>Automatic Closing</u> doors close under fire conditions (closer, hold-open & smoke detector)		NFPA 80 §5.2.4.1(6)	
5. <u>Closer speed</u> set per ADA requirements (min 5 sec from full open to 12° open).		NFPA 80 §5.2.14.2	
6. <u>Coordinator</u> needed on pairs of single egress doors, so the inactive leaf closes before the active		ADA §404.2.7.1	
7. <u>Rating Labels</u> are on Door & Frame & readable		NFPA 80 §5.2.4.2(7)	
8. Door <u>gaps</u> do not exceed clearances 1/8" (astragal required on pairs of corridor doors > 2003)		NFPA 80 §5.2.4.1(5)	
9. No <u>field modifications</u> that void the rating label.		NFPA 80 §5.2.4.2(10)	
10. <u>Gaskets</u> and edge seals are inspected to verify their presence and integrity		NFPA 80 §5.2.4.2(11)	
11. <u>Surface of Door & Frame</u> does Not have open holes or breaks; no grills w/o damper		NFPA 80 §5.2.4.2(1)	
12. <u>Signs</u> must (a) be intact, legible, proper size, (b) Have required wording, (c) No screws		NFPA 80 §4.1.4.2.2	
13. <u>Glazing</u> is intact and securely fastened in place, if so equipped		NFPA 80 §5.2.4.1(2)	
14. <u>Positive Latching</u> hardware operates and secures the door when it is closed		NFPA 80 §5.2.4.2(8)	
15. <u>Latch located</u> >=34" high (new) and <=48" high (if installed > 2003)		LSC §7.2.1.5.10	
16. <u>Pairs</u> of doors must (a) both have independent unlatching, or auto flush bolt & no latch on inactive and unlatching hardware on active door; (b) Astragal on rated doors & corridor doors;		LSC §7.2.1.5.11	
17. <u>Unlatch</u> from egress side (a) with 1 motion; (b) <u>not require</u> use of a key or special knowledge;		LSC §7.2.1.5	
(c) <u>Obvious operation</u> in all light conditions		LSC §7.2.1.4.5	
18. Max <u>Opening force</u> to (a) <u>release</u> latch is 15 lb; (b) to set door in <u>motion</u> with a closer is 30 lb (new) and (c) to <u>full open</u> is 15 lbs (new); (d) Doors without closers open <= 5 lbs; (e) <=50 lb if installed > 1988		NFPA 80 §5.2.4.2(9)	
19. <u>Auxiliary hardware</u> items that interfere with operation are not installed		LSC §7.2.1.5.12	
20. "Panic-type" hardware does not have <u>locking device</u> (except Delayed Egress, Access-Control,		LSC §7.2.1.4.3	
21. <u>Outswinging doors</u> must (a) Leave >= 50% of egress width; (b) project <= 7" into width when full open		LSC §7.2.1.15.7(1)	
22. No <u>obstruction</u> to full opening & freely closing; <u>Floor is Level</u> on both sides of door		NFPA 80 §5.2.13.3	
23. No <u>wedging</u> or blocking of doors in the open position		NFPA 80 §6.5.4.3	
24. <u>Kickplates</u> : ≤ 48" @ Haz Rm/per LSC; ≤ 16" hi @ other Fire Doors, unless rated (no limit @ Smk Doors)		NFPA 80 §4.8.4.1	
25. Door <u>Undercut</u> <= 3/4" on Fire Doors; & the minimal needed for operation on Smoke Doors		LSC §7.2.1.9	
26. <u>Power doors</u> : (a) must set in motion with <= 50 lbs; (b) will swing fully open;		LSC §7.2.1.6.1	
(c) Has sign "In Emergency, Push to Open"; (d) Min 30" wide; (e) openable on power failure		LSC §7.2.1.6.2	
27. <u>Delayed egress</u> locks must: (a) release in <=15 sec after max 3 sec pushing with <= 15 lb;		LSC §7.2.1.6.2	
(b) manual reload only; (c) audible alarm at door; (d) release on power failure, sprinkler, one heat, or 2 smoke detectors; (e) sign says "Push Until Alarm Sounds, Door Can Be Opened In 15 Seconds" in 1" hi contrasting letters		NFPA 80 §5.2.9	
28. <u>Access control</u> must: (a) unlock from egress side via auto sensor; (b) unlock with manual button <=5" from door & Independent from sensor; (c) Signed "Push to Exit"; (d) unlatch on power loss, sprinkler, or fire alarm			
29. <u>Hardware</u> examined & inoperative parts, or other defects replaced without delay			

3 sheets to
Document your
Inspections

Page 1:
Inspection Check
Points

Download from
our website:
(Instructions Following)

RATED HINGED DOOR ANNUAL INSPECTION

A

RATED HINGED DOORS

Facility:

Page 2 of 3

Inspector Name

Inspection Date

DEFICIENCY & CORRECTION SUMMARY

Instructions: Use this sheet to describe the issues found during the door inspection of the facility. Enter NONE if no deficiencies are found. Page 2 should always be attached to the actual inspection report. All deficiencies must be corrected as soon as possible after discovery. Document each step of the repair process. Re-inspect / test door to ensure compliance.

[illegible]

Use Additional Pages as needed. Every Swinging Rated Door must be listed

Free Form

Sheet 2: Document Repairs

Download from
our website:

(Instructions Following)

A

**RATED HINGED
DOORS**

Facility:

Page 3 of 3

Inspection Date

INSTRUCTIONS: Inspect doors for ALL check-points on Page 1 & enter Pass/Fail below; If door fails ANY check-point on Page 1, enter # of check to indicate problem AND describe details & corrective actions on page 2; Use additional sheets as needed

[illegible]

*Door ID: Any method facility wants to uniquely identify each door (Door #, Asset #, 1.2.3...ect). Best to tag ID on door


** Life Safety Function: C=Corridor; H=Haz Rm; Occupancy Separation; B=Bldg Construction Separation; H=Horizontal Exit; EP=Exit Passageway; E=Exit; S=Smoke Barrier; V=Vertical Opening/Stairs/Shaft; O=Other © LLSC, Jan 20

© LLSC, Jan 2018

Free Form

Sheet 3: Document Inspections

Download from our website:
<http://www.lauzon-lsc.com>




Lauzon Life Safety Consulting

Questions? 262-664-9071

"Your Protective Shield in the Code War"

Call or EMAIL Now!
Bill Lauzon, 262-945-4567
Lauzon.LSC@gmail.com
Heather Werner, 262-664-9071
HLauzonWerner@gmail.com



Lauzon Life Safety Consulting, LLC offers the best inspection, consultation, and training when it comes to the Life Safety Code and Wisconsin regulations for hospitals, nursing homes, CBRF's, ASC's, ESRD's, hospital-linked clinics and critical access hospitals.

We can help you promote self-compliance with codes (NFPA/ICC), prepare for surveys (DQA, CMS, TJC), respond to survey citations (POC, Waivers, FSES), and we educate staff both online and on-site.

Website Home
About LLSC
Code Workshops
Services & Rates
Free Forms
Free Training
Free Tools
Code Central Info & Log-In

NEW IN JAN, 2018

Updated ANNUAL DOOR INSPECTION FORM -->Click on "Free Forms" at Left (Free in Jan & Feb ONLY) Learn HOW to use by Viewing the WHEA Lunch & Learn Webinar on Feb 8, 2018 (11:30am-1pm). Subscribe at WHEA.com

NEW IN NOV, 2017

Updated Risk Assessment Tool - See "Free Tools": (1) Expanded Utility Assessment; (2) New Equipment Risk Assessment; (3) New Door Risk Assessment



Lauzon Life Safety Consulting

Questions? 262-664-9071

Call Now!

Bill Lauzon, 262-945-4567

Lauzon.LSC@gmail.com

Heather Werner, 262-664-9071

HLauzonWerner@gmail.com

FREE FORMS

Test & Inspection Documentation

Keys to Avoid Cites:

- **SCROLL DOWN**
- **MAKE SURE** all the code requirements)
- **MAKE SURE** scheduled work is completed

FREE FORMS

Here is a SAMPLE of of the forms that are available to Code Central members. NOTE: The FREE forms are in "pdf" format and typically based on the 2000 Life Safety Code

JOIN CODE CENTRAL to get:

1. Many MORE forms
2. Forms that are UPDATED to follow the 2012 LSC, 2012 NFPA 99, and all the referenced codes
3. Forms that are in an "Excel" or "Word" format so you can easily CUSTOMIZE to your situation

DAILY INSPECTIONS

ILSM Daily Checks

WEEKLY INSPECTIONS

Roll/Slide Fire Doors Annual

Generator Weekly

MONTHLY INSPECTIONS

Elevator Recall Monthly

Wet Sys Monthly

Fire Pump Monthly/SA

Fire Extinguishers Monthly

Exit Lights Monthly

Generator Monthly

Emerg Battery Monthly

Website Home

About LLSC

Code Workshops

Services & Rates

Free Forms

Free Training

Free Tools

Code Central Info & Log-In



Lauzon Life Safety Consulting

Questions? 262-664-9071

Call Now!

Bill Lauzon, 262-945-4567


Lauzon.LSC@gmail.com

Heather Werner, 262-664-9071

SEMI-ANNUAL INSPECTIONS

Fire Alarm Inspection (Semi-A)

SCROLL DOWN



ANNUAL INSPECTIONS

Based on 2012 LSC &
NFPA 80-2010 (pdf)

Rated Doors
Annual
(UPDATED)

Click

Sprinkler
Annual

Hydrant
(Annual)

Fire Pump (Annual)

Generator Load Bank
(Annual)

NEW-2012 - Receptacle
Inspection(Annual)

MULTI-YEAR INSPECTIONS

Damper Inspect (4 Yr)

Damper Inspect (6 Yr)

FOR EVERY CONSTRUCTION PROJECT

ICRA

Project Assessment (Life Safety & Infect
Control Risks)

NEW-2012 - Receptacle
Inspection(Installation)

Monthly/SA

Monthly

RATED HINGED DOOR ANNUAL INSPECTION		A	RATED HINGED DOORS
Facility: <input type="text"/>		Page 1 of 3	
Inspector Name <input type="text"/>		Inspection Date <input type="text"/>	
Inspect doors for ALL check-points below and enter results on page 3; If door fails ANY check, enter # of check-point to indicate problem, describe details & corrective action on page 2. EVERY rated hinged door must be included on the Report. Use form 1BC for Sliding or Rolling Rated doors.			
This checklist contains the minimum inspection requirements of NFPA 80 and the major door requirements of the LSC			
Documentation is on file that shows the person who performed tests has knowledge & understanding of the operating components of the door being inspected, per NFPA 80-2010, §5.2.3.1		Y	N
Visual inspection must be performed from both sides of door prior to testing		NFPA 80 §5.2.4.1	
1. No parts are missing or broken		NFPA 80 §5.2.4.1(4)	
2. No Damage on Hardware, Door, frame, & hinges secured, aligned		NFPA 80 §5.2.4.1(3)	
3. Closer is operational so each doors completely close from the full open position		NFPA 80 §5.2.4.1(6)	
4. Automatic Closing doors close under fire conditions (closer, hold-open & smoke detector)		NFPA 80 §5.2.14.2	
5. Closer speed set per ADA requirements (min 5 sec from full open to 12" open).		ADA §404.2.7.1	
6. Coordinator needed on pairs of single egress doors, so the inactive leaf closes before the active		NFPA 80 §5.2.4.2(7)	
7. Rating Labels are on Door & Frame & readable		NFPA 80 §5.2.4.1(5)	
8. Door gaps do not exceed clearances 1/8" (astragal required on pairs of corridor doors > 2003)		NFPA 80 §5.2.4.2(10)	
9. No field modifications that void the rating label.		NFPA 80 §5.2.4.2(11)	
10. Gaskets and edge seals are inspected to verify their presence and integrity		NFPA 80 §5.2.4.2(1)	
11. Surface of Door & Frame does Not have open holes or breaks; no grills w/o damper		NFPA 80 §4.1.4.2.2	
12. Signs must (a) be intact, legible, proper size, (b) Have required wording, (c) No screws		NFPA 80 §5.2.4.1(2)	
13. Glazing is intact and securely fastened in place, if so equipped		NFPA 80 §5.2.4.2(8)	
14. Positive Latching hardware operates and secures the door when it is closed		LSC §7.2.1.5.10	
15. Latch located >=34" high (new) and <=48" high (if installed > 2003)		LSC §7.2.1.5.11	
16. Pairs of doors must (a) both have independent unlatching, or auto flush bolt & no latch on inactive and unlatching hardware on active door; (b) Astragal on rated doors & corridor doors;		LSC §7.2.1.5	
17. Unlatch from egress side (a) with 1 motion; (b) not require use of a key or special knowledge; (c) Obvious operation in all light conditions		LSC §7.2.1.4.5	
18. Max Opening force to (a) release latch is 15 lb; (b) to set door in motion with a closer is 30 lb (new) and (c) to full open is 15 lbs (new); (d) Doors without closers open <= 5 lbs; (e) <=50 lb if installed > 1988		NFPA 80 §5.2.4.2(9)	
19. Auxiliary hardware items that interfere with operation are not installed		LSC §7.2.1.5.12	
20. "Panic-type" hardware does not have locking device (except Delayed Egress, Access-Control).		LSC §7.2.1.4.3	
21. Outswinging doors must (a) Leave >= 50% of egress width; (b) project <= 7" into width when full open		LSC §7.2.1.15.7(1)	
22. No obstruction to full opening & freely closing; Floor is Level on both sides of door		NFPA 80 §5.2.13.3	
23. No wedging or blocking of doors in the open position		NFPA 80 §6.3.4.3	
24. Kickplates: <= 48" @ Haz Rm(per LSC); <= 16" hi @ other Fire Doors, unless rated (no limit @ Smk Doors)		NFPA 80 §4.8.4.1	
25. Door Undercut <= 3/4" on Fire Doors; & the minimal needed for operation on Smoke Doors		LSC §7.2.1.9	
26. Power doors: (a) must set in motion with <= 50 lbs; (b) will swing fully open; (c) Has sign "In Emergency, Push to Open"; (d) Min 30" wide; (e) openable on power failure		LSC §7.2.1.6.1	
27. Delayed egress locks must: (a) release in <=15 sec after max 3 sec pushing with <= 15 lb; (b) manual relock only; (c) audible alarm at door; (d) release on power failure, sprinkler, one heat, or 2 smoke detectors; (e) sign says "Push Until Alarm Sounds, Door Can Be Opened In 15 Seconds" in 1" hi contrasting letters		LSC §7.2.1.6.2	
28. Access control must: (a) unlock from egress side via auto sensor; (b) unlock with manual button <=5" from door & Independent from sensor; (c) Signed "Push to Exit"; (d) unlatch on power loss, sprinkler, or fire alarm		NFPA 80 §5.2.9	
29. Hardware examined & inoperative parts, or other defects replaced without delay			

Page 1: Inspection Check Points

Form includes
the Mandatory
Check Points &
Installation
requirements of
NFPA 80

§5.2.4

Swinging Doors must be inspected for 11 points:

- (1) No open holes or breaks in surfaces of the door or frame
- (2) Glazing is intact & securely fastened in place, if so equipped
- (3) Door assembly in working order; no visible signs of damage
- (4) No parts are missing or broken
- (5) Door clearances do not exceed clearances 1/8"
- (6) Closer is operational so the active door completely closes
- (7) If coordinator, inactive leaf closes before active leaf
- (8) Latch operates and secures the door when it is closed
- (9) Interfering hardware not installed on the door or frame
- (10) No field modifications that void the label.
- (11) Gaskets and edge seals are inspected to verify their presence and integrity

RATED HINGED DOOR ANNUAL INSPECTION		A	RATED HINGED DOORS
Facility: 		Page 1 of 3	
Inspector Name: 		Inspection Date: 	
Inspect doors for ALL check-points below and enter results on page 3; If door fails ANY check, enter # of check-point to indicate problem, describe details & corrective action on page 2. EVERY rated hinged door must be included on the Report. Use form 1BC for Sliding or Rolling Rated doors.			
This checklist contains the minimum inspection requirements of NFPA 80 and the major door requirements of the LSC			
Documentation is on file that shows the person who performed tests has knowledge & understanding of the operating components of the door being inspected, per NFPA 80-2010, §5.2.3.1		Y	N
Visual inspection must be performed from both sides of door prior to testing		NFPA 80 §5.2.4.1	
1. No parts are missing or broken		NFPA 80 §5.2.4.1(4)	
2. No Damage on Hardware, Door, frame, & hinges secured, aligned		NFPA 80 §5.2.4.1(3)	
3. Closer is operational so each doors completely close from the full open position		NFPA 80 §5.2.4.1(6)	
4. Automatic Closing doors close under fire conditions (closer, hold-open & smoke detector)		NFPA 80 §5.2.14.2	
5. Closer speed set per ADA requirements (min 5 sec from full open to 12" open).		ADA §404.2.7.1	
6. Coordinator needed on pairs of single egress doors, so the inactive leaf closes before the active		NFPA 80 §5.2.4.2(7)	
7. Rating Labels are on Door & Frame & readable		NFPA 80 §5.2.4.1(5)	
8. Door gaps do not exceed clearances 1/8" (astragal required on pairs of corridor doors > 2003)		NFPA 80 §5.2.4.2(10)	
9. No field modifications that void the rating label.		NFPA 80 §5.2.4.2(11)	
10. Gaskets and edge seals are inspected to verify their presence and integrity		NFPA 80 §5.2.4.2(1)	
11. Surface of Door & Frame does Not have open holes or breaks; no grills w/o damper		NFPA 80 §4.1.4.2.2	
12. Signs must (a) be intact, legible, proper size, (b) Have required wording, (c) No screws		NFPA 80 §5.2.4.1(2)	
13. Glazing is intact and securely fastened in place, if so equipped		NFPA 80 §5.2.4.2(8)	
14. Positive Latching hardware operates and secures the door when it is closed		LSC §7.2.1.5.10	
15. Latch located >=34" high (new) and <=48" high (if installed > 2003)		LSC §7.2.1.5.11	
16. Pairs of doors must (a) both have independent unlatching, or auto flush bolt & no latch on inactive and unlatching hardware on active door; (b) Astragal on rated doors & corridor doors;		LSC §7.2.1.5	
17. Unlatch from egress side (a) with 1 motion; (b) not require use of a key or special knowledge; (c) Obvious operation in all light conditions		LSC §7.2.1.4.5	
18. Max Opening force to (a) release latch is 15 lb; (b) to set door in motion with a closer is 30 lb (new) and (c) to full open is 15 lbs (new); (d) Doors without closers open <= 5 lbs; (e) <=50 lb if installed > 1988		NFPA 80 §5.2.4.2(9)	
19. Auxiliary hardware items that interfere with operation are not installed		LSC §7.2.1.5.12	
20. "Panic-type" hardware does not have locking device (except Delayed Egress, Access-Control,		LSC §7.2.1.4.3	
21. Outswinging doors must (a) Leave >= 50% of egress width; (b) project <= 7" into width when full open		LSC §7.2.1.15.7(1)	
22. No obstruction to full opening & freely closing; Floor is Level on both sides of door		NFPA 80 §5.2.13.3	
23. No wedging or blocking of doors in the open position		NFPA 80 §6.5.4.3	
24. Kickplates: <= 48" @ Haz Rm/per LSC; <= 16" hi @ other Fire Doors, unless rated (no limit @ Smk Doors)		NFPA 80 §4.8.4.1	
25. Door Undercut <= 3/4" on Fire Doors; & the minimal needed for operation on Smoke Doors		LSC §7.2.1.9	
26. Power doors: (a) must set in motion with <= 50 lbs; (b) will swing fully open; (c) Has sign "In Emergency, Push to Open"; (d) Min 30" wide; (e) operable on power failure		LSC §7.2.1.6.1	
27. Delayed egress locks must: (a) release in <=15 sec after max 3 sec pushing with <= 15 lb; (b) manual reload only; (c) audible alarm at door; (d) release on power failure, sprinkler, one heat, or 2 smoke detectors; (e) sign says "Push Until Alarm Sounds, Door Can Be Opened In 15 Seconds" in 1" hi contrasting letters		LSC §7.2.1.6.2	
28. Access control must: (a) unlock from egress side via auto sensor; (b) unlock with manual button <=5" from door & Independent from sensor; (c) Signed "Push to Exit"; (d) unlatch on power loss, sprinkler, or fire alarm		NFPA 80 §5.2.9	
29. Hardware examined & inoperative parts, or other defects replaced without delay			

Form also includes
The Mandatory
Door Requirements
of NFPA 101

These are more
commonly found
and cited than the
NFPA 80 checks

4. MAKE IMMEDIATE REPAIRS

NFPA 80 uses words like:

“Immediate Repair”

“Without Delay”

Citations Possible:

- Anything that is NOT fixed when a surveyor visits
- There was unexcused delay, even if repaired



STEP by STEP INSPECTION

Via PHOTOS
FROM ACTUAL
INSPECTIONS

Welcome to the Feb 2018

WHEA Lunch & Learn

Lauzon
Life Safety
Consulting



RATED HINGED DOOR ANNUAL INSPECTION

Facility:

Page 1 of 3

Inspector Name

Inspection Date

Inspect doors for ALL check-points below and enter results on page 3; If door fails ANY check, enter # of check-point to indicate problem, describe details & corrective action on page 2 . EVERY rated hinged door must be included on the Report. Use form 1BC for Sliding or Rolling Rated doors.

This checklist contains the minimum inspection requirements of NFPA 80 and the major door requirements of the LSC

The Basics:

- Facility Name
 - Inspector Signature
 - Inspection Date
(completion)
-
- Show & Follow Instructions

[illegible][illegible]

Sheet 3:

Document Inspections

RESULTS OF DOOR INSPECTION

INSTRUCTIONS: Inspect doors for ALL check-points on Page 1 & enter Pass/Fail below; If door fails ANY check-point on Page 1, enter # of check to indicate problem AND describe details & corrective actions on page 2; Use additional sheets as needed

Door ID*	Floor	Wing	Room Name	**LS Function	Pass / Fail	Reasons for Failure (Enter Check # from Page 1); Describe Repair on Page 2
					<input type="checkbox"/> <input type="checkbox"/>	

1. List EACH door with a unique identifier

- Any method facility chooses
(Door # from plan, Asset #, Bar Code, etc)
- Best to place ID on door/frame
(don't cover the rating label)

Sheet 3: Document Inspections

RESULTS OF DOOR INSPECTION

INSTRUCTIONS: Inspect doors for ALL check-points on Page 1 & enter Pass/Fail below; If door fails ANY check-point on Page 1, enter # of check to indicate problem AND describe details & corrective actions on page 2; Use additional sheets as needed

Door ID*	Floor	Wing	Room Name	**LS Function	Pass / Fail	Reasons for Failure (Enter Check # from Page 1); Describe Repair on Page 2
					<input type="checkbox"/> <input type="checkbox"/>	

2. Indicate its Life Safety function

3. Indicate if door complied with ALL checks

4. If it failed ANY check, indicate which one & how/if fixed

** Life Safety Function: C=Corridor; H=Haz Rm; Occupancy Separation; B=Bldg Construction Separation; H=Horizontal Exit; EP=Exit Passageway; E=Exit; S=Smoke Barrier; V=Vertical Opening/Stairs/Shaft; O=Other

© LLSC, Jan 2018

Step-By Step


ALTERNATIVE METHOD

(Life Safety Plan)

- Facility Name
- Inspector Signature
- When Completed

INSTRUCTIONS

Inspect each door circled on drawing per the check-list on page 1; mark with "✓" if all are satisfactory or with "X" if it fails any requirement; Write reasons for failure on page 2



point on sheets as

m Page 1);

d
&
d

al Exit;
, Jan 2018

Sheet 2: Document Repairs

DEFICIENCY & CORRECTION SUMMARY

Instructions: Use this sheet to describe the issues found during the door inspection of the facility. Enter NONE if no deficiencies are found. Page 2 should always be attached to the actual inspection report. All deficiencies must be corrected as soon as possible after discovery. Document each step of the repair process. Re-inspect / test door to ensure compliance.

Door ID	Floor	Wing	Room Name	ISSUE # & DESCRIPTION	CORRECTIVE ACTIONS	DATE & WHO REPAIRED
---------	-------	------	-----------	-----------------------	--------------------	---------------------

1. List EACH door with a unique identifier

2. Indicate What Check(s) Were failed

3. Indicate what was done to correct the issue

4. Indicate When the repair was fully complete

Step-By Step

Visual inspection must be performed from both sides of door prior to testing

1. No parts are missing or broken
2. No Damage on Hardware, Door, frame, & hinges secured, aligned
3. Closer is operational so each doors completely close from the full open position
4. Automatic Closing doors close under fire conditions (closer, hold-open & smoke detector)
5. Closer speed set per ADA requirements (min 5 sec from full open to 12° open).
6. Coordinator needed on pairs of single egress doors, so the inactive leaf closes before the active
7. Rating Labels are on Door & Frame & readable
8. Door gaps do not exceed clearances 1/8" (astragal required on pairs of corridor doors > 2003)
9. No field modifications that void the rating label.
10. Gaskets and edge seals are inspected to verify their presence and integrity
11. Surface of Door & Frame does Not have open holes or breaks; no grills w/o damper
12. Signs must (a) be intact, legible, proper size, (b) Have required wording, (c) No screws
13. Glazing is intact and securely fastened in place, if so equipped
14. Positive Latching hardware operates and secures the door when it is closed
15. Latch located >=34" high (new) and <=48" high (if installed > 2003)
16. Pairs of doors must (a) both have independent unlatching, or auto flush bolt & no latch on inactive and unlatching hardware on active door; (b) Astragal on rated doors & corridor doors;
17. Unlatch from egress side (a) with 1 motion; (b) not require use of a key or special knowledge; (c) Obvious operation in all light conditions
18. Max Opening force to (a) release latch is 15 lb; (b) to set door in motion with a closer is 30 lb (new) and (c) to full open is 15 lbs (new); (d) Doors without closers open <= 5 lbs; (e) <=50 lb if installed >
19. Auxiliary hardware items that interfere with operation are not installed
20. "Panic-type" hardware does not have locking device (except Delayed Egress, Access-Control,
21. Outswinging doors must (a) Leave >= 50% of egress width; (b) project <= 7" into width when full op
22. No obstruction to full opening & freely closing; Floor is Level on both sides of door
23. No wedging or blocking of doors in the open position
24. Kickplates: ≤ 48" @ Haz Rm(per LSC); ≤ 16" hi @other Fire Doors, unless rated (no limit @Smk Doors)
25. Door Undercut < 3/4" on Fire Doors; & the minimal needed for operation on Smoke Doors
26. Power doors: (a) must set in motion with <= 50 lbs; (b) will swing fully open; (c) Has sign "In Emergency, Push to Open"; (d) Min 30" wide; (e) openable on power failure
27. Delayed egress locks must: (a) release in <=15 sec after max 3 sec pushing with <= 15 lb; (b) manual relock only; (c) audible alarm at door; (d) release on power failure, sprinkler, one heat, or 2 smoke detectors ; (e) sign says "Push Until Alarm Sounds, Door Can Be Opened In 15 Seconds" in 1" hi contrasting letters
28. Access control must: (a) unlock from egress side via auto sensor; (b) unlock with manual button <=5' from door & Independent from sensor; (c) Signed "Push to Exit"; (d) unlatch on power loss, sprinkler, or fire alarm
29. Hardware examined & inoperative parts, or other defects replaced without delay

NFPA 80 §5.2.4.1

NFPA 80 §5.2.4.1(4)

NFPA 80 §5.2.4.1(3)

NFPA 80 §5.2.4.1(6)

We're going to look at each of the Check-Points (via photos)

NFPA 80 §5.2.4.2(8)

LSC §7.2.1.5.10

LSC §7.2.1.5.11

LSC §7.2.1.5

In the same sequence as the Check List

NFPA 80 §5.2.15.3

NFPA 80 §6.5.4.3

NFPA 80 §4.8.4.1

LSC §7.2.1.9

LSC §7.2.1.6.1

LSC §7.2.1.6.2

NFPA 80 §5.2.9

Use a Walk-Around
“Cheat-Sheet”
to recall the 29
Key Points

DOOR INSPECTION KEY-POINTS

Inspect BOTH Sides

- | | |
|------------------------|------------------------|
| 1. No Missing Parts | 16. Pair Latching |
| 2. No Damage | 17. Door Unlatching |
| 3. Closer | 18. Opening Force |
| 4. Auto Closer | 19. Auxiliary Hardware |
| 5. ADA Speed | 20. “Panic” Security |
| 6. Coordinator | 21. Door Obstructions |
| 7. Rating Label | 22. Free Door Swing |
| 8. Gaps | 23. Door Blocking |
| 9. Field Modify | 24. Kick plate |
| 10. Gaskets/Seals | 25. Undercut |
| 11. Surface Conditions | 26. Powered Doors |
| 12. Approved Signs | 27. Delayed Egress |
| 13. Glazing | 28. Access Control |
| 14. Door Latching | 29. Immediate Repair |
| 15. Latch Height | |

OVERALL CHECK-POINT

Checkpoint #

1

NO MISSING PARTS

No parts are missing or broken

Missing parts is a general overall key point to keep in mind for all the remaining checks

OVERALL CHECK-POINT

Checkpoint #

1

NO Missing Parts



Missing Screw on Closer

OVERALL CHECK-POINT

Checkpoint #

1

NO Missing Parts



Missing Screws on Hinge

OVERALL CHECK-POINT

Checkpoint #

1

NO Missing Parts



Missing Key Core on Latch

OVERALL CHECK-POINT

Checkpoint #

1

NO Missing Parts



Missing Bottom Flush Latch

OVERALL CHECK-POINT

Checkpoint #

1

NO Missing Parts



Missing Bottom Rod

Verify if Multi-Point latching is
needed (Check door listing)

NFPA 80-2010, 7.4.3.3

7.4.3.3* Hinges and Latches, Number and Length. The number and length of both the hinges and the latches shall be in accordance with the manufacturer's label service procedure and individual published listing.

OVERALL CHECK-POINT


Checkpoint #

1

NO Missing Parts

Indicators of a Missing Bottom Rod

- Floor Strike w/o bottom rod



“Something has changed from original rated install”

OVERALL CHECK-POINT

Checkpoint #

2

NO DAMAGE

Door assembly in working order;
no visible signs of damage

Damage is a general overall key
point to keep in mind for all the
remaining checks

OVERALL CHECK-POINT

Checkpoint #


2

No Damage



Bent Bottom Rod

NOW we get started Inspecting in Earnest



DOOR INSPECTION KEY-POINTS

Inspect BOTH Sides

- | | |
|------------------------|------------------------|
| 1. No Missing Parts | 16. Pair Latching |
| 2. No Damage | 17. Door Unlatching |
| 3. Closer | 18. Opening Force |
| 4. Auto Closer | 19. Auxiliary Hardware |
| 5. ADA Speed | 20. "Panic" Security |
| 6. Coordinator | 21. Door Obstructions |
| 7. Rating Label | 22. Free Door Swing |
| 8. Gaps | 23. Door Blocking |
| 9. Field Modify | 24. Kick plate |
| 10. Gaskets/Seals | 25. Undercut |
| 11. Surface Conditions | 26. Powered Doors |
| 12. Approved Signs | 27. Delayed Egress |
| 13. Glazing | 28. Access Control |
| 14. Door Latching | 29. Immediate Repair |
| 15. Latch Height | |

Hinged DOOR INSPECTION

Checkpoint #

3

**CLOSER is
OPERATING**

Closer is operational so the door
completely closes



Hinged DOOR INSPECTION

Checkpoint #

3

Closer Operation



Missing Closer

Hinged DOOR INSPECTION

Checkpoint #
3

Closer Operation




Closer must
have enough
pull force to
latch to retract

Especially check
WOOD doors,
which tend to
expand & warp

Hinged DOOR INSPECTION

Checkpoint #
3

Closer Operation




**Push (or Pull)
to confirm
Latching**

Hinged DOOR INSPECTION

Checkpoint #
3

Closer Operation



**Door Scraping on frame
indicates possible closing issue**

Hinged DOOR INSPECTION

Checkpoint #

3

Closer Operation



Door Rub on
Floor Mat
prevents door
closing

Hinged DOOR INSPECTION

Checkpoint #

3

Closer Operation



Test
Operation
Old Style

Hinged DOOR INSPECTION

Checkpoint #

4

AUTO-CLOSE OPERATING

Automatic Closing doors close under fire conditions, with properly installed closer, mag hold-open, and smoke detector

Hinged DOOR INSPECTION

Checkpoint #

4

Auto Closing

Automatic-closing fire doors

- a. Self-Closing Device
- b. Hold-Open Device
- c. Smoke Detector



Hinged DOOR INSPECTION

Checkpoint

4

a. Closer



Confirm
Closer fully
closes the
door from full
open position

Hinged DOOR INSPECTION

Checkpoint #

4

b. Hold-Open



Confirm
Hold-Open
was Listed
with use of a
Chain

Hinged DOOR INSPECTION

Checkpoint

4

b. Hold-Open



Do not
custom make
Hold-Open
Extension
Arms

Hinged DOOR INSPECTION

Checkpoint

4

b. Hold-Open




Do not
custom make
Hold-Open
Extension
Arms

Hinged DOOR INSPECTION

Checkpoint #
4

c. Smoke Detector



Stand in Door
Opening & Look
on both sides

MUST have
Smoke Detector

Refer to NFPA 72-2010, 17.7.5.6

Hinged DOOR INSPECTION

Checkpoint #

4

c. Smoke Detector

Measure Distance of
Detector to Door

(Situation #1)

If full area detection

on both sides:

≤15' & max 30' oc



Refer to NFPA 72-2010, 17.7.5.6.1 and 17.7.3

Hinged DOOR INSPECTION


Checkpoint #

4

c. Smoke Detector

(Situation #2)

If Stand-Alone detector:
Min 1' and $\leq 5'$



Refer to NFPA 72-2010, 17.7.5.6.5.1

Hinged DOOR INSPECTION

Checkpoint #
4

c. Smoke Detector



(Situation #2)

If **Stand-Alone** detector:

Must Also Measure Height of Door Header


- Detector needed on any side >24"

Refer to NFPA 72-2010, 17.7.5.6.5.1

Hinged DOOR INSPECTION

Checkpoint #
4

c. Smoke Detector



(Situation #2)

If Stand-Alone detector:

Soffits can
hide the
“true” header
height

Refer to NFPA 72-2010, 17.7.5.6.5.1

Hinged DOOR INSPECTION

Checkpoint #
4

c. Smoke Detector



Must test that
Detector
actually
closes the
door

Coordinate door inspection with the
annual fire alarm inspection
(they must coincide)

Hinged DOOR INSPECTION

Checkpoint #

5

CLOSER SPEED

Closer speed set per ADA requirements (minimum 5 sec from full open to 12" open)

Hinged DOOR INSPECTION

Checkpoint #

5

ADA Speed

Min 5 sec to close from full open



Hinged DOOR INSPECTION

Checkpoint #

6

**COORDINATOR
Is OPERATING**

Coordinator is needed on pairs of
single egress doors, so the
inactive leaf closed before the
active leaf




Hinged DOOR INSPECTION

Checkpoint #
6

NFPA 80 Requirement

6.4.1.2.1 Where there is an astragal or projecting latch bolt that prevents the inactive door from closing and latching before the shall be used.



50%
Failure
Rate

Hinged DOOR INSPECTION

Checkpoint #
6

Test Coordinator

Step 1

Close Active
Door so
Rests on
Coordinator
Hold-Open
Arm



Hinged DOOR INSPECTION

Checkpoint #
6

Test Coordinator



Step 2
Release
Inactive
Door so it
pushes
against
coordinator
mechanism

Hinged DOOR INSPECTION

Checkpoint #
6

Test Coordinator

Step 3

Pull on door
to check for
positive self
latching



Hinged DOOR INSPECTION

Checkpoint #

7

RATING LABELS

Signs that are required to be placed on doors must be intact, legible, properly sized and have the required wording

Hinged DOOR INSPECTION

Checkpoint #
7

Rating Labels

LABELS



- Provide visible proof that the components are the same as those that were tested by independent laboratories for use on fire-rated doors

- Labels are applied at the factory before the door assembly components are shipped



- Labeled door assemblies are only valid when all required components are installed and function properly

Hinged DOOR INSPECTION

Checkpoint # 7

Rating Labels



Must be
on Both
Door
&
Frame

Hinged DOOR INSPECTION

Checkpoint # 7

Rating Labels



- Must be fully readable

Hinged DOOR INSPECTION

Checkpoint # 7

a. Door Labels



If there's no label on the Door Jamb:

1. May be on the header
2. May be excepted from rating

Hinged DOOR INSPECTION

Checkpoint # 7

a. Door Labels


Check
by
feeling
for the
label on
the
header



Hinged DOOR INSPECTION

Checkpoint # 7

a. Door Labels



Or use a mirror

Move mirror
along the head

Hinged DOOR INSPECTION


Checkpoint # 7

a. Door Labels

Until a label is
found

Confirm the rating

(learn to read backwards)



Hinged DOOR INSPECTION

Checkpoint #
7

a. Door Labels

Beware of
Continuous
Hinges That
Cover Labels



Hinged DOOR INSPECTION

Checkpoint # 7

a. Door Labels



Added note may help, but surveyors do NOT need to accept instead of seeing the label

Hinged DOOR INSPECTION

Checkpoint # 7

a. Door Labels



Label Cannot be
removed &
reapplied


Or Cut

Hinged DOOR INSPECTION

Checkpoint #
7

a. Door Labels

Manufacturer
Door info is NOT
a Rating Label



Hinged DOOR INSPECTION

Checkpoint #

7

a. Door Labels

Read the Fine Print



Test did NOT include the Hose Stream

Hinged DOOR INSPECTION

Checkpoint #
7

a. Door Labels

Read the Fine Print




Requires use of Panic or Fire Exit Device

Hinged DOOR INSPECTION

Checkpoint # 7

b. Frame Labels



If there's no label
on the Frame:

In the past Frames &
Doors were rated as
an Assembly so
Frame may NOT
have been labels

(TJC accepts, CMS does not)

Hinged DOOR INSPECTION

Checkpoint #
7

b. Frame Labels

Stamped
into Frame



Hinged DOOR INSPECTION

Checkpoint # 7

b. Frame Labels



“Embossed”
but
Painted

Hinged DOOR INSPECTION

Checkpoint #
7

b. Frame Labels



Painted,
Not
Readable

Hinged DOOR INSPECTION

Checkpoint #
7

b. Frame Labels

Field Inspected



Hinged DOOR INSPECTION

Checkpoint #

8

FRAME/DOOR GAPS


- (a) Frame Gaps per CMS memo
- (b) Door Gaps do not exceed the maximum clearance
- (c) Astragal required on corridor doors since 2003)

Hinged DOOR INSPECTION

Checkpoint #
8

a. Frame Gap


CMS Letter 07-18 on Frame Gaps



Hinged DOOR INSPECTION

Checkpoint #
8

b. Door Gap



If you can
see
through it,
Measure

Hinged DOOR INSPECTION

Checkpoint #
8

b. Door Gap



Measure on
the "pull" side
of the door



Hinged DOOR INSPECTION

Checkpoint

8

c. Astragal

NFPA 80 Astragal Requirements

6.4.1.2.1 Where there is an astragal or projecting latch bolt that prevents the inactive door from closing and latching before the active door closes and latches, a coordinating device shall be used.

6.4.7.2* Pairs of doors that require astragals shall have at least one attached in place to project approximately 3/4 in. (19 mm) or as otherwise indicated in the individual published listings.

Hinged DOOR INSPECTION

Checkpoint #
8

c. Astragal



Single Swing:
Needs

- Astragal
- Coordinator

Hinged DOOR INSPECTION

Checkpoint #

8

c. Astragal




Confirm the
Astragal
actually
closes the
gap

Hinged DOOR INSPECTION

Checkpoint #
8

c. Astragal



**Must confirm that rating of
brush astragal matches
the door rating**

**Testing to 4L10-UL is not enough.
Should obtain test report by an
independent listing agency that
shows the duration of the test. Do
not rely on sales literature.**

Hinged DOOR INSPECTION

Checkpoint #
8

c. Astragal



Must confirm rating of
vinyl astragal matches
the door rating

Testing to UL10C is not enough.
Should obtain test report by an
independent listing agency that
shows the duration of the test.
Do not rely on sales literature.

Hinged DOOR INSPECTION

Checkpoint #

FIELD 9 MODIFICATIONS

No field modifications that void the label.

▲ 5.1.5.2 Field Modifications.

5.1.5.2.1 In cases where a field modification to a fire door or a fire door assembly is desired, the laboratory with which the product or component being modified is listed shall be contacted and a description of the modifications shall be presented to that laboratory.

5.1.5.2.2 If the laboratory finds that the modifications will not compromise the integrity and fire resistance capabilities of the assembly, the modifications shall be permitted to be authorized by the laboratory without a field visit from the laboratory.


Hinged DOOR INSPECTION

Checkpoint # 9

Field Modifications

If you field modify:

- Confirm ok with Door/Frame Listing, or
- Field certify



Intertek

Email: [REDACTED]

Intertek Project/Report Number: G101970370

Enclosed is a copy of the report issued on the following field inspection project:

Jobsite: [REDACTED]

DESCRIPTION OF PROJECT: Field Inspection of Fire Doors and/or Fire Door Frames - openings all compliant.

OPENING IDENTIFICATION(S): VARIOUS - Please refer to enclosed report.
REQUIREMENTS (if any) FOR RE-INSPECTION BY INTERTEK AND/OR AUTHORITY HAVING JURISDICTION: None

This report completes our work on this project. Please forward a copy of this report to the local authority having jurisdiction - if applicable.

Thank you for allowing Intertek to be of service. Please feel free to contact us if you have any questions regarding this inspection, or if we can be of assistance on future projects.

Report Reviewed and Issued by:

Hinged DOOR INSPECTION

Checkpoint #

9

Field Modifications

NEVER MODIFY* a listed door or frame

Typical Modifications:

- Changing Closer
- Changing Latch
- Installing Mag Lock
- Installing Elec Strike
- Screwed Signs

- Changing Hinges
- Adding Deadbolts
- Adding Combo
- Adding Auto Open
- Make-shift Repairs

MOST violated Life Safety “Rule”

Hinged DOOR INSPECTION

Checkpoint #

9

a. Door Modification



Combo Locks can Void Label

- If Lock Model is not Listed by Door Mfr
- If Lock itself is not listed for the door rating

Hinged DOOR INSPECTION

Checkpoint #

9

a. Door Modifications



Convert
Method of
Latching

Hinged DOOR INSPECTION

Checkpoint #

9

a. Door Modifications



Half-Surface Hinges can Void Door Label

- If not shown on door mfr Listing Sheet or Field Applied

Hinged DOOR INSPECTION

Checkpoint #

9

a. Door Modifications




Field Modify
an Astragal

Hinged DOOR INSPECTION

Checkpoint #

9

a. Door Modifications



Field
In-Fill
On Door

Hinged DOOR INSPECTION

Checkpoint #
9

b. Frame Modifications



Look at
Strike Area

Hinged DOOR INSPECTION

Checkpoint #

9

b. Frame Modifications



Field Cut-In Strike

Hinged DOOR INSPECTION

Checkpoint #

9

b. Frame Modifications



Field Cut-In
Electric
Strike

Hinged DOOR INSPECTION

Checkpoint #

9

b. Frame Modifications



Field Cut-In
Electric
Strike

Hinged DOOR INSPECTION

Checkpoint #

9

b. Frame Modifications



Field Cut-In
Dead-Bolt
Hole

Hinged DOOR INSPECTION

Checkpoint #
9

Field Modifications



Frame
Notched for
Pipes

Hinged DOOR INSPECTION

Checkpoint #

10

GASKETS & SEALS

Gaskets and edge seals are inspected to verify their presence and integrity

NFPA 80: 6.4.8 Gasketing. Gasketing on fire doors or frames shall be in accordance with the published listings of the door, frame, or gasketing material manufacturer.

Hinged DOOR INSPECTION

Checkpoint #
10


Gasket/Seal

Popular Spec Feature

Health care doors are NOT required by LSC to be smoke-leakage rated (CMS Letter 17-38)



Gaskets sometimes prevent door latching



Hinged DOOR INSPECTION

Checkpoint #

11

SURFACE CONDITIONS

No open holes or breaks in
surfaces of the door or frame

Hinged DOOR INSPECTION

Checkpoint #
11

a. Door Conditions



Edge of door
Scraping

Note the manual
slide bolt

Hinged DOOR INSPECTION

Checkpoint #
11

a. Door Conditions



**“Breaks”
are very
subjective**

Hinged DOOR INSPECTION

Checkpoint #
11

a. Door Conditions



“Breaks”
are very
subjective

Hinged DOOR INSPECTION

Checkpoint #
11

a. Door Conditions




“Breaks” are
very subjective

Hinged DOOR INSPECTION

Checkpoint #
11

a. Door Conditions



Is Scratched
Paint on the
Door a
violation?

Hinged DOOR INSPECTION

Checkpoint #
11

a. Door Conditions




Hole from
Old Screw

Hinged DOOR INSPECTION

Checkpoint #
11

a. Door Conditions



Unfilled
Door Holes

Hinged DOOR INSPECTION

Checkpoint #
11

a. Door Conditions



Grill must have a fire damper with same rating as the door & be listed for use by the door mfr

Note: If door is located on a corridor wall, grills are not permitted, even with a damper

Hinged DOOR INSPECTION

Checkpoint #
11

b. Frame Conditions



Missing Silencer



Hinged DOOR INSPECTION

Checkpoint #
11

b. Frame Conditions



Unfilled Strike Holes

Hinged DOOR INSPECTION

Checkpoint #
11

b. Frame Conditions



Unfilled
Frame
Holes

Hinged DOOR INSPECTION

Checkpoint #

12

APPROVED SIGNS

Signs that are required to be placed on doors must be intact, legible, properly sized and have the required wording

Hinged DOOR INSPECTION

Checkpoint #
12

Door Signage



**No
Exit**

Since 1988

Hinged DOOR INSPECTION

Checkpoint #
12

Door Signage



No
screws

Hinged DOOR INSPECTION

Checkpoint #

13

**APPROVED
GLAZING**

Glazing is intact & securely
fastened in place, if so equipped

Hinged DOOR INSPECTION

Checkpoint #

14

DOOR LATCHING

- (a) Be Positive (self) latching
- (b) Latch operates and secures the door when it is closed

Hinged DOOR INSPECTION

Checkpoint #
14

a. Positive Latch




Positive Latch
=
Self Latch

Hinged DOOR INSPECTION

Checkpoint #
14

b. Secures Door



Tape over
strike hole

Missing
the Strike
Plate

Hinged DOOR INSPECTION

Checkpoint #
14

b. Secures Door



Turn knob
all the way
& see if
plunger
sticks
inside
door

Hinged DOOR INSPECTION

Checkpoint #
14

b. Secures Door



Door Seals

Can Prevent
full Self-
Closing &
Latching

Hinged DOOR INSPECTION

Checkpoint #

15

LATCH HEIGHT

Latch must be located 34" or higher from the floor and 48" or lower (LSC, 7.2.1.5.10.1)

Hinged DOOR INSPECTION

Checkpoint #
15

Latch Height



Measure if
close to limits

Hinged DOOR INSPECTION

Checkpoint #

16

PAIR LATCHING

Pairs of doors: Both leaves must have independent unlatching or auto-flush bolt and no latch on inactive door & unlatching hardware on the active door

(LSC, 7.2.1.5.11)

Hinged DOOR INSPECTION

Checkpoint #
16

Pair Latching



1. Both
Independent
Unlatched

OR

Hinged DOOR INSPECTION

Checkpoint #
16

Pair Latching



2. No Latch
on Inactive;

Latch on
Active

Hinged DOOR INSPECTION

Checkpoint #
16

Pair Latching



Manual Slide
Bolts permitted
on Mech Rms, IF

- Kept in the locked position
- Used only for equipment in/out
- Not a healthcare corridor door

Hinged DOOR INSPECTION

Checkpoint #

17

DOOR UNLATCHING

Must be readily opened from egress side

- (a) 1 motion latch release
- (b) without using a key or tool or special knowledge (some exceptions)
- (c) obvious operation in all lighting conditions;

Hinged DOOR INSPECTION

Checkpoint #
17

a. 1 Motion



Dead-Bolt:

- Not Self-Latching
- Requires 2 Motions

Hinged DOOR INSPECTION

Checkpoint #
17

b. No Key or Card

**EGRESS Must Unlatch without a
“tool” or special knowledge (24 / 7)**



**Any of these on an egress door
should invite further investigation**

Hinged DOOR INSPECTION

Checkpoint #

18

OPENING FORCES

Opening force to

- (a) Releases latch is 15 lbs or less
- (b) set door in motion is 30 lbs or less in new or 50 lbs or less in existing;
- (c) force to fully open is 15 lbs or less in new or 50 lbs or less in existing;
- (d) force to doors without closers is 5 lbs or less (LSC, 7.2.1.4.5)

Hinged DOOR INSPECTION

Checkpoint # 18

Door Force

Do NOT buy
the 0-35 pound
gauge



- Not usable for Existing Doors
- Powered Doors

Buy the 10-50 pound gauge



Amazon
(an example only)

TechnologyLK

Door Pressure Gauge, 10-50 Lbs

Be the first to review this item

Available from these sellers.

New (1) from \$65.99 + \$5.15 shipping

Hinged DOOR INSPECTION

Checkpoint #
18

a. Unlatch Force

Lever Latch

Calendrical Knob?

1. Set Guage to 0 lb

2. Push down on
lever latch



Hinged DOOR INSPECTION

Checkpoint #
18

a. Unlatch Force

Lever Latch



3. Push Down to
Unlatch

Hinged DOOR INSPECTION

Checkpoint #
18

a. Unlatch Force

Lever Latch

4. Read Gauge
(Max 15 lbs)




Hinged DOOR INSPECTION

Checkpoint #
18

a. Unlatch Force

“Panic” Latch




2. Push on Gauge
Until Latch Releases

Hinged DOOR INSPECTION

Checkpoint #
18

a. Unlatch Force

“Panic” Latch



2. Push on Gauge
Until Latch Releases

Hinged DOOR INSPECTION

Checkpoint #
18

b. Motion Force

Lever Latch



1. Reset Gauge to 0
lbs

Hinged DOOR INSPECTION

Checkpoint #
18

b. Motion Force

Lever Latch



3. Push on Gauge until Door is about 30% open



Hinged DOOR INSPECTION

Checkpoint #
18

b. Motion Force

Lever Latch




4. Read Gauge
(Max 30 lbs)

Hinged DOOR INSPECTION

Checkpoint #
18

c. Open Force

Lever Latch



1. Reset Gauge to 0
lbs

Hinged DOOR INSPECTION

Checkpoint #
18

c. Open Force

Lever Latch




3. Push on Gauge until
Door is Fully Open

Hinged DOOR INSPECTION

Checkpoint #
18

c. Open Force

Lever Latch



4. Read Gauge
(Max 15 lbs)

Hinged DOOR INSPECTION

Checkpoint #

19

AUXILIARY HARDWARE


Auxiliary hardware that interferes with function is not installed on the door or frame

Hinged DOOR INSPECTION

Checkpoint #
19

Auxiliary Hardware

Follow Manufacturer's Listed Instructions



Hinged DOOR INSPECTION

Checkpoint #
19

Auxiliary Hardware



- Not Interfere
- UL Listed

Hinged DOOR INSPECTION

Checkpoint #
19

Auxiliary Hardware



- Not Interfere
- UL Listed

Hinged DOOR INSPECTION

Checkpoint #
19

Auxiliary Hardware



- Not Interfere
- UL Listed

Hinged DOOR INSPECTION

Checkpoint #
19

Auxiliary Hardware



- Not Interfere
- UL Listed

Hinged DOOR INSPECTION

Checkpoint #

20

“PANIC” SECURITY


No security devices can be on doors with
“panic” hardware of rated doors (LSC,
7.2.1.5.12)

Hinged DOOR INSPECTION

Checkpoint #
20

“Panic” Hardware

Fire Exit Hardware Looks & Operates like Panic Hardware



Only approved **Fire Exit Hardware** shall be used
on fire doors

Hinged DOOR INSPECTION

Checkpoint #
20

No Locking

Fire Exit Hardware Looks & Operates like Panic Hardware



Investigate egress door with “panic” type hardware if these are present

Hinged DOOR INSPECTION

Checkpoint #

21

DOOR OBSTRUCTION

Out-swinging doors must

- (a) Leave at least 50% of the required egress width clear; and
- (b) (2) Project no more than 7" into the required width when the door is fully open (LSC, 7.2.1.4.3)

Hinged DOOR INSPECTION

Checkpoint #
21

Obstructions



50%Rule

Applies
when door
is open
part way

Hinged DOOR INSPECTION

Checkpoint #

21

Obstructions



7" Rule

Applies
when door
is open to
max

Hinged DOOR INSPECTION

Checkpoint #

22

FREE DOOR MOVEMENT

- (a) No Obstruction to door opening fully and closing freely;
- (b) Floor space on both side of the opening must be level within $\frac{1}{2}$ " for the width of the door (LSC, 7.2.1.15.7)

Hinged DOOR INSPECTION

Checkpoint #
22

a. No Obstruction



Hinged DOOR INSPECTION

Checkpoint #
22

b. Level Landing



Max ½" height variance
(LSC, 7.2.1.3.1)

Hinged DOOR INSPECTION

Checkpoint #

23

DOOR BLOCKING

No Wedging or blocking of doors
in the open position (NFPA 80)

Hinged DOOR INSPECTION

Checkpoint #
23

No Blocking Open



No Wedges

Hinged DOOR INSPECTION

Checkpoint #
23

No Blocking Open



No
Weighted
Objects

Hinged DOOR INSPECTION

Checkpoint #

23

No Blocking Open



No Weighted Objects

Hinged DOOR INSPECTION

Checkpoint #
23

No Blocking Open



No Belts or Ropes

Hinged DOOR INSPECTION

Checkpoint #
23

No Blocking Open



No Kick Stops

Hinged DOOR INSPECTION

Checkpoint #

24

KICKPLATE HEIGHT

Kickplates must be

- $\leq 48''$ high on Haz Rm Doors
- $\leq 16''$ high on other Fire Doors
- No limit on Smoke Barrier Doors

Unless protective plate is Listed

Hinged DOOR INSPECTION

Checkpoint #

24

Kick Plate



Need Plate
Listing
Document if
over the
permitted
height

Hinged DOOR INSPECTION

Checkpoint #
24

Kick Plate



Need Plate
Listing
Document if
over the
permitted
height

Hinged DOOR INSPECTION

Checkpoint #

25

UNDERCUT HEIGHT

Door Undercut must be

- $\leq 3/4$ " on Fire Doors
- Minimum Needed for Operation on Smoke Barrier Doors

Hinged DOOR INSPECTION

Checkpoint #
25

Undercuts



Shop-Made Undercut Gauge

- $\frac{3}{4}$ " max for rated doors
- 1" max for corridor doors

Hinged DOOR INSPECTION

Checkpoint #
25

Undercuts



Undercut Gauge

- $\frac{3}{4}$ " max for rated doors
- 1" max for corridor doors

Hinged DOOR INSPECTION

Checkpoint #
25

Undercuts

Measure



Hinged DOOR INSPECTION

Checkpoint #
25

Undercuts

Measure at
several locations

- Pass at Center
- Fail at Edge

(Due to floor slope)



Hinged DOOR INSPECTION

Checkpoint #
25

Undercuts



Sweep may
not be
accepted if
on Listed
for Rated
Doors

Hinged DOOR INSPECTION

Checkpoint #

26**POWERED
DOORS**

Power doors must (a) be openable on power failure (b) must set in motion with 50 lb or less; (c) Will swing fully open; (d) Have a sign: "In Emergency, Push to Open"; (e) If fewer than 50 occupants, sliding doors do not need to breakaway or have a sign; (f) Minimum of 30" wide
(LSC 7.2.1.9)

Hinged DOOR INSPECTION

Checkpoint #

27

DELAYED EGRESS

Delayed egress hardware must (a) Release in 15 sec or less when pushed with 15 lbs or 3 seconds; (b) Sound an audible alarm at the door; (c) Release on loss of power, on sprinkler, 1 heat detector, or 2 smoke detectors; (d) Have appropriate sign (LSC, 7.2.1.6.1)


Hinged DOOR INSPECTION

Checkpoint #

27

Delayed Egress

Required Sign



Contrasting Color?

Hinged DOOR INSPECTION

Checkpoint #

28

ACCESS CONTROL

Access control hardware must (a) Unlock from egress side via an auto sensor; (b) Unlock with a manual release switch located 5' or less from the door & is independent of the auto sensor; (c) Has sign "Push to Exit"; (d) Unlatches on loss of power, sprinkler, or fire alarm (LSC, 7.2.1.6.2)

Hinged DOOR INSPECTION

Checkpoint #
28

a. Sensor

**Must have
Auto
Sensor**



Hinged DOOR INSPECTION

Checkpoint #
28

b. Secondary Button

Must have Manual Button

DOOR

← Max 5' →



Hinged DOOR INSPECTION

Checkpoint #

29

**REPAIR
w/o DELAY**

Hardware shall be examined & inoperative hardware, parts, or other defects shall be replaced without delay

Hinged DOOR INSPECTION

Checkpoint #
29

Repair w/o Delay



Must Fix Immediately

Hinged DOOR INSPECTION

Checkpoint #
29

Repair w/o Delay



**Must Fix
Immediately**

Inspection of Rated Doors

Visual

1. No parts are <u>missing</u> or broken	NFPA 80 §5.2.4.1(4)
2. No Damage on <u>Hardware</u> , Door, frame, & hinges secured, aligned	NFPA 80 §5.2.4.1(3)
3. <u>Closer</u> is operational so each doors completely close from the full open position	NFPA 80 §5.2.4.1(6)
4. <u>Automatic Closing</u> doors close under fire conditions (closer, hold-open & smoke d	
5. <u>Closer speed</u> set per ADA requirements (min 5 sec from full open to 12° open).	
6. <u>Coordinator</u> needed on pairs of single egress doors, so the inactive leaf closes bef	
7. <u>Rating Labels</u> are on Door & Frame & readable	
8. Door <u>gaps</u> do not exceed clearances 1/8" (astragal required on pairs of corridor d	
9. No <u>field modifications</u> that void the rating label.	
10. <u>Gaskets</u> and edge seals are inspected to verify their presence and integrity	
11. <u>Surface of Door & Frame</u> does Not have open holes or breaks; no grills w/o dam	
12. <u>Signs</u> must (a) be intact, legible, proper size, (b) Have required wording, (c) No screws	NFPA 80 §5.2.4.1(2)
13. <u>Glazing</u> is intact and securely fastened in place, if so equipped	
14. <u>Positive Latching</u> hardware operates and secures the door when it is closed	
15. <u>Latch located</u> >=34" high (new) and <=48" high (if installed > 2003)	
16. <u>Pairs</u> of doors must (a) both have independent unlatching, or auto flush bolt & n and unlatching hardware on active door; (b) Astragal on rated doors & c	
17. <u>Unlatch</u> from egress side (a) with <u>1 motion</u> ; (b) <u>not require</u> use of a key or special (c) <u>Obvious operation</u> in all light conditions	
18. Max <u>Opening force</u> to (a) <u>release</u> latch is 15 lb; (b) to set door in <u>motion</u> with a closer is 30 lb (new) and (c) to <u>full open</u> is 15 lbs (new); (d) Doors without closers open <= 5 lbs; (e) <=50 lb if installed > 1988	LSC §7.2.1.4.5
19. <u>Auxiliary hardware</u> items that interfere with operation are not installed	NFPA 80 §5.2.4.2(9)
20. "Panic-type" hardware does not have <u>locking device</u> (except Delayed Egress, Access-Control,	LSC §7.2.1.5.12
21. <u>Outswinging doors</u> must (a) Leave >= 50% of egress width; (b) project <= 7" into width when full open	LSC §7.2.1.4.3
22. No <u>obstruction</u> to full opening & freely closing; <u>Floor is Level</u> on both sides of door	LSC §7.2.1.15.7(1)
23. No <u>wedging</u> or blocking of doors in the open position	NFPA 80 §5.2.13.3
24. <u>Kickplates</u> : ≤ 48" @Haz Rm(per LSC); ≤ 16" hi @other Fire Doors, unless rated (no limit @Smk Doors)	NFPA 80 §6.5.4.3
25. Door <u>Undercut</u> < 3/4" on Fire Doors; & the minimal needed for operation on Smoke Doors	NFPA 80 §4.8.4.1
26. <u>Power doors</u> : (a) must set in motion with <= 50 lbs; (b) will swing fully open; (c) Has sign "In Emergency, Push to Open"; (d) Min 30" wide; (e) openable on power failure	LSC §7.2.1.9
27. <u>Delayed egress</u> locks must: (a) release in <=15 sec after max 3 sec pushing with <= 15 lb; (b) manual relock only; (c) audible alarm at door; (d) release on power failure, sprinkler, one heat, or 2 smoke detectors ; (e) sign says "Push Until Alarm Sounds, Door Can Be Opened In 15 Seconds" in 1" hi contrasting letters	LSC §7.2.1.6.1
28. <u>Access control</u> must: (a) unlock from egress side via auto sensor; (b) unlock with manual button <=5' from door & Independent from sensor; (c) Signed "Push to Exit"; (d) unlatch on power loss, sprinkler, or fire alarm	LSC §7.2.1.6.2
29. <u>Hardware</u> examined & inoperative parts, or other defects replaced without delay	NFPA 80 §5.2.9

- There are many door requirements to check

- It gets easier with experience



Inspection of Rated Doors

Questions?

Welcome to the Feb 2018

WHEA Lunch & Learn

Lauzon
Life Safety
Consulting

