



Preparing for Fire Door Inspections



**Have You
Heard This
Before?**



Have You Heard This Before?

**Why can't I prop
the door open
with a wedge?
I'll be nearby in
case of a fire.**



Have You Heard This Before?

**I don't want
anyone using
that exit door.
Do something so
people have to
use a different
door.**



Have You Heard This Before?

**There's room in
the hall next to
the fire exit.
Let's store those
big boxes there.**



Have You Heard This Before?

**That fire door
doesn't always
close all the way.
Fix it whenever
you get time.**





Have You Heard This Before?


**Have you
inspected the
fire doors?**



Fire Door Requirements



NFPA 101 2012 Edition




7.2.1.15.1 “Where required..., the following door assemblies shall be inspected and tested not less than annually...

- (1) Door leaves equipped with panic hardware or fire exit hardware
- (2) Door assemblies in exit enclosures
- (3) Electrically controlled egress doors
- (4) Door assemblies with special locking arrangements

NFPA 101 2012 Edition

Door Inspection Requirements




Per 7.2.1.15.2 “Fire-rated door assemblies shall be inspected and tested in accordance with NFPA 80, ...”

NFPA 80 2010 Edition

Fire Door Inspection Requirements

Chapter 5 Care and Maintenance



NFPA 80 2010 Edition

Fire Door Inspection Requirements



Per 5.1.1.2 “The requirements of this chapter shall apply to **new and existing** installations.”

NFPA 80 2010 Edition

Fire Door Inspection Requirements

Per 5.1.5.1 “Repairs shall be made, and defects that could interfere with operation shall be **corrected without delay.**”



NFPA 80 2010 Edition

Fire Door Inspection Requirements



Per 5.1.5.2.1

“In cases where a **field modification** to a fire door assembly is desired, the laboratory with which the product or component being modified is listed shall be contacted and a description of the modifications shall be presented to the laboratory.”

Field Modifications



NFPA 80 2010 Edition

Fire Door Inspection Requirements

Per 5.2.1 “Fire door assemblies shall be inspected and tested not less than **annually**, and a **written record** of the inspection shall be signed and kept for the inspection by the **AHJ**.”



NFPA 80 2010 Edition

Fire Door Inspection Requirements























Per 5.2.3.1 “Functional testing of fire door and window assemblies shall be performed by **individuals with knowledge and understanding** of the operating components of the type of door subject to testing.”











Knowledge and Understanding

- VonDuprin 98/99 Rim Exit Device



SCREW CHART

Subassembly	Screw		Application
A  299 Strike 499F Strike		#10-24 x ¾" (19 mm)	Metal frame
		#10 x 1½" (38 mm) Wood screw	Wood frame
B 		#10-24 x 1" (25 mm)	Surface mount or Sex bolts 1¾" (44 mm) door
		#10-24 x 1½" (38 mm)	Sex bolts, 2¼" (57 mm) door
		#10 x 1¼" (32 mm) Wood screw	Surface mount (wood)
	Packaged with 990 Trims:		
		#10-24 x 1⅝" (35 mm)	1¾" (44 mm) door, 990 Trim
		#10-24 x 1⅞" (48 mm)	2¼" (57 mm) door, 990 Trim
C 		#10-24 x ¾" (19 mm)	Surface mount or Sex bolts 1¾" (44 mm) door
		#10-24 x 1⅞" (29 mm)	Sex bolts, 2¼" (57 mm) door
		#10 x 1¼" (32 mm) Wood screw	Surface mount (wood)
D 		#10-16 x ⅜" (10 mm) Thread cutting	End cap
E 		#10-24 x 1" (25 mm)	Surface mount (metal)
		#10 x 1¼" (32 mm) Wood screw	Surface mount (wood)
F 		#8-18 x ⅜" (10 mm) Thread cutting	Center case cover

Subassembly	Screw	
<p>A</p>  <p>299 Strike 499F Strike</p>	 	<p>#10-24 x 3/4" (19 mm)</p> <p>#10 x 1 1/2" (38 mm) Wood screw</p>
<p>C</p> 	  	<p>#10-24 x 3/4" (19 mm)</p> <p>#10-24 x 1 1/8" (29 mm)</p> <p>#10 x 1 1/4" (32 mm) Wood screw</p>
<p>E</p> 	 	<p>#10-24 x 1" (25 mm)</p> <p>#10 x 1 1/4" (32 mm) Wood screw</p>


PREPARATION CHART

Go to Instructions on next page before using preparation chart



*End cap bracket - 2 holes

Surface mount		Sex bolts	
Metal	#25 Drill	Metal	1/4" Drill (device side)
	#10-24 tap		13/32" Drill (trim side)
Wood	1/8" Drill	Wood	13/32" Drill thru
	pilot 1" deep		

*Prepare holes after lock side of device is mounted and hinge side is leveled



Door cut-outs

	Outside cylinder applications: Mark with template and cut-out: Metal door (cut device side) Wood door (cut thru)
	For trim applications with working lever, thumbpiece, or knob: Mark with template and cut out: (cut device side only)


Center case - 4 holes

Surface mount		Sex bolts or 990 trim	
Metal	#25 Drill	Metal	1/4" Drill (device side)
	#10-24 tap		13/32" Drill (trim side)
Wood	1/8" Drill	Wood	13/32" Drill thru
	pilot 1" deep		


Center case - 2 support holes

Metal	#25 Drill #10-24 tap
Wood	1/8" Drill pilot 1" deep
For 98-F/99-F (fire) wood door	
#825 Sex bolts (2) required	
Wood or composite	3/8" Drill thru
	5/8" Spade drill 1/16" Deep outside


299/299F Strike



Shim as needed



299



299F

NFPA 80 2010 Edition

Fire Door Inspection Requirements

Per 5.2.3.2 “Before testing, a visual inspection shall be performed to identify any damaged or missing parts that can create a hazard during testing or affect operation or resetting.”



NFPA 80 2010 Edition

Fire Door Inspection Requirements

Per 5.2.13.1 “Door openings and the surrounding areas shall be kept clear of anything that could obstruct or interfere with the **free operation of the door.**”




Which doors do I inspect?



Which doors do I inspect?

Where are my **fire doors**?

How can I tell?



INSPECTION CHECKLIST

Date _____

Pg. _____ of _____

BUILDING NAME _____

Door Number	Fire-Rating	Door Location	Compliant
			<input type="checkbox"/> YES <input type="checkbox"/> NO
Remarks:			

FRAME

- ☐ Loose Frame
- ☐ Damaged Frame
- ☐ Rust-through on Frame
- ☐ Missing Label
- ☐ Frame is Out of Alignment
- ☐ Incorrect Glass in Sidelight or Transom-light
- ☐ Broken Glass in Sidelight or Transom-light
- ☐ Missing Glazing Bead at Light(s)
- ☐ Missing Glazing Bead Screw(s)
- ☐ Improper Field Modification (Explain Modification)
- ☐ Incorrect Hardware Preparation (Explain)
- ☐ Unused Fastener Hole(s) in Frame
- ☐ Other _____

DOOR (cont.)

- ☐ Loose Light Kits
- ☐ Missing Light Kit Screw(s)
- ☐ Improper Field Modification (Explain Modification)
- ☐ Incorrect Hardware Preparation (Explain)
- ☐ Unused Fastener Hole(s) in Door(s)
- ☐ Improper Plant-ons
- ☐ Replace Door
- ☐ Other _____

OPERATIONAL TEST

- ☐ Door Does NOT Swing Freely
- ☐ Door Does NOT Close Completely
- ☐ Door Does NOT Securely Latch
- ☐ Electric Door Release Does NOT Allow Door to Close
- ☐ Door Bottom Drags Against Floor Material
- ☐ Door Rubs Against Frame
- ☐ Edges of Paired Doors Overlap
- ☐ Coordinator Does NOT Function Properly
- ☐ Other _____

DOOR

- ☐ Missing Door(s)
- ☐ Missing Label
- ☐ Damaged Door(s) (e.g., Dented, Bent)
- ☐ Rust-through on Door(s)
- ☐ Delamination of Door Skin or Face
- ☐ Incorrect Glass in Light(s)
- ☐ Broken Glass in Light(s)
- ☐ Light(s) is/are Too Large

HINGES/PIVOTS

- ☐ Missing Hinge(s)
- ☐ Incorrect Hinge(s)
- ☐ Loose Hinge(s)
- ☐ Missing Screw(s)
- ☐ Replace Hinge(s)
- ☐ Other _____

DOOR BOLTS

- ☐ Missing Top Flush Bolt
- ☐ Missing Bottom Flush Bolt
- ☐ Missing Strike (Top Bolt)
- ☐ Missing Strike (Bottom Bolt)
- ☐ Bottom Bolt does NOT Engage Strike
- ☐ Missing Bolt Head (Top)
- ☐ Missing Bolt Head (Bottom)
- ☐ Missing Rub Plate(s)
- ☐ Incorrect Type of Flush Bolt(s)
- ☐ Other _____

LOCKS

- ☐ Missing Lock
- ☐ Incorrect Latch Bolt Throw
- ☐ Non-fire Rated Latch Bolt
- ☐ Latch Bolt Binds
- ☐ Latch Bolt Missing
- ☐ Loose Lever(s) or Knob(s)
- ☐ Latch Bolt Does NOT Engage Strike
- ☐ Missing Strike Plate
- ☐ Missing Screw(s)
- ☐ Missing Flush Bolt
- ☐ Missing Flush Bolt Strike
- ☐ Other _____

FIRE EXIT HARDWARE

- ☐ Missing Fire Exit Device
- ☐ Missing Latch Bolt Assembly (Top)
- ☐ Missing Latch Bolt Assembly (Bottom)
- ☐ Missing Strike(s)
- ☐ Missing Vertical Rod (Top)
- ☐ Missing Vertical Rod (Bottom)
- ☐ Push Bar Does NOT Extend Halfway Across Door Width
- ☐ Non-fire Rated Panic Hardware (Dogging)
- ☐ Missing Lever or Knob

FIRE EXIT HARDWARE (cont.)

- ☐ Other _____
- ☐ Missing Door Closer(s)
- ☐ Leaking Door Closer(s)
- ☐ Missing Arm(s)
- ☐ Broken Arm(s)
- ☐ Missing Closer(s)
- ☐ Does NOT Close Door Completely
- ☐ Missing Screw(s)
- ☐ Missing Drop and/or Adapter Plate(s)
- ☐ Hold-open Arm(s)
- ☐ Missing Coordinator
- ☐ Missing Carry Bar
- ☐ Broken Coordinator
- ☐ Broken Carry Bar
- ☐ Overhead Hold-open (Surface or Concealed)
- ☐ Other _____

MISCELLANEOUS

- ☐ Missing Threshold/ Saddle
- ☐ Incorrect Clearance (Top of Door to Frame)
- ☐ Incorrect Clearance (Hinge Edge to Frame)
- ☐ Incorrect Clearance (Lock Edge to Frame)
- ☐ Incorrect Clearance (Door Bottom to Floor)
- ☐ Incorrect Clearance (Between Doors)
- ☐ Missing Astragal
- ☐ Missing or Damaged Gasketing/Smoke Seal
- ☐ Kick-down Door Holder
- ☐ Door Wedge
- ☐ Door Stop with Hold Open (Manual)
- ☐ Protection Plate(s) too Large
- ☐ Protection Plate(s) Missing screw(s)
- ☐ Signage Too Large
- ☐ Signage, Screwed/Nailed to Door
- ☐ Other _____


A Program of the
Door and Hardware Institute

("White" copy is ORIGINAL • "Pink" copy is DUPLICATE COPY • "Yellow" copy is INSPECTOR'S COPY)

© COPYRIGHT 2008 THE DOOR AND HARDWARE INSTITUTE. ALL RIGHTS RESERVED.
Use of this inspection form without the express written consent of the Door and Hardware Institute is strictly forbidden.

NFPA 80 2010 Edition


Fire Door Inspection Requirements

AS A MINIMUM!

NFPA 80 2010 Edition

Fire Door Inspection Requirements


**No open
holes or
breaks...**



NFPA 80 2010 Edition

Fire Door Inspection Requirements

Glazing...
intact and
securely
fastened...




Examples of labels

NFPA 80 2010 Edition

Fire Door Inspection Requirements


**...secured,
aligned,
and in
working
order...**



NFPA 80 2010 Edition

Fire Door Inspection Requirements

**No
missing
or broken
parts**




Missing Parts




NFPA 80 2010 Edition

Fire Door Inspection Requirements

**Clearances
are limited
to...**




Clearances



NFPA 80 2010 Edition

Fire Door Inspection Requirements


Self-closing device... completely closes from full open position




NFPA 80 2010 Edition

Fire Door Inspection Requirements

If coordinator...
inactive leaf must
close before the
active leaf



Gravity Type





Bar Type

NFPA 80 2010 Edition

Fire Door Inspection Requirements


**Latching
hardware
operates
and
secures...**



NFPA 80 2010 Edition

Fire Door Inspection Requirements


**Fire Exit
Hardware...**



NFPA 80 2010 Edition

Fire Door Inspection Requirements

**Nothing
that
interferes
with the
operation...**




Interference



NFPA 80 2010 Edition

Fire Door Inspection Requirements


**No field
modifications
that void the
label!**



NFPA 80 2010 Edition

Fire Door Inspection Requirements

**If required,
gasketing
and edge
seals...
presence
and
integrity**



NFPA 80 2010 Edition

Fire Door Inspection Requirements

Per 5.2.1 “Fire door assemblies shall be inspected and tested not less than **annually**, and a **written record** of the inspection shall be signed and kept for the inspection by the **AHJ**.”



The Performance-Based Option

**When there are THOUSANDS
of Fire Doors...**

An AUDIT program

Subject to the AHJ



After a Fire...



...with Properly-Functioning Fire Doors

With Properly-Functioning Fire Doors



**At
Minimum,
What
Will
You
Test &
Inspect?**



As A Minimum

5.2.4.2 As a minimum, the following items shall be verified:

- (1) No open holes or breaks exist in surfaces of either the door or frame.
- (2) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.
- (3) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.
- (4) No parts are missing or broken.
- (5) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.
- (6) The self-closing device is operational; that is, the active door completely closes when operated from the full open position.
- (7) If a coordinator is installed, the inactive leaf closes before the active leaf.
- (8) Latching hardware operates and secures the door when it is in the closed position.
- (9) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.
- (10) No field modifications to the door assembly have been performed that void the label.
- (11) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.

More Information?

John Lozano ICPL, CJIL, CHSP, CFDI
Hardware Consultant

ALLEGION

947 Hawthorn Drive

Itasca, IL 60143

Office: 877.282.1721 ext.4809

Mobile: 414-881-0448

Fax: 1-888-829-1094

Email: john.lozano@allegion.com



ALLEGION™

PIONEERING SAFETY™



ALLEGIONTM

PIONEERING SAFETYTM